

**CITY OF NEWTON
MASSACHUSETTS**

PETITION for GRANT OF LOCATION

To the Petitioner:

City of Newton Ordinance Section 23-52 requires that each petition for grant of location be submitted to the City Council before it is sent to the Public Works Department for a preliminary review. The comments of the Public Works Commissioner will be part of the record submitted to the City Council. Upon filing with the City Council, the petition will be scheduled for a public hearing before the Public Facilities Committee of City Council. **The petitioner is responsible for insuring that the petition is complete, and all required materials are in order for review.** Attached please find the City Engineer's Standard Requirements for Plans and the Department of Public Works Permit Processing brochure.

Grant of Location Process:

1. Applicant submits completed Petition Form and required materials to the City Council
2. Public Works Department conducts preliminary review and gives written comments to the applicant
3. Engineering Division files Petition Form with comments with the Clerk of the City Council
4. City Council schedules petition for a public hearing before the Public Facilities Committee of the City Council
5. Public Facilities Committee recommendations are forwarded to the City Council for a final decision

Questions may be directed to:

Lou Taverna, City Engineer, 617-796-1020

Cassidy Flynn, Clerk of the Public Facilities Committee 617-796-1213

I. IDENTIFICATION (Please Type or Print Clearly)

Company Name NATIONALGRID

201 Rivermoor Street

Address _____

West Roxbury, MA 02132

Phone Number 617-894-3896

Fax Number _____

Mary Mulrone

Permit Representative

Contact Person _____

Title _____

Mary Mulrone

January 19, 2023

Signature _____

Date _____

Person filing application

If a telecommunications company, indicate how certified by the Department of Telecommunications and Energy:

II. DESCRIPTION OF PROJECT: to be completed by petitioner

Write here or attach a description of the project including, location, proposed time frame for completion, type of materials to be used, benefit provided to the City, project mitigation plan as applicable, street reconstruction plan including timetable for completion.

Nationalgrid requests a Main Extension to install approximately 75 feet of 6- inch Plastic main extending from the existing 6 -inch Cast Iron (1916) main in Tyler Ter for new service at #75 Pleasant St.

Service Installation- Install approximately 60 feet of 2- inch, Plastic service at #75 Pleasant St extending from the new 6- inch, Plastic main extension.

A. Include or attach a sketch to provide a visual description of the project. If plans are attached, provide:
Title of Plan _____ Date of plan _____

III. PUBLIC WORKS DEPARTMENT REVIEW

Date received by Public Works Department January 20, 2023

Check One:
Minor Project Major Project Lateral

(Refer to City Engineer Standard Requirements for Plans for definition of minor and major project)

Plans Submitted:
Certified Plot Plan Stamped Plans

DATE AND COMMENTS:

RECOMMENDATIONS:

The contractor of record shall obtain a Sidewalk Crossing & Trench Permits w/DPW prior to any construction. Pedestrian access shall be accommodated for the duration in accordance with the DPW requirements. Siltation control shall be placed & maintained in the catch basins w/in the construction zone. The contractor shall contact the Utilities Division to mark out water-sewer-drain lines.	prior to any construction as the City is not a member of Dig Safe. Upon completion an as built shall be submitted to the DPW. All restoration shall be in kind to current standards. <i>John Daghljan, Associate City Engineer</i> <i>June 20, 2023</i>
---	---

V. RECOMMENDATION TO PUBLIC FACILITIES COMMITTEE:

Shawna Sullivan Digitally signed by Shawna Sullivan
Date: 2023.01.23 17:37:54 -05'00' _____
Commissioner, Public Works Date