

CITY OF NEWTON
Department of Public Works
ENGINEERING DIVISION

Memorandum

To: Councilor Alison Leary, Facilities Committee Chair.


From: John Daghlian, Associate City Engineer

Re: Walnut Street: pole #437/34 w/anchor guy

Date: October 14, 2022

CC: Jim Mcgonagle, Commissioner
Shawna Sullivan, Chief of Staff
Lou Taverna, PE City Engineer
Cassidy Flynn, Associate City Clerk
Kim Ritcey, DPW Inspector

In reference to the above location, the following are my comments for a plan entitled:



Executive Summary:

This is an after the fact filing, Engineering received this filing today. Eversource installed a new replacement pole within the limits of the original GOL and limits of relocation, however; the new pole received a guy & anchor not part of the original GOL. At this time Eversource is petitioning the for the guy & anchor that is needed for the stress imposed on the pole given the angle of the overhead wires along Walnut Street Walnut Park.



If you have any questions or concerns, please call me at 617-796-1023.