

CITY OF NEWTON, MASSACHUSETTS
PURCHASING DEPARTMENT
purchasing@newtonma.gov
Fax (617) 796-1227

January 10, 2024

ADDENDUM #2
INVITATION FOR BID #24-39

MAIN LIBRARY HVAC SYSTEM IMPROVEMENTS

THIS ADDENDUM IS TO: CHANGE THE BID SUBMISSION DATE AND TIME AND TO ANSWER THE FOLLOWING QUESTIONS.

THE BID SUBMISSION DATE AND TIME ARE CHANGED TO

FEBRUARY 1, 2024, AT 10:30AM

THE QUESTION DEADLINE DATE AND TIME ARE NOT CHANGED

Q1. The “receiving area” has a spline ceiling. We have determined the only way for the (3) 4” conduit to be run concealed in finished areas is for this spline ceiling to be removed and replaced. Is it possible for this work to be added to this contract?

A1. The general contractor shall remove the existing spline ceiling in the Receiving Area as required to facilitate installation of the electrical conduits. The general contractor shall re-install the ceiling after commencement of the electrical work. Ceiling shall be patched to match existing.

All other terms and conditions of the IFB remain unchanged.

**PLEASE ENSURE THAT YOU ACKNOWLEDGE ALL ADDENDA ON YOUR
BID FORM. FAILURE TO ACKNOWLEDGE ALL ADDENDA COULD
RESULT IN REJECTION OF YOUR BID AS NONRESPONSIVE.**

Thank you.



Nicholas Read
Chief Procurement Officer