

Nadia Khan

From: Louis M. Taverna
Sent: Wednesday, March 4, 2020 8:44 AM
To: Emily Norton
Cc: Andrea W. Kelley; Emily Norton; Jennifer Steel; Julia Malakie; Maria P. Rose; Nadia Khan; Pamela Wright; John Daghlian; Shawna Sullivan; Jennifer Caira
Subject: RE: Ascend project drainage
Attachments: Washington St 1089.pdf

Councilor,

Page 2 of engineering division's review memo describes a proposed rain garden as stormwater management for this facility.

Lou

"Based upon DPW's request, the enhancements to the site includes a new rain garden to collect and treat runoff from the parking lot with appropriate plantings that will improve stormwater quality and quantity of runoff from the site. The rain garden does have an overflow connection to the City's drainage system via a HDPE pipe which shall be a ductile iron pipe, additionally calculations are needed to demonstrate the treatment and capacity of the rain garden; these may be submitted at the Building Permit phase should this Special Permit receive approval. In concert with the proposed overflow connection, a Pre & Post Closed Circuit Television [CCTV] inspection must be performed and witnessed by the Engineering Division, 48 hours prior notice shall be given for each inspection. Washington Street is a reinforced cement concrete roadway, restoration of any trench on the street shall be to the original design of two-way reinforced cement concrete slabs, depending on the limit of the trench work either a 1/3 or half, or entire slab maybe required; this shall be determined once the Utility Connection Permit is submitted."

Lou

Louis M. Taverna, P.E.
City Engineer
City of Newton DPW
1000 Commonwealth Ave
Newton, MA 02459
617-796-1020

From: Emily Norton <councilornorton@gmail.com>
Sent: Tuesday, March 3, 2020 4:37 PM
To: Louis M. Taverna <ltaverna@newtonma.gov>

Cc: Andrea W. Kelley <akelley@newtonma.gov>; Emily Norton <enorton@newtonma.gov>; Jennifer Steel <jsteel@newtonma.gov>; Julia Malakie <jmalakie@newtonma.gov>; Maria P. Rose <mrose@newtonma.gov>; Nadia Khan <nkhan@newtonma.gov>; Pamela Wright <pwright@newtonma.gov>
Subject: Re: Ascend project drainage

[DO NOT OPEN links/attachments unless you are sure the content is safe.]

Hi all can someone respond to this email. I know it's being voted on tonight.

On Fri, Jan 31, 2020 at 5:08 PM Emily Norton <councilornorton@gmail.com> wrote:

Hi Lou,

I'm reaching out about the Ascend project in West Newton, and what they are planning to do vis a vis stormwater. I hope we are pushing them to treat as much stormwater as possible.

Thanks,

Emily

Emily Norton
Newton Ward 2 Councilor
www.emilynorton.org
Office (617) 795-0362
Cell (508) 397-6839
She/her/hers

--

Emily Norton
Newton Ward 2 Councilor
www.emilynorton.org
Office (617) 795-0362
Cell (508) 397-6839
She/her/hers