

CITY OF NEWTON  
Department of Public Works  
ENGINEERING DIVISION

MEMORANDUM

To: Council Rick Lipof, Land Use Committee Chairman

From: John Daghlian, Associate City Engineer

Re: Special Permit – 99 Pine Ridge Road

Date: April 1, 2020

CC: Barney Heath, Director of Planning  
Jennifer Caira, Deputy Director Planning  
Lou Taverna, PE City Engineer  
Nadia Khan, Committee Clerk  
Neil Cronin, Chief Planner  
Katie Whewell, Sr. Planner

---

In reference to the above site, I have the following comments for a plan entitled:

*Topographic Site Plan  
Showing Proposed Conditions at  
#99 Pine Ridge Road  
Newton, MA  
Prepared By: VTP Associates Inc.  
Dated: July 18, 2019  
Revised: August 5, 2019*

*Executive Summary:*

This Special Permit application entails the demolition of an existing garage and the construction of a new two stall garage and carriage house. At the time of this review drainage calculations were not provided; however, the plan does show a stormwater collection system to collect roof and driveway runoff and infiltrate to underground system.

An Operations and Maintenance (O&M) plan for Stormwater Management Facilities needs to be drafted and submitted for review. Once approved the O&M must be adopted by applicant, incorporated into the deeds; and recorded at the Middlesex Registry of Deeds. A copy of the recording instrument shall be submitted to the Engineering Division.

On-site soil evaluation is required to determine the seasonal high groundwater elevation and percolation rate these tests shall be performed within 25-feet of each system; soil logs shall be submitted for review.

Water and sanitary sewer services are being extended from the main house to this building.

Construction Management:

1. A construction management plan is needed for this project. At a minimum, it must address the following: staging site for construction equipment, construction materials, parking of construction worker's vehicles, phasing of the project with anticipated completion dates and milestones, safety precautions, emergency contact personnel of contractor. It shall also address any anticipated dewatering during construction, site safety & stability, and impact to abutting properties.
2. Stabilized driveway entrances are needed during construction which will provide a tire wash and mud removal to ensure City streets are kept clean.

Drainage:

1. It is imperative to note that the ownership, operation, and maintenance of the proposed drainage system and all appurtenances including but not limited to the drywells, catch basins, and pipes are the sole responsibility of the property owner(s).

Environmental:

1. Has a 21E investigation & report been performed on the site, if so copies of the report should be submitted to the Newton Board of Health and the Engineering Division.
2. Are there any existing underground oil or fuel tanks, are they to be removed, if they have been evidence should be submitted to the Newton Fire Department, and Newton Board of Health.

Water:

1. All water connections shall be chlorinated & pressure tested in accordance to AWWA and the City of Newton Construction Standards and Specifications prior to opening the connection to existing pipes.
2. Approval of the final configuration of the water service(s) shall be determined by the Utilities Division, the engineer of record should submit a plan to the Director of Utilities for approval

General:

1. All trench excavation contractors shall comply with Massachusetts General Laws Chapter 82A, Trench Excavation Safety Requirements, to protect the general public from unauthorized access to unattended trenches. Trench Excavation Permit required. This applies to all trenches on public and private property. *This note shall be incorporated onto the plans*
2. All tree removal shall comply with the City's Tree Ordinance.
3. The contractor is responsible for contacting the Engineering Division and scheduling an appointment 48 hours prior to the date when the utilities will be made available for an inspection of water services, sewer service, and drainage system installation. The utility in question shall be fully exposed for the inspector to view; backfilling shall only take place when the City's Inspector has given their approval. *This note should be incorporated onto the plans*
4. The applicant will have to apply for Street Opening, Sidewalk Crossing, and Utilities Connecting permits with the Department of Public Works prior to any construction. *This note must be incorporated onto the site plan.*
5. The applicant will have to apply for a Building Permits with the Department of Inspectional Service prior to any construction.
6. Prior to Occupancy Permit being issued, an As-Built Plan shall be submitted to the Engineering Division in both digital format and in hard copy. The plan should show all utilities and final grades, any easements and final grading, improvements and limits of restoration work. The plan shall also include profiles of the various new utilities, indicating rim & invert elevations, slopes of pipes, pipe material, and swing ties from permanent building corners. ***This note must be incorporated onto the final contract plans.***

7. All site work including trench restoration must be completed before a Certificate of Occupancy is issued. *This note must be incorporated onto the site plan.*
8. If any changes from the original approved design plan that are required due to unforeseen site conditions, the engineer of record shall submit a revised design & stamped and submitted for review and approval prior to continuing construction.

Note: If the plans are updated it is the responsibility of the Applicant to provide all City Departments [Conservation Commission, ISD, and Engineering] involved in the permitting and approval process with complete and consistent plans.

If you have any questions or concerns please feel free to contact me @ 617-796-1023.