

CITY of NEWTON
ENGINEERING DIVISION

MEMORANDUM

To: Alderman Mark Laredo, Land Use Committee Chairman

From: John Daghlian, Associate City Engineer

Re: Special Permit – 740 Beacon Street

Date: March 26, 2014

CC: Lou Taverna, PE City Engineer
Linda Finucane, Associate City Clerk
Alexandria Ananth, Chief Planner
Dan Sexton, Sr. Planner

In reference to the above site, I have the following comments for a plan entitled:

*Topographic Site Plan
Showing Proposed Conditions at
740 Beacon Street
Newton, MA
Prepared by: VTP Associates Inc.
Dated: October 21, 2013
Last Revised: March 10, 2014*

Executive Summary:

The existing autobody & repair shop intends to place an addition in the form of a pre-fabricated spray booth adjacent to the building over a paved surface. Since no new impervious surface is being added, no new drainage improvements are needed. However, floor drains with MDC gas traps will be required that will be connected to the sanitary sewer service.

If the special permit is approved an Approval Not Required (ANR) plan will be needed in accordance to Massachusetts General Laws Chapter 41 Section 81P requiring the two separate lots be combined into one lot.

Environmental:

1. Has a 21E investigation & report been performed on the site, if so copies of the report should be submitted the Newton Board of Health and the Engineering Division.
2. Are there any existing underground oil or fuel tanks, that need to be removed for the installation of the spray booth? If this is the case then the applicant will need permits from the Newton Fire Department, and Newton Board of Health.

Sewer:

1. A detailed profile is needed which shows the existing water main, proposed water service(s), sewer main and proposed sewer service(s) with the slopes and inverts labeled to ensure that there are no conflicts between the sewer services and the water service. The minimum slope for a service is 2.0%, with a maximum of 10%. Pipe material shall be 6" diameter SDR 35 PVC pipe within 10' of the dwelling then 4" pipe per Massachusetts State Plumbing Code. In order to verify the slopes and inverts of the proposed service connection, two manholes of the existing sanitary sewer system need to be identified on the plan with rim & invert elevations.
2. A detail of the MDC gas trap or oil/water separator is needed.

General:

1. As of January 1, 2009, all trench excavation contractors shall comply with Massachusetts General Laws Chapter 82A, Trench Excavation Safety Requirements, to protect the general public from unauthorized access to unattended trenches. Trench Excavation Permit required. This applies to all trenches on public and private property. *This note shall be incorporated onto the plans*
2. All tree removal shall comply with the City's Tree Ordinance.
3. The contractor is responsible for contacting the Engineering Division and scheduling an appointment 48 hours prior to the date when the utilities will be made available for an inspection of water services, sewer service, and drainage system installation. The utility is question shall be fully exposed for the inspector to view; backfilling shall only take place when the City's Inspector has given their approval. *This note should be incorporated onto the plans*

4. The applicant will have to apply for a Utilities Connection permit with the Department of Public Works prior to any construction. *This note must be incorporated onto the site plan.*
5. The applicant will have to apply for a Building Permits with the Department of Inspectional Service prior to any construction.
6. Prior to Occupancy Permit being issued, an As-Built Plan shall be submitted to the Engineering Division in both digital format and in hard copy. The plan should show all utilities and final grades, any easements and final grading. *This note must be incorporated onto the site plan.*
7. All site work must be completed before a Certificate of Occupancy is issued. *This note must be incorporated onto the site plan.*

Note: If the plans are updated it is the responsibility of the Applicant to provide all City Departments [Conservation Commission, ISD, and Engineering] involved in the permitting and approval process with complete and consistent plans.

If you have any questions or concerns please feel free to contact me @ 617-796-1023.