

**CITY OF NEWTON
ENGINEERING DIVISION**

MEMORANDUM

To: Alderman Ted Hess-Mahan, Land Use Committee Chairman

From: John Daghlian, Associate City Engineer

Re: Special Permit – 176 Boylston Street

Date: April 26, 2013

CC: Lou Taverna, PE City Engineer (via email)
Linda Finucane, Associate City Clerk (via email)
Eve Tapper, Chief Planner (via email)
Alexandria Ananth, Sr. Planner (via email)

In reference to the above site, I have the following comments for a plan entitled:

*Milton's
176 Boylston Street
Area Plans
Newton, MA
Prepared by: Arrowstreet
Dated: March 4, 2013*

Executive Summary:

The existing retail store has planned to add two spaces to the building, based on the architects calculations the impervious area has an additional 701 square feet, thus there is a requirement for on-site drainage improvement for the net additional stormwater runoff.

Drainage:

1. A drainage analysis needs to be performed based on the City of Newton's 100-year storm event of 6-inches over a 24-hour period. All runoff from impervious areas need to be infiltrated on site, for the project. The design of the proposed on site drainage system needs to comply with the MassDEP Stormwater Regulations and City Ordinances.

2. An Operations and Maintenance (O&M) plan for Stormwater Management Facilities needs to be drafted and submitted for review. Once approved the O&M must be adopted by applicant, incorporated into the deeds; and recorded at the Middlesex Registry of Deeds. A copy of the recording instrument shall be submitted to the Engineering Division.
3. It is imperative to note that the ownership, operation, and maintenance of the proposed drainage system and all appurtenances including but not limited to the drywells, catch basins, and pipes are the sole responsibility of the Homeowners Association.

Environmental:

1. Has a 21E investigation & report been performed on the site, if so copies of the report should be submitted to the Newton Board of Health and the Engineering Division.
2. Are there any existing underground oil or fuel tanks, are they to be removed, if they have been evidence should be submitted to the Newton Fire Department, and Newton Board of Health.

Construction Management:

1. A construction management plan is needed for this project. At a minimum, it must address the following: staging site for construction equipment, construction materials, parking of construction worker's vehicles, phasing of the project with anticipated completion dates and milestones, safety precautions, emergency contact personnel of contractor. Anticipated dewatering during construction, site safety & stability. Impact to abutting properties.
2. Stabilized driveway entrances are needed during construction which will provide a tire wash and mud removal to ensure City streets are kept clean.

General:

1. As of January 1, 2009, all trench excavation contractors shall comply with Massachusetts General Laws Chapter 82A, Trench Excavation Safety Requirements, to protect the general public from unauthorized access to unattended trenches. Trench Excavation Permit required. This applies to all trenches on public and private property. *This note shall be incorporated onto the plans*
2. All tree removal shall comply with the City's Tree Ordinance.
3. The contractor is responsible for contacting the Engineering Division and scheduling an appointment 48 hours prior to the date when the utilities will be made available for an inspection of water services, sewer service, and drainage system installation. The utility is question shall be fully exposed for the inspector to view; backfilling shall only take place when the City's Inspector has given their approval. *This note should be incorporated onto the plans*
4. The applicant will have to apply for a Building Permits with the Department of Inspectional Service prior to any construction.
5. Prior to Occupancy Permit being issued, an As-Built Plan shall be submitted to the Engineering Division in both digital format and in hard copy. The plan should show all utilities and final grades, any easements and final grading. *This note must be incorporated onto the site plan.*
6. If a Certificate of Occupancy is requested prior to all site work being completed, the applicant will be required to post a Certified Bank Check in the amount to cover the remaining work. The City Engineer shall determine the value of the uncompleted work. *This note must be incorporated onto the site plan.*

Note: If the plans are updated it is the responsibility of the Applicant to provide all City Departments [Conservation Commission, ISD, and Engineering] involved in the permitting and approval process with complete and consistent plans.

If you have any questions or concerns please feel free to contact me @ 617-796-1023.