

**CITY OF NEWTON  
ENGINEERING DIVISION**

**MEMORANDUM**

To: Alderman Ted Hess-Mahan, Land Use Committee Chairman

From: John Daghlian, Associate City Engineer

Re: Special Permit – 176 Boylston Street

Date: June 13, 2013

CC: Lou Taverna, PE City Engineer (via email)  
Linda Finucane, Associate City Clerk (via email)  
Alexandria Ananth, Chief Planner (via email)

---

In reference to the above site, I have the following comments for a plan entitled:

*Milton's  
176 Boylston Street  
Area Plans  
Newton, MA  
Prepared by: Arrowstreet  
Dated: March 4, 2013  
Revised: 6-3-'13*

*Executive Summary:*

In response to my memo dated June 13<sup>th</sup>, R.J. O'Connell, has submitted supplemental calculations that clarify the design in terms to drainage requirements. Accordingly since a net increase of 4,480 square feet is being provided, no additional drainage improvements is required.

Note: If the plans are updated it is the responsibility of the Applicant to provide all City Departments [Conservation Commission, ISD, and Engineering] involved in the permitting and approval process with complete and consistent plans.

If you have any questions or concerns please feel free to contact me @ 617-796-1023.