

**CITY OF NEWTON**  
**ENGINEERING DIVISION**

MEMORANDUM

To: Alderman Ted Hess-Mahan, Land Use Committee Chairman

From: John Daghlian, Associate City Engineer

Re: Special Permit – 44 Sylvan Avenue

Date: June 6, 2013

CC: Lou Taverna, PE City Engineer  
Linda Finucane, Associate City Clerk  
Alexandria Ananth, Sr. Planner

---

In reference to the above site, I have the following comments for a plan entitled:

*Sylvan Avenue Reality Trust*  
*Special Permit Application Package*  
*Newton, MA*  
*Prepared by: Stantec Consulting Service*  
*Dated: February 1, 2013*

*Executive Summary:*

This single-family dwelling is proposing a garage in excess of 700 square feet. The home was approved via a By- Right Building Permit issued from Inspectional Services and reviewed by Engineering. All drainage and site construction issues were addressed via the Building Permit.

*General:*

1. As of January 1, 2009, all trench excavation contractors shall comply with Massachusetts General Laws Chapter 82A, Trench Excavation Safety Requirements, to protect the general public from unauthorized access to unattended trenches. Trench Excavation Permit required. This applies to all trenches on public and private property. *This note shall be incorporated onto the plans*
2. All tree removal shall comply with the City's Tree Ordinance.

3. The contractor is responsible for contacting the Engineering Division and scheduling an appointment 48 hours prior to the date when the utilities will be made available for an inspection of water services, sewer service, and drainage system installation. The utility in question shall be fully exposed for the inspector to view; backfilling shall only take place when the City's Inspector has given their approval. *This note should be incorporated onto the plans.*
4. The applicant will have to apply for Street Opening, Sidewalk Crossing, and Utilities Connecting permits with the Department of Public Works prior to any construction. *This note must be incorporated onto the site plan.*
5. Prior to Occupancy Permit being issued, an As-Built Plan shall be submitted to the Engineering Division in both digital format and in hard copy. The plan should show all utilities and final grades, any easements and final grading. *This note must be incorporated onto the site plan.*
6. If a Certificate of Occupancy is requested prior to all site work being completed, the applicant will be required to post a Certified Bank Check in the amount to cover the remaining work. The City Engineer shall determine the value of the uncompleted work. *This note must be incorporated onto the site plan.*

Note: If the plans are updated it is the responsibility of the Applicant to provide all City Departments [Conservation Commission, ISD, and Engineering] involved in the permitting and approval process with complete and consistent plans.

If you have any questions or concerns please feel free to contact me @ 617-796-1023.