

Linda M. Finucane

From: Laurance Lee <llee@rfl-law.com>
Sent: Wednesday, September 09, 2015 7:10 AM
To: John Daghlian; Stephen Pantalone
Cc: Linda M. Finucane
Subject: 28 Sumner Street, Newton
Attachments: 214212bp_9-Zoning Plan_Sht 1of4[3].pdf

Dear John and Steve:

Please find attached updated proposed site plan for the project. Pursuant to the Fire Department's request the main driveway and walkway on the northerly side of the site were widened slightly to a cumulative 20 feet clearance for a fire engine (15 ft for drive and 5 for walkway). No other changes were made.

Joe Porter of VTP confirmed no changes to the drainage calculations – please feel free to independently verify with him.


Please call or email me with any questions.

Thank you

--
Laurance S.L. Lee
Attorney

Rosenberg, Freedman & Lee LLP
246 Walnut Street - Suite 201
Newton, Massachusetts 02460
T: 617-964-7000 x30
F: 617-964-4025
Email: llee@rfl-law.com
Firm web site: www.rfl-law.com

Send files securely:
<https://securesend.rfl-law.com/filedrop/llee@rfl-law.com>

 *please consider the environment before printing this email*

STATEMENT OF CONFIDENTIALITY

This e-mail, including any attached files, may contain confidential and privileged information for the sole use of the intended recipient(s). Any review, use, distribution or disclosure by others is strictly prohibited. If you are not the intended recipient (or authorized to receive information for the recipient), please contact the sender by reply e-mail and delete all copies of this message. Thank you.

RECEIVED
Newton City Clerk
2015 SEP -9 AM 11:16
DAVID A. OLSON, OMC
Newton, MA 02459

