

**CITY OF NEWTON
DEPARTMENT OF PUBLIC WORKS
ENGINEERING DIVISION**

MEMORANDUM

To: Alderman Mark Laredo, Land Use Committee Chairman

From: John Daghlian, Associate City Engineer

Re: Special Permit – 102 McCarthy Road

Date: October 2, 2014

CC: Lou Taverna, PE City Engineer
Linda Finucane, Associate City Clerk
Alexandria Ananth, Chief Planner
Dan Sexton, Sr. Planner

In reference to the above site, I have the following comments for a plan entitled:

*102 McCarthy Road
Newton, MA
Prepared by: Clear Water Environmental
Dated: June 9, 2014
Revised: 8/7/14*

Executive Summary:

The proposed project includes the removal of the existing garage and breezeway, and constructing a new garage and living space. Based on the calculations submitted the threshold for on-site drainage is not required, however; the applicant is proposing an infiltration system designed for the 100-year storm event for the proposed work. The site plan however does not show the location of the system nor is there any detail of the system. Prior to the Building Permit on site soil evaluation will be required for verification of design assumption made by the engineer of record.

If the interior of the house is renovated or gutted out, then both water and sewer services shall be updated per the Utilities Division.

Drainage:

1. An on-site soil evaluation needs to be performed to obtain the seasonal high groundwater elevation, percolation rate in accordance to Title V. This information must be submitted with the drainage study. The locations of these tests need to be shown on the site plan and must be performed within 20-feet of a proposed system.
2. An Operations and Maintenance (O&M) plan for Stormwater Management Facilities needs to be drafted and submitted for review. Once approved the O&M must be adopted by applicant, incorporated into the deeds; and recorded at the Middlesex Registry of Deeds. A copy of the recording instrument shall be submitted to the Engineering Division.
3. It is imperative to note that the ownership, operation, and maintenance of the proposed drainage system and all appurtenances including but not limited to the drywells, catch basins, and pipes are the sole responsibility of the property owner(s).

General:

1. All trench excavation contractors shall comply with Massachusetts General Laws Chapter 82A, Trench Excavation Safety Requirements, to protect the general public from unauthorized access to unattended trenches. Trench Excavation Permit required. This applies to all trenches on public and private property. *This note shall be incorporated onto the plans*
2. All tree removal shall comply with the City's Tree Ordinance.
3. The contractor is responsible for contacting the Engineering Division and scheduling an appointment 48 hours prior to the date when the utilities will be made available for an inspection of the drainage system installation. The utility in question shall be fully exposed for the inspector to view; backfilling shall only take place when the City's Inspector has given their approval. *This note should be incorporated onto the plans*
4. The applicant will have to apply for Street Opening, and Sidewalk Crossing permits with the Department of Public Works prior to any construction. *This note must be incorporated onto the site plan.*
5. The applicant will have to apply for a Building Permits with the Department of Inspectional Service prior to any construction.

6. Prior to Occupancy Permit being issued, an As-Built Plan shall be submitted to the Engineering Division in both digital format and in hard copy. The plan should show all utilities and final grades, any easements and final grading. *This note must be incorporated onto the site plan.*
7. If a Certificate of Occupancy is requested prior to all site work being completed. *This note must be incorporated onto the site plan.*

Note: If the plans are updated it is the responsibility of the Applicant to provide all City Departments [Conservation Commission, ISD, and Engineering] involved in the permitting and approval process with complete and consistent plans.

If you have any questions or concerns please feel free to contact me @ 617-796-1023.