

CITY OF NEWTON
Department of Public Works
ENGINEERING DIVISION

MEMORANDUM

To: Council Rick Lipof, Land Use Committee Chairman

From: John Daghlian, Associate City Engineer

Re: Special Permit – 740 Beacon Street

Date: April 12, 2021

CC: Barney Heath, Director of Planning
Jennifer Caira, Deputy Director
Lou Taverna, PE City Engineer
Nadia Khan, Committee Clerk
Neil Cronin, Chief Planner
Michael Gleba, Sr. Planner
Katie Whewell, Sr. Planner

In reference to the above site, I have the following comments for a plan entitled:

740 Beacon Street
Proposed Conditions Site Plan
Prepared by: Verne T. Porter, Jr., PLS
Dated: December 21, 2020
Received by Engineering: April 6, 2021

Executive Summary:

This application entails the conversion of a collision repair shop into a marijuana retail shop. The site is approximately 100% impervious with no on site drainage collection system. The plans indicate that a couple of landscape planing beds will be installed by removing some asphalt pavement. The runoff from the site will continue to be un-controlled towards Beacon Street and into the City drainage system. An existing building on the site will be razed to expand the on-site parking along the east side of the main building. DPW encourages all developments to enhance stormwater runoff, if a rain garden or on-site infiltration system could be added; it would improve water quality runoff and re-charge the groundwater.

If the existing structure is remodeled by more than 50% then the water and sanitary sewer services shall be updated to current standards.

As part of the access the driveway apron should be updated to current City Standards.



Access Driveway Apron

Environmental:

1. Has a 21E Investigation and report been performed on the site, if so, copies of the report should be submitted to the Newton Board of Health and Engineering Division.
2. Are there any existing underground oil or fuel tanks? Have they been removed, if they have been, evidence of the proper removal should be submitted to the Newton Fire Department and the Board of Health.

General:

1. 5 Year Moratorium – if at time of construction the roadway is under a 5-year moratorium, the roadway must be milled and paved gutter-to-gutter for a distance of 25 feet in each direction from the outermost trenches.
2. All trench excavation shall comply with Massachusetts General Law Chapter 82A, Trench Excavation Safety Requirements, and OSHA Standards to protect the general public from unauthorized access to unattended trenches or excavations. Trench Excavation Permit is required prior to any construction. This applies to all trenches on public and private property. *This note shall be incorporated onto the final plans.*
3. All tree removal shall comply with the City's Tree Ordinance.
4. The contractor of record is responsible for contacting the Engineering Division and scheduling an appointment 48-hours prior to the date when the utilities will be made available for an inspection of water services, sewer services and drainage system installation. The utility in question shall be fully exposed for the Inspector to view, backfilling shall only take place when the City Engineer's Inspector has given their approval. *This note shall be incorporated onto the final plans.*
5. The applicant shall apply for a Building Permit with the Inspectional Services Department prior to ANY construction.
6. All site work including trench restoration, sidewalk, curb ,apron and loam border (where applicable) shall be completed before a Certificate of Occupancy is issued. *This note shall be incorporated onto the final plans.*
7. If any changes from the final approved design plan that are required due to unforeseen site conditions, the contractor of record shall contact the design engineer of record and submit revised design and stamped full scale plans for review and approval prior to continuing with construction.
8. *The engineer of record shall add the following attestation to the plans when applying for a building permit:*

I certify that the construction so shown was inspected prior to backfill and that all work conforms with the Approved Plan and meets or exceeds the City of Newton Construction Standards.

Signature

Note: If the plans are updated it is the responsibility of the applicant to provide all City Departments [ISD, Conservation Commission, Planning and Engineering] involved in the permitting and approval process with complete and consistent plans.

If you have any questions or concerns, please feel free to contact me at 617-796-1023.