

EXISTING IMPER	VIOUS AREA
	EXISTING
HOUSE	1469.10 S.F
BULKHEAD	42.82 S.F
LANDING & STEPS	163.94 S.F
WALKWAY	673.47 S.F
DRIVEWAY	581.82 S.F
TOTAL	2,931.15 S.F

PROPOSED IMPERVIOUS AREA					
_	PROPOSED				
HOUSE	4898.08 S.F				
PATIO	597.03 S.F				
DRIVEWAY	3025.64 S.F				
RETAINING WALL	117.26 S.F				
PORCH & STEPS	218.66 S.F				
TOTAL	8,856.67 S.F				

SOIL LOG-1

DEEP OBSERVATION HOLE LOG GENERAL SOIL CONDITIONS FOR THE AREA PERFORMED AT 1092-1094 CHESTNUT ST , NEWTON BY SPRUHAN ENGINEERING, P.C.

GENERAL SITE CONDITIONS:

GRASS AND TREES.

HOLE NUMBER: TP - 1 DATED: 1/27/21

GRADE	DEPTH	HORIZON	TEXTURE		COI	_OR	MOTTLING	OTHER
114.0'-113.0'	0" - 12"	A _P	L _{SAND}	10	YR	5/4	NO	NONE
113.0'-111.0'	12" - 36"	B _W	L _{SAND}	10	YR	5/6	@3'	NONE
111.0'-106.0'	36" - 96"	C ₁	L _{SAND}	7.5	ΥR	7/1	YES	NONE
				REFL	JSAL	AT 90	 6"	

127 129 126 125 BOW=120.5 /× 132.38 BOW=120.5 TOW=124.4 BOW = 120.5BOW=120.5 TOW = 124.0BOW=120.5 PATIO SETBACK > PATIO MNE ,291± S.F IJ BOW=120.5 117.5'± TOW=124.4 **EXISTING** BOW=120.5 CHAINLINK BUILDING #2 | x 125.29 FENCE 29 RETAINING WALL SILT FENCE UNIT 3 UNIT 4 & HAYBALE GF=118.5 GF = 118.5'DWELLIN LINE *** 1**626364 **PROPOSED** BF=11 WATER LINE TO BE ENCASED IN CONCRETE SUMP PUMP A/C UNITS TOW = 121.510' AWAY FROM TO BE V.I.F. PROPOSED SEWER BOW=120.5 **<** ❷ PROPOSED BY PLUMBER SEWER CROSSING CONNECTION /C UNITS (SEE DETAIL) **BELOW BASEMENT** PROPOSED SEWER CONNECTION INV=111.6' **BELOW BASEMENT** SUMP PUME INV=111.6' TO BE V.I.F BY PLUMBER 115.5°± (SEE DETAIL) 116.0'± PROPOSED DRAIN LINE TO BE ENCASED IN CONCRETE PROPOSED IMPERVIOUS UNDER BARRIER ALONG ALL SIDES DRIVEWAY OF STORAGE SYSTEM. FIRESTONE POND GUARD 45 37 SILT FENCE & HAYBALE MIL EPDM LINE (OR EQUAL) Ö LINE PROPOSED CATCH BASIN #2 (SEE DETAIL) PROPOSED RIM =117.8'± 10'x10' INV OUT =115.5'± CRUSHED $\dot{\Box}$ \Box STONE SYSTEM PROPOSED SMH # -114.6°± RIM=118.20 DIFAZIO TONY INVin=110.42 **×** 118.53 INVout=110.2 00 (SEE DETAIL) SETBACK X 118.66 $\widetilde{\sim}$ SUMP PUMP ∞ TO BE V.I.F. FF=119' EXISTING PROPOSED SEWER BY PLUMBER RETAINING CONNECTION Z (SEE DETAIL) **BELOW BASEMENT** WALL INV=109.7' BUILDING SYSTEM 2# PROPOSED CRUSHED STONE SYSTEM 114.9'± × 117. GRADE=116.8' VIRGILIO PAUL C 16(8) 1 TO 118.8' (SEE DETAIL) 7.13 unit 2 **-X** 1/7.09 b GF=117.0' DRIVEWAY * SETBACK PROPOSED SS PROPOSED A/C UNITS -X PROPOSED SMH #2 GF=117.0' ×119.3.38 RIM=115.90 INVin=109.0 PROPOSED CATCH INVout=107.0 BASIN #1 (SEE DETAIL) (SEE DETAIL) D 14.5°± $RIM = 116.3' \pm$ INV OUT =113.0'± CHAINLINK PROPOSED SEWER FENCE SILT FENCE CONNECTION WALKV & HAYBALE **BELOW BASEMENT** LINE INV=109.7' SYSTEM 1# PROPOSED SUMP PUMP CRUSHED STONE TO BE V.I.F. SYSTEM BY PLUMBER GRADE=113.5' (SEE DETAIL) TO 116.2' (SEE DETAIL) **(R)** 113.5'± **PROVIDE** SILT FENCE OPENING FOR & HAYBALE CONSTRUCTION ENTRANCE AND RETAINING EXIT WITH ANTI-TRACKING MEASURES (PREVENT šediment from LEAVING SITE) PROPOSED 10'x10' PROPOSED CRUSHED 113.8'±\113.8' OUTLINE FOR STONE SYSTEM TEMPORARY CONSTRUCTION ENTRANCE (SEE DETAIL) PROPOSED #1 D.M.H. EXISTING WATER LATERAL PROPOSED SEWER 6" UPVC TO BE CUT AND CAPPED AT RIM=113.50 CONNECTION TO MAIN AS PER PROPOSED #2 D.M.H. MAIN PER CITY OF NEWTON INVin=111.4 CITY OF NEWTON SPECIFICATIONS. SPECIFICATIONS AND COMPLETEL INVout=111.2 INV=99.93'± CONFIRM PRIOR INVin=111.3 REMOVED FROM THE MAIN AND (SEE DETAIL) TO ANY PLUMBING INVout=111.1 ⋘ THE SITE TO BE BACKFILLED. BEING CARRIED OUT. (SEE DETAIL) 113 S 08°29'34" E≪ TRENCH DRAIN EXISTING OVERHEAD ELECTRIC LINE RIM=112.9 INV=111.55 (SEE DETAIL) PROPOSED DOMESTIC 1.0" CATCH BASIN OF WATER LINES TYPE K WATER LINE TO PROPOSED GRANITE RIM=112.16 CONNECTION VERIFIED BY CONTRACTOR CURB CUT TO BE APRX. LOCATION OF MAIN WATER LINE APRX. LOCATION INSTALLED PER CITY OF NEWTON STANDARDS. \bowtie OF SEWER LINE 12" SEWER LINE 12" SEWER LINE EXISTING SEWER LATERAL 24" DRAIN LINE 24" DRAIN LINE EXISTING S.M.H. AT MAIN PER CITY RIM = 112.38**NEWTON SPECIFICATIONS** AND COMPLETELY REMOVED
FROM THE MAIN AND
THE SITE TO BE BACKFILLED. PROPOSED
DRAIN OVERFLOW
CONNECTION TO MAIN
INV=106.58 CHESTNUT EXISTING D.M.H. RIM=112.41 INV=106.77 CATCH BASIN (PUBLIC WAY) APRX. LOCATION OF MAIN GAS LINE APRX. (TO BE V.I.F.) RIM=112.19 **×** 111.72

RET. WALL

100.00'

N 05°37'13" W

PROPOSED

RET. WALL

MUSTAFAYEVA NATIG

MUSTAFAYEVA SAIDA

SOIL LOG-2


DEEP OBSERVATION HOLE LOG

GENERAL SOIL CONDITIONS FOR THE AREA PERFORMED AT 1092-1094 CHESTNUT ST , NEWTON BY SPRUHAN ENGINEERING, P.C.

DATED: 1/27/21 HOLE NUMBER: TP - 2 **GENERAL SITE CONDITIONS:** GRASS AND TREES.

GRADE	DEPTH	HORIZON	TEXTURE		COI	_OR	MOTTLING	OTHER
117.5'-116.5'	0" - 12"	A _P	L _{SAND}	10	YR	5/4	NO	NONE
116.5'-114.5	12" - 36"	B _W	L _{SAND}	10	YR	5/6	@3'	NONE
114.5'-110.5'	36" - 84"	C ₁	L _{SAND}	7.5	YR	7/1	YES	NONE

REFUSAL AT 84"





REVISION BLOCK		DATE	1/30/21	
BY	DESCRIPTION	DATE	DRAWN BY	DK
			CHECKED BY	ES
			APPROVED BY	ES
			SHEET	3
			PLAN NO.	1 OF 1
			CLIENT:	
			OUEET	
			SHEET:	
			•	4

All legal rights including, but not limited to, copyright and design patent rights, in the designs, arrangements and plans shown on this document are the property of Spruhan Engineering, P.C. They may not be used or reused in whole or in part, except in connection with this project, without the prior written consent of Spruhan Engineering, P.C.. Written dimensions on these drawings shall have precedence over scaled dimensions. Contractors shall verify and be responsible for all dimensions and conditions on this project, and Spruhan Engineering, P.C., must be notified of any variation from the

dimensions and conditions shown by these

drawings.

1092-1094 CHESTNUT STREET, NEWTON, **MASSACHUSETTS**

> PROPOSED DRAINAGE AND UTILITIES PLAN



SPRUHAN ENGINEERING P.C.

80 JEWETT ST, (SUITE 1) NEWTON, MA 02458

Tel: 617-816-0722

Email:edmond@spruhaneng.com

DRAINAGE SYSTEM-1


NOTE: CONTRACTOR TO REMOVEPEAT LAYER FROM BELOW DRAINAGE SYSTEM & REPLACE WITH DRAINAGE STONE

PVC PIPE INV=111.6'± GRADE 113.5' TO 116.2' TOP OF STONE=112.0' IIII' INV=111' 2.5' BOTTOM OF STONE.=109.5' SCALE: NOT TO SCALE


DRAINAGE SYSTEM NOTES:

- 1. TOP OF SYSTEM SHALL BE ENCASED IN FILTER FABRIC.
- 2. LOCATION OF SYSTEM PER PLANS.
- 3. DESIGN ENGINEER WILL INSPECT AND CERTIFY IN WRITING THAT ALL DRAINAGE WORK WAS INSTALLED IN ACCORDANCE WITH APPROVED PLANS. CONTRACTOR TO NOTIFY ENGINEER AT LEAST 72 HOURS IN ADVANCE FOR DRAINAGE SYSTEM INSPECTION PRIOR TO BACKFILLING.

<u>PLAN VIEW</u> DRAINAGE SYSTEM DETAIL




DRAINAGE SYSTEM-2



6" OVERFLOW PIPE: INV=115.2'


 igspace (TO THE CRUSHED STONE SYSTEM1)

NOTE:
CONTRACTOR TO REMOVEPEAT LAYER FROM BELOW DRAINAGE
SYSTEM & REPLACE WITH DRAINAGE STONE



DRAINAGE SYSTEM NOTES:

- 1. TOP OF SYSTEM SHALL BE ENCASED IN FILTER FABRIC.
- 2. LOCATION OF SYSTEM PER PLANS.
- 3. DESIGN ENGINEER WILL INSPECT AND CERTIFY IN WRITING THAT ALL DRAINAGE WORK WAS INSTALLED IN ACCORDANCE WITH APPROVED PLANS. CONTRACTOR TO NOTIFY ENGINEER AT LEAST 72 HOURS IN ADVANCE FOR DRAINAGE SYSTEM INSPECTION PRIOR TO BACKFILLING.



Spruhan Engineering, P.C.

> 80 JEWETT ST, (SUITE 2) NEWTON, MA 02458 Tel: 617-816-0722

Email:edmond@spruhaneng.com

1092–1094 CHESTNUT STREET NEWTON

MASSACHUSETTS

DETAILS

REVISION BLOCK

DESCRIPTION	DATE
_	


All legal rights including, but not limited to, copyright and design patent rights, in the designs, arrangements and plans shown on this document are the property of Spruhan Engineering, P.C. They may not be used or reused in whole or in part, except in connection with this project, without the prior written consent of Spruhan Engineering, P.C.. Written dimensions on these drawings shall have precedence over scaled dimensions. Contractors shall verify and be responsible for all dimensions and conditions on this project, and Spruhan Engineering, P.C., must be notified of any variation from the dimensions and conditions shown by these drawings.




DATE: 01/30/2021
DRAWN BY: D.K.
CHECKED BY: E.S
APPROVED BY: E.S


DETAILS


SHEET 4 OF 6








DRAIN MANHOLE DETAIL











Spruhan Engineering, P.C.

> 80 JEWETT ST, (SUITE 2) NEWTON, MA 02458 Tel: 617-816-0722

Email:edmond@spruhaneng.com

1092–1094 CHESTNUT STREET NEWTON MASSACHUSETTS

DETAILS

REVISION BLOCK

DESCRIPTION	DATE

All legal rights including, but not limited to, copyright and design patent rights, in the designs, arrangements and plans shown on this document are the property of Spruhan Engineering, P.C. They may not be used or reused in whole or in part, except in connection with this project, without the prior written consent of Spruhan Engineering, P.C.. Written dimensions on these drawings shall have precedence over scaled dimensions. Contractors shall verify and be responsible for all dimensions and conditions on this project, and Spruhan Engineering, P.C., must be notified of any variation from the dimensions and conditions shown by these drawings.




DRAWN BY:
CHECKED BY:
APPROVED BY:


01/30/2021 D.K. E.S

E.S

DETAILS

SHEET 5 OF 6








Engineering, P.C. 80 JEWETT ST, (SUITE 2) NEWTON, MA 02458


> Tel: 617-816-0722 Email:edmond@spruhaneng.com

1092-1094 CHESTNUT STREET NEWTON **MASSACHUSETTS**

DETAILS

REVISION BLOCK





SEE PLANS FOR FINAL GRADING EXISTING GROUND SURFACE SEE TYPICAL
PAVEMENT SECTIONS PROTECTION ZONE, SAND OR TYPE-C GRAVEL BORROW COMPACTED AS SPECIFIED ABOVE MAXIMUM STONE SIZE-2 NDISTURBED NATURAL SUITABILITY OF MATERIAL IS TO BE DETERMINED BY THE CITY OF NEWTON.

1. GRAVEL BORROW SHALL CONFORM TO MASS HIGHWAY SPECIFICATION M1.03.0 2. CRUSHED STONE BEDDING SHALL CONFORM TO MASS HIGHWAY SPECIFICATION M2.01.1

N.T.S.

TYPICAL TRENCH DETAIL

SEE PLANS FOR FINAL GRADING & CAPPING REQUIREMENTS 3/4" CRUSHED STONE BEDDING_ (SEE NOTE 2) * SUITABILITY OF MATERIAL IS TO BE DETERMINED BY THE CITY OF NEWTON.

1. GRAVEL BORROW SHALL CONFORM TO MASS HIGHWAY SPECIFICATION M1.03.0
2. CRUSHED STONE BEDDING SHALL CONFORM TO MASS HIGHWAY SPECIFICATION M2.01.1

GRAVITY SEWER TRENCH DETAIL

TYPICAL SEWER CONFIGURATION

CRUSHED AGGREGATE GREATER THAN 3" BUT SMALLER THAN 6" CONDITION THAT WILL PREVENT TRACKING OR FLOWING OF SEDIMENT ONTO PUBLIC RIGHT-OF-WAYS. THIS MAY REQUIRE TOP DRESSING, REPAIR AND/OR CLEANOUT OF - FILTER FABRIC ANY MEASURES USED TO TRAP SEDIMENT. - ORIGINAL GRADE 2. WHEN NECESSARY, WHEELS SHALL BE CLEANED PRIOR TO ENTRANCE ONTO PUBLIC RIGHT-OF-WAY. $\stackrel{\textstyle \sim}{}$ 12" MIN, UNLESS OTHERWISE 3. WHEN WASHING IS REQUIRED, IT SHALL BE DONE ON AN AREA STABILIZED WITH CRUSHED STONE THAT DRAINS INTO AN SPECIFIED BY A SOIL ENGINEER APPROVED SEDIMENT TRAP OR SEDIMENT SECTION B-B RUMBLE STRIPS MAY BE USED AS AN ALTERNATIVE SUBJECT TO THE APPROVAL OF THE CONSTRUCT SEDIMENT BARRIER CITY PRIOR TO INSTALLATION AND CHANNEL RUNOFF TO SEDIMENT TRAPPING DEVICE WIDTH AS REQUIRED TO ACCOMMODATE ANTICIPATED TRAFFIC TEMPORARY PIPE CULVERT ☐B AS NEEDED OR FOUR TIMES THE CIRCUMFERENCE OF THE LARGEST CONSTRUCTION VEHICLE TIRE, MATCH WHICHEVER IS GREATER **EXISTING** STABILIZED CONSTRUCTION ENTRANCE DETAIL

SEE TYPICAL TRENCH REPAIR DETAILS FOR SURFACE RESTORATION ELEMENTS

TYPICAL WATER TRENCH DETAIL

SEE PLANS FOR FINAL GRADING

CONTROLLED DENSITY FILL (C.D.F.)

1 1/2" BITUMINOUS FINISH

GRADE

* SUITABILITY OF MATERIAL IS TO BE DETERMINED BY THE CITY OF NEWTON.

CONTROLLED DENSITY FILL (C.D.F.) TYPICAL TRENCH DETAIL

BEDDING & PROTECTION ZONE PER SPECIFIC UTILITY TRENCH DETAIL

TYPE IE (EXCAVATABLE)

CONSTRUCTION SPECIFICATIONS:

- THE ENTRANCE SHALL BE MAINTAINED IN A 1. THE AGGREGATE SIZE FOR CONSTRUCTION OF THE PAD SHALL BE 2-3 INCH (50-75 MM) STONE. PLACE THE GRAVEL TO THE SPECIFIC GRADE AND DIMENSIONS SHOWN ON THE PLANS,
 - THE THICKNESS OF THE PAD SHALL NOT BE LESS THAN 6 INCHES (152 MM). USE GEOTEXTILE FABRICS, IF NECESSARY, TO IMPROVE STABILITY OF THE FOUNDATION IN LOCATIONS SUBJECT TO SEEPAGE OR HIGH WATER TABLE. 3. THE WIDTH OF THE PAD SHALL NOT BE LESS THAN THE FULL WIDTH OF ALL POINTS OF
 - INGRESS OR EGRESS AND IN ANY CASE SHALL NOT BE LESS THAN 12 FEET (3.6 M) WIDE. 4. THE LENGTH OF THE PAD SHALL BE AS REQUIRED, BUT NOT LESS THAN 50 FEET (15.2 M). 5. LOCATE CONSTRUCTION ENTRANCES AND EXITS TO LIMIT SEDIMENT LEAVING THE SITE AND TO PROVIDE FOR MAXIMUM UTILITY BY ALL CONSTRUCTION VEHICLES. AVOID ENTRANCES WHICH
 - THE ENTRANCE SHALL BE MAINTAINED IN A CONDITION THAT WILL PREVENT TRACKING OR FLOWING OF SEDIMENT ONTO PUBLIC RIGHTS-OF-WAY. THIS MAY REQUIRE PERIODIC TOP DRESSING WITH ADDITIONAL STONE AS CONDITIONS DEMAND, AND REPAIR AND/OR MAINTENANCE OF ANY MEASURES USED TO TRAP SEDIMENT.


HAVE STEEP GRADES AND ENTRANCES AT CURVES IN PUBLIC ROADS.

- ALL SEDIMENT SPILLED, DROPPED, WASHED OR TRACKED ONTO PUBLIC RIGHTS-OF-WAY SHALL BE REMOVED IMMEDIATELY. PROVIDE DRAINAGE TO CARRY WATER TO A SEDIMENT TRAP OR OTHER SUITABLE OUTLET.
- WHEN NECESSARY, WHEELS SHALL BE CLEANED TO REMOVE SEDIMENT PRIOR TO ENTRANCE ONTO PUBLIC RIGHTS-OF-WAY. WHEN WASHING IS REQUIRED, IT SHALL BE DONE ON AN AREA STABILIZED WITH CRUSHED STONE THAT DRAINS INTO AN APPROVED SEDIMENT TRAP OR SEDIMENT BASIN. SEE SEDIMENT BASIN BMP.
- 10. ALL SEDIMENT SHALL BE PREVENTED FROM ENTERING ANY STORM DRAIN, DITCH OR WATERCOURSE THROUGH USE OF SAND BAGS, GRAVEL, STRAW BALES, OR OTHER APPROVED METHODS.

INSPECTION AND MAINTENANCE:

N.T.S.

- 11. MAINTAIN THE GRAVEL PAD IN A CONDITION TO PREVENT MUD OR SEDIMENT FROM LEAVING THE CONSTRUCTION SITE.
- 12. REPLACE GRAVEL MATERIAL WHEN SURFACE VOIDS ARE NOT VISIBLE. 13. AFTER EACH RAINFALL, INSPECT ANY STRUCTURE USED TO TRAP SEDIMENT AND CLEAN IT
- 14. IMMEDIATELY REMOVE ALL OBJECTIONABLE MATERIALS SPILLED, WASHED, OR TRACKED ONTO PUBLIC ROADWAYS. REMOVE ALL SEDIMENT DEPOSITED ON PAVED ROADWAYS WITHIN 24 HOURS.



STANDARD SPECIFICATIONS FOR HIGHWAYS AND BRIDGES, 1988 AS AMENDED. 2. ALL EXPOSED BITUMINOUS CONCRETE IS TO BE TACKED PER MHD PRIOR TO NEW BITUMINOUS CONCRETE INSTALLATIONS.

3. ALL EXPOSED JOINTS ARE TO BE SEALED WITH TACK AND STONE DUST. 4. ANY TOP COURSE APPLIED AT A WIDTH OF 6' WIDE OR GREATER IS TO BE 5. PLACED BY MACHINE/BAX SPREADER WHEN & AS DIRECTED BY THE CITY OF NEWTON.

_SCREEN ____ DOWNSPOUT OVERFLOW OUTLET COVER (MIN) 4" PVC (MIN) LEACHING STRUCTURE 10' MINIMUM (SEE DETAIL) TYPICAL DOWNSPOUT DETAIL

N.T.S.

All legal rights including, but not limited to, copyright and design patent rights, in the designs, arrangements and plans shown on this document are the property of Spruhan Engineering, P.C. They may not be used or reused in whole or in part, except in connection with this project, without the prior written consent of Spruhan Engineering, P.C.. Written dimensions on these drawings shall have precedence over scaled dimensions. Contractors shall verify and be responsible for all dimensions and conditions on this project, and Spruhan Engineering, P.C., must be notified of any variation from the dimensions and conditions shown by these drawings.



01/30/2021 DRAWN BY: CHECKED BY: E.S APPROVED BY: F.S

DETAILS

SHEET 6 OF 6