

Facility Name: Albemarle Field 'Russell J. Halloran Sports and Recreation Complex'		
Size (Ac): 24.9 acres		
Address: 250 Albemarle Road, Newtonville (Adjacent to Day Middle School and Horace Mann Elementary School)		
Ward: 2		
General Facility Notes: Accessible playground area (3-5-yr & 5-12-yr), raised planters & gazebo near Horace-Mann (future Newton Early Childhood); ballfield bleachers, tennis courts, basketball courts, field house on accessible route; Albemarle Rd. sidewalk runs the length of the park; accessible on-street parking near playground and pool; contiguous to wooded Avery Estate (not accessible).		
Site Furnishings	YES	
Tables & Benches		
Number of Benches	yes	There are 27 benches.
Number of Tables	yes	There are 5 picnic tables
Located adjacent to accessible paths	yes	
Back and Arm Rests	yes	There are 9 benches with backs and arm rests, there are 15 benches with backs and 3 backless benches.
Grills		
Located adjacent to accessible paths	no	
Trash Cans		
Located adjacent to accessible paths	yes	7 bigbelly trash compactor; 7 bigbelly recycling unit; 1 trash/1 recycling by field house
Picnic Shelters		
Located adjacent to accessible paths	yes	Gazebo and 3 picnic tables are located next to playground
Notes:		
Trails & Paths		
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	yes	A, C
Dimensions (width)	yes	Pathway is five feet wide, driveway is eight feet wide.
Rails	N/A	
Signage for visually impaired	N/A	
Notes:		
Aquatics - Refer to Harry Gath memorial Pool	YES	
Notes:		
Play Areas	YES	
Facility Type (3-5 Yrs, 5-12 Yrs)	yes	Fibar safety surfacing, poured in place surfacing
Same experience provided to all	yes	
Access Routes		
Located adjacent to accessible paths	yes	
Enough space between equipment for wheelchair	yes	
Notes: There is a bubbler at the playground.		
Game Areas	YES	
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Bocce)	yes	4 RF, 6 BF, 1 BK, 2 TN, 2 BK Standards
Access Routes		
Located adjacent to accessible paths	yes	
Equipment		
Spectator Seating	yes	There are 4 bleacher seating areas at the ball fields
Notes: Athletic fields are irrigated with well water. There is athletic lighting for the football, baseball and softball field. There is a flagpole and scoreboard by Murphy little league. There is a snack shack and three double station bubblers on site. There are six bleacher sets. many of these amenities lack accessible paths		
Boat Docks	N/A	
Fishing Facilities	N/A	
Community Gardens	N/A	
Parking	YES	
Total Spaces	180	Accessible Spaces
		10 Spaces
Parking Amenities (L=lot, ST=street)	yes	L, ST
Accessible space located closest to accessible entrance	yes	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	N/A	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	yes	1 Yes, 9 No
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	yes	6 Yes, 4 No
Sign with international symbol of accessibility at each space	yes	Yes, 10
Sign 5'-8' to top of sign	yes	4 yes, 6 no
Surface evenly paved or hard-packed (no cracks)	No	10 no
Surface slope less than 1:20, 5%	yes	
Curbscut to pathway from parking lot at each space if sidewalk (curb) is present.	yes	Some curb cuts are shared
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	no	9 curb cuts are not painted yellow or textured
Notes:		
Ramps	N/A	
Site Access, Path of Travel, Entrances	YES	
Site Access		
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	yes	
Surface evenly paved or hard-packed	yes	
Disembarking area at accessible entrance	yes	not all spots have a disembarking area
Path of Travel		
Description		Comments

Path does not require the use of stairs	yes	
Path does not require the use of wheelchair ramp	yes	
Path is stable, firm and slip resistant	yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	yes	
Continuous common surface, no changes in level greater than 1/8 inch	yes	
Entrances		
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	Yes	
Level space extending 5 ft. from the door, interior and exterior of entrance doors	Yes	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)	Yes	
At least 18" clear floor area on latch, pull side of door	Yes	
Door handle no higher than 48" and operable with a closed fist	No	
Vestibule is 4 ft plus the width of the door swinging into the space	N/A	
Entrance(s) on a level that makes elevators accessible	N/A	
Door mats less than 1/2" thick are securely fastened	N/A	
Door mats more than 1/2" thick are recessed	N/A	
Grates in path of travel have openings of 1/2" maximum	Yes	
Signs at non-accessible entrance(s) indicate direction to accessible entrance	No	
Emergency egress – alarms with flashing lights and audible signals, sufficiently lighted	No	

Notes:

Stairs and Doors	YES
-------------------------	------------

Doors		
Minimum 32" clear opening	Yes	
At least 18" clear floor space on pull side of door	Yes	
Closing speed minimum 3 seconds to within 3" of the latch	No	
Maximum pressure 5 pounds interior doors	N/A	
Threshold maximum 1/2" high, beveled on both sides	Yes	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)	No	
Hardware minimum 36", maximum 48" above the floor	No	
Clear, level floor space extends out 5 ft from both sides of the door	Yes	
Door adjacent to revolving door is accessible and unlocked	N/A	
Doors opening into hazardous area have hardware that is knurled or roughened	N/A	

Notes:

Restrooms	YES
------------------	------------

5 ft turning space measured 12" from the floor	Yes	
At least one Sink		
Clear floor space of 30" by 48" to allow a forward approach	Yes	
Mounted without pedestal or legs, height 34" to top of rim	Yes	
Extends at least 22" from the wall	Yes	
Open knee space a minimum 19" deep, 30" width, and 27" high	Yes	
Cover exposed pipes with insulation	No	
Faucets operable with closed fist (lever or spring activated handle)	No	
At least one Stall		
Accessible to person using wheelchair at 60" wide by 72" deep	No	
Stall door is 36" wide	No	
Stall door swings out	Yes	
Stall door is self closing	No	
Stall door has a pull latch	No	
Lock on stall door is operable with a closed fist, and 32" above the floor	No	
Coat hook is 54" high	No	NO hook

Toilet		
Description		
18" from center to nearest side wall	Yes	Comments
42" minimum clear space from center to farthest wall or fixture	Yes	
Top of seat 17"-19" above the floor	Yes	

Grab Bars		
Description		
On back and side wall closest to toilet	Yes	Comments
1 1/2" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	Yes	
Acid-etched or roughened surface	Yes	
42" long	Yes	

Fixtures		
Description		
1 1/2" diameter	Yes	Comments
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	No	

Notes:

Floors, Drinking Fountains, Telephones	YES
---	------------

Floors		
Description		
Non-slip surface	No	Comments
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored	N/A	
Corridor width minimum is 3 ft	Yes	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor	N/A	

Notes:

Signs, Signals, and Switches	YES
-------------------------------------	------------

Switches, Controls and Signs		
Description		
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach	No	Comments

Electrical outlets centered no lower than 18" above the floor	Yes	
Warning signals must be visual as well as audible	No	

Notes:

Swimming Pool/ Lake beach	N/A
Shower Rooms	N/A
Picknicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Angier School Playground		
Size (Ac): 4.7 acres		
Address: 1697 Beacon Street, Waban		
Ward: 5		
General Facility Notes: Recent school rebuilt and accessible play equipment areas in 2016; no accessible pathways in the field area. Poured in place saefty surfacing.		
Site Furnishings YES		
Description		Comments
Tables & Benches		
Number of Benches	yes	14 total - 6 have backs, 6 have no backs, 2 spectator benches with backs at little league
Number of Tables	yes	8 picnic tables w/ shade structure
Located adjacent to accessible paths	yes	no paths, large pad area at playground
Back and Arm Rests	yes	4 - 2 have backs, 2 have no backs
Trash Cans		
Located adjacent to accessible paths	yes	1 bigbelly trash compactor; 1 bigbelly recycling unit; 1trash/1 recycling by tennis court
Picnic Shelters		
Located adjacent to accessible paths	YES	no paths, shelters are within large accessible area at playground
Notes:		
Trails & Paths YES		
Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	yes	A, C
Dimensions (width)	N/A	no paths, large pad area at playground
Rails	No	
Signage for visually impaired	No	
Notes:		
Play Areas YES		
Description		Comments
Facility Type (3-5 Yrs,5-12 Yrs)	yes	gaga pit
Same experience provided to all	yes	
Access Routes		
Located adjacent to accessible paths	yes	no paths, large pad area at playground
Enough space between equipment for wheelchair	yes	
Notes:		
Game Areas YES		
Description		Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Bocce)	yes	3 TN (2 benches w/ backs at tennis courts), 1 basketball court, 1 basketball standard, 1BF (w/ backstop, benches, protective screens and shed)
Access Routes		
Located adjacent to accessible paths	No	
Equipment		
Spectator Seating	yes	8 picnic tables w/ shade structure,
Notes: require accessible route to non accessible amenities		
Boat Docks N/A		
Fishing Facilities N/A		
Community Gardens N/A		
Parking YES		
Total Spaces	Accessible Spaces	
25	1	
Description		Comments
Parking Amenities (L=lot, ST=street)	yes	L
Accessible space located closest to accessible entrance	yes	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	N/A	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	No	12.5 ft wide
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	yes	
Sign with international symbol of accessibility at each space	yes	
Sign 5'-8" to top of sign	No	
Surface evenly paved or hard-packed (no cracks)	yes	
Surface slope less than 1:20, 5%	yes	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	yes	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	yes	
Notes:		
Ramps N/A		
Site Access, Path of Travel, Entrances YES		
Site Access		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	yes	no paths, large pad area at playground
Surface evenly paved or hard-packed	yes	
Disembarking area at accessible entrance	Yes	
Path of Travel		
Description		Comments
Path does not require the use of stairs	yes	no paths, large pad area at playground

Path does not require the use of wheelchair ramp	yes	
Path is stable, firm and slip resistant	yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	yes	
Continuous common surface, no changes in level greater than ¼ inch	yes	
Stairs and Doors	N/A	
Restrooms	N/A	
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picnicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: Auburndale Park 'The Cove'		
Size (Ac): 29.9 acres		
Address: West Pine Street, Auburndale		
Ward: 4		
General Facility Notes: Accessible asphalt pathway to picnic area, and fieldhouse. Portions of stone dust path through undeveloped wooded area to Waltham and Flowed Meadow are accessible; tot lot is accessible; 5-12 play apparatus required accessible path; fitness equipment stations on accessible route; accessible parking lot; acreage includes contiguous Lyons Park.		
Site Furnishings		YES
<i>Description</i>		<i>Yes</i> <i>Comments</i>
Tables & Benches		
Number of Benches	YES	
Number of Tables	YES	30 tables dispersed into 5 permitted picnic areas.
Located adjacent to accessible paths		3 of the 5 picnic areas are along an accessible path, 2 benches are on an accessible path.
Back and Arm Rests	YES	City standard benches have backrest but no arm rests. Picnic tables do not have back rests
Grills		
Located adjacent to accessible paths	YES	3 of the 5 grilling areas are along an accessible path. Each picnic area has multiple grills
Trash Cans		
Located adjacent to accessible paths	YES	
Notes:		
Trails & Paths		YES
<i>Description</i>		<i>Comments</i>
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	YES	A; SD; NS; BR
Dimensions (width)		6 feet minimum; paths range up to 12 feet in width
Rails	No	
Signage for visually impaired	No	
Notes:		
Play Areas		YES
<i>Description</i>		<i>Comments</i>
Facility Type (3-5 Yrs,5-12 Yrs)	YES	3-5 Yrs; 5-12 Yrs
Same experience provided to all	No	
Access Routes		
Located adjacent to accessible paths	YES	
Enough space between equipment for wheelchair	YES	
Notes:		
Game Areas		YES
<i>Description</i>		<i>Comments</i>
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Bocce)	YES	1 BF; 1 BK; 2 TN
Access Routes		
Located adjacent to accessible paths	YES	basketball and tennis courts are on accessible path; ball fields not on an accessible path
Equipment		
Spectator Seating	YES	spectator seating not on accessible route
Notes:		
Boat Docks		N/A
Fishing Facilities		N/A
Community Gardens		N/A
Parking		YES
<i>Total Spaces</i>	<i>Accessible Spaces</i>	
144	5 Space	
<i>Description</i>		<i>Comments</i>
Parking Amenities (L=lot, ST=street)	YES	L
Accessible space located closest to accessible entrance	YES	All 5 parking spaces are next to an accessible park entrance
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	YES	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	YES	
Sign with international symbol of accessibility at each space	YES	
Surface evenly paved or hard-packed (no cracks)	YES	
Surface slope less than 1:20, 5%	YES	
Notes:		
Site Access, Path of Travel, Entrances		YES
Site Access		
<i>Description</i>		<i>Comments</i>
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	YES	
Surface evenly paved or hard-packed	YES	
Ponding of water?	No	
Path of Travel		
<i>Description</i>		<i>Comments</i>
Path does not require the use of stairs	YES	
Path does not require the use of wheelchair ramp	YES	
Path is stable, firm and slip resistant	YES	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	YES	

Continuous common surface, no changes in level greater than 1/4 inch	YES	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	No	
Entrances		
<i>Description</i>		<i>Comments</i>
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	Yes	
Level space extending 5 ft. from the door, interior and exterior of entrance doors	Yes	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)	Yes	
At least 18" clear floor area on latch, pull side of door	Yes	
Door handle no higher than 48" and operable with a closed fist	No	
Vestibule is 4 ft plus the width of the door swinging into the space	Yes	
Entrance(s) on a level that makes elevators accessible	N/A	
Door mats less than 1/2" thick are securely fastened	No	
Door mats more than 1/2" thick are recessed	No	
Grates in path of travel have openings of 1/2" maximum	N/A	
Signs at non-accessible entrance(s) indicate direction to accessible entrance	No	
Emergency egress – alarms with flashing lights and audible signals, sufficiently lighted	No	

Notes:

Stairs and Doors **YES**

Doors		
<i>Description</i>		<i>Comments</i>
Minimum 32" clear opening	Yes	
At least 18" clear floor space on pull side of door	Yes	
Closing speed minimum 3 seconds to within 3" of the latch	Yes	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)	No	
Hardware minimum 36", maximum 48" above the floor	Yes	
Clear, level floor space extends out 5 ft from both sides of the door	Yes	
Door adjacent to revolving door is accessible and unlocked	N/A	
Doors opening into hazardous area have hardware that is knurled or roughened	N/A	

Notes:

Restrooms **YES**

<i>Description</i>		<i>Comments</i>
5 ft turning space measured 12" from the floor	Yes	

At least one Sink

<i>Description</i>		<i>Comments</i>
Clear floor space of 30" by 48" to allow a forward approach	Yes	
Mounted without pedestal or legs, height 34" to top of rim	Yes	
Extends at least 22" from the wall	Yes	
Open knee space a minimum 19" deep, 30" width, and 27" high	Yes	
Cover exposed pipes with insulation	No	
Faucets operable with closed fist (lever or spring activated handle)	Yes	

At least one Stall

<i>Description</i>		<i>Comments</i>
Accessible to person using wheelchair at 60" wide by 72" deep	Yes	
Stall door is 36" wide	Yes	
Stall door swings out	Yes	
Stall door is self closing	No	
Stall door has a pull latch	Yes	
Lock on stall door is operable with a closed fist, and 32" above the floor	No	
Coat hook is 54" high	Yes	

Toilet

<i>Description</i>		<i>Comments</i>
18" from center to nearest side wall	Yes	
42" minimum clear space from center to farthest wall or fixture	Yes	
Top of seat 17"-19" above the floor	Yes	

Grab Bars

<i>Description</i>		<i>Comments</i>
On back and side wall closest to toilet	Yes	
1 1/2" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	Yes	
Acid-etched or roughened surface	Yes	
42" long	Yes	

Fixtures

<i>Description</i>		<i>Comments</i>
1 1/2" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	Yes	

Notes:

Floors, Drinking Fountains, Telephones **N/A**

Signs, Signals, and Switches **N/A**

Swimming Pool/ Lake beach **N/A**

Shower Rooms **N/A**

Picnicking **YES**

<i>Description</i>		<i>Comments</i>
A minimum of 5% of the total tables must be accessible with clear space under the table top not less than 30" wide and 19" deep per seating space and not less than 27" clear from the ground to the underside of the table. An additional 29" clear space (totaling 48") must extend beyond the 19" clear space under the table to provide access	YES	10% are accessible
For tables without toe clearance, the knee space under the table must be at least 28" high, 30" wide and 24" deep.	YES	
Top of table no higher than 32" above ground	YES	
Surface of the clear ground space under and around the table must be stable, firm and slip-resistant, and evenly graded with a maximum slope of 2% in all directions	YES	
Accessible tables, grills and fire rings must have clear ground space of at least 36" around the perimeter	YES	

Notes:

Off Leash Dog Areas (OLA)	N/A
---------------------------	-----

Facility Name: Officer Bobby Braceland Playground 'Upper Falls Playground'		
Size (Ac): 8.8 acres		
Address: Chestnut Street, Newton Upper Falls		
Ward: 5		
General Facility Notes: Van accessible parking spaces, accessible park entry and route to tennis courts and benches constructed in 2012; no accessible pathways at ballfields, off-leash dog area, tot lot and basket ball court.		
Site Furnishings		YES
<i>Description</i>		<i>Comments</i>
Tables & Benches		
Number of Benches	YES	6 BENCHES
Number of Tables	No	
Located adjacent to accessible paths	YES	1 bench located along accessible path; remaining five are on lawn or mulch
Back and Arm Rests	YES	3 benches have backrest; no arm rest on any of the benches
Trash Cans		
Located adjacent to accessible paths	YES	Trash, Recycling and dog waste bin are adjacent to accessible path
Picnic Shelters		
Located adjacent to accessible paths	N/A	
Notes:		
Trails & Paths		YES
<i>Description</i>		<i>Comments</i>
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	YES	A, C
Dimensions (width)	N/A	6 feet minimum
Rails	NO	
Signage for visually impaired	No	
Notes:		
Play Areas		YES
<i>Description</i>		<i>Comments</i>
Facility Type (3-5 Yrs,5-12 Yrs)	YES	
Same experience provided to all	No	
Access Routes		
Located adjacent to accessible paths	No	requires accessible route to play structure from Pennsylvania Ave.
Enough space between equipment for wheelchair	Yes	
Notes:		
Game Areas		YES
<i>Description</i>		<i>Comments</i>
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Bocce)	YES	1 RF; 1 BF; 1 BK; 2 TN
Access Routes		
Located adjacent to accessible paths	YES	Tennis courts are located adjacent to accessible path; all other amenities are not adjacent to accessible paths
Equipment		
Spectator Seating		
Notes:		
Boat Docks		N/A
Fishing Facilities		N/A
Community Gardens		N/A
Parking		YES
<i>Total Spaces</i>	<i>Required Accessible Spaces</i>	
32	2 Space	
<i>Description</i>		<i>Comments</i>
Parking Amenities (L=lot, ST=street)	YES	L
Accessible space located closest to accessible entrance	YES	Both accessible parking spaces are located at the entrance
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	YES	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	YES	
Sign with international symbol of accessibility at each space	YES	
Surface evenly paved or hard-packed (no cracks)	YES	
Surface slope less than 1:20, 5%	YES	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	YES	one curb cut for both parking spaces
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	YES	
Notes:		
Ramps		N/A
Site Access, Path of Travel, Entrances		YES
Site Access		
<i>Description</i>		<i>Comments</i>
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	YES	
Surface evenly paved or hard-packed	YES	
Ponding of water?	NO	
Disembarking area at accessible entrance	YES	
Path of Travel		
<i>Description</i>		<i>Comments</i>
Path does not require the use of stairs	YES	
Path does not require the use of wheelchair ramp	YES	

Path is stable, firm and slip resistant	YES	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	YES	
Continuous common surface, no changes in level greater than ¼ inch	YES	
Any objects protruding onto the pathway that may not be detected by a person with a visual disability using a cane	NO	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	NO	
Curb on the pathway must have curb cuts at drives, parking and drop-offs	YES	
Stairs and Doors	N/A	
Restrooms	N/A	
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picknicking	N/A	
Off Leash Dog Areas (OLA)	YES	
<i>Description</i>	<i>Yes</i>	<i>Comments</i>
Access Routes		
Located adjacent to accessible paths	No	
Area accessible	No	
Notes:		

Facility Name: Boyd Park		
Size (Ac): 4.8 acres		
Address: Jackson Road, Nonantum		
Ward: 1		
General Facility Notes: Accessible parking at the Lincoln-Elliot School; Park dissected by Watertown and Newton city lines; accessible pathway to courts; steep stairs down from Pearl St; playfield and softball field have no accessible pathways (including the portion in Watertown); 2-5 yr play structure; 5-12 yr Structure; play		
Site Furnishings		YES
Description	Yes	<i>Comments</i>
Tables & Benches		
Number of Benches	YES	7 Benches
Number of Tables	YES	1
Located adjacent to accessible paths	YES	2
Back and Arm Rests	YES	4 with Backs
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	YES	1
Picnic Shelters		
Located adjacent to accessible paths		
Notes:		
Trails & Paths		YES
Description		<i>Comments</i>
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	YES	A
Dimensions (width)		6-ft Min.
Rails	No	
Signage for visually impaired	No	
Notes:		
Play Areas		YES
Description		<i>Comments</i>
Facility Type (3-5 Yrs, 5-12 Yrs)	YES	2 Structures one accessible with ramp
Same experience provided to all	YES	
Access Routes		
Located adjacent to accessible paths	YES	
Enough space between equipment for wheelchair		
Notes:		
Game Areas		YES
Description		<i>Comments</i>
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Bocce)	YES	2 BF, 1 BK, 1 RF
Access Routes		
Located adjacent to accessible paths	YES	Basketball accessible by path
Berm cuts onto courts		
Equipment		
Spectator Seating	No	
Notes:		
Boat Docks		N/A
Fishing Facilities		N/A
Community Gardens		N/A
Parking		YES
Total Spaces		<u>Required Accessible Spaces</u>
	26	1 Space
Description		<i>Comments</i>
Parking Amenities (L=lot, ST=street)	YES	lot
Accessible space located closest to accessible entrance	YES	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	Yes	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	No	
Sign with international symbol of accessibility at each space	Yes	
Surface evenly paved or hard-packed (no cracks)	Yes	
Surface slope less than 1:20, 5%	Yes	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	Yes	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	Yes	
Notes:		
Ramps		N/A
Site Access, Path of Travel, Entrances		YES
Site Access		
Description		<i>Comments</i>
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	YES	Asphalt path to Hardpack around play structure
Surface evenly paved or hard-packed	Yes	
Disembarking area at accessible entrance	Yes	
Path of Travel		
Description		<i>Comments</i>
Path does not require the use of stairs	Yes	

Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than 1/8 inch	No	

Notes:

Stairs and Doors **YES**

<u>Stairs</u>		
Description		Comments
Open risers	No	
Nosings not projecting	Yes	
Treads no less than 11" wide	Yes	
Handrails on both sides	Yes	
Handrails 34"-38" above tread	Yes	
Handrail extends a minimum of 1' beyond top and bottom riser (if no safety hazard and space permits)	No	
Handgrip oval or round	Round	
Handgrip has a smooth surface	Yes	
Handgrip diam. 1 1/4" - 1 3/4"	Yes	
1 1/2" clearance between wall and handrail	NA	

Notes:

Restrooms	N/A
Floors, Drinking Fountains, Telephones	N/A
Signs, Signals, and Switches	N/A
Swimming Pool/ Lake beach	N/A
Shower Rooms	N/A
Picnicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Bullough's Pond Park		
Size (Ac): 1.4 acres (not including pond)		
Address: Bullough Park, Newton Centre		
Ward: 2		
General Facility Notes: On-street parking; sloped, perimeter park along pond shore; stone dust sidewalk running the length of the park on Bulloughs Park Rd. is not accessible in some sections; skating hut demolished in 2017. Sitting area is accessible with two benches and companion space on a concrete outlook constructed from the existing skating hut foundation in 2018.		
Site Furnishings		YES
Description		Comments
Tables & Benches		
Number of Benches	YES	7 benches total
Number of Tables	NO	
Located adjacent to accessible paths	YES	2 benches on the concrete outlook are accessible
Back and Arm Rests	YES	5 out of 7 benches have back and arm rest
Trash Cans		
Located adjacent to accessible paths	NO	
Notes:		
Trails & Paths		YES
Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	YES	SD; A.
Dimensions (width)		4 feet minimum
Rails	NO	
Signage for visually impaired	NO	
Notes:		
Play Areas	N/A	
Game Areas	N/A	
Boat Docks	N/A	
Fishing Facilities	N/A	
Community Gardens	N/A	
Parking	N/A	
Ramps	N/A	
Site Access, Path of Travel, Entrances	YES	
Site Access		
Description		Comments
Surface evenly paved or hard-packed	YES	
Ponding of water?	NA	N/A
Path of Travel		
Description		Comments
Path does not require the use of stairs	YES	
Path does not require the use of wheelchair ramp	YES	
Path is stable, firm and slip resistant	YES	Perimeter stone dust path has a number of obstructions due to erosion
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	YES	
Continuous common surface, no changes in level greater than 1/8 inch	NO	surface condition is fair but lacks continuity in some sections
Any objects protruding onto the pathway that may not be detected by a person with a visual disability using a cane	YES	
Stairs and Doors	N/A	
Restrooms	N/A	
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picnicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: Burr Playground

Size (Ac): 5.1 acres

Address: Waverly Ave. or Park Street, Newton Corner (across from Bigelow Middle School), Newton Corner

Ward: 1

General Facility Notes: Accessible pathways to the building and splash pad from both Park St. and Waverly Ave.; accessible splash pad constructed in 2017; Play structures are not accessible; Burr Playground serves Bigelow Middle School.

Site Furnishings		YES	
Description			Comments
Tables & Benches			
Number of Benches	YES	8	
Number of Tables			
Located adjacent to accessible paths			
Back and Arm Rests	YES	5	
Trash Cans			
Located adjacent to accessible paths	YES	1	
Picnic Shelters			
Located adjacent to accessible paths			
Notes:			

Trails & Paths		YES	
Description			Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	YES	A	
Dimensions (width)		8 FT	
Rails	NO		
Signage for visually impaired	NO		
Benches	No		
Notes:			

Aquatics		YES	
Description			Comments
Facility Type (P=Pool, L=Lake Beach, SP= Splash Pad)	YES	SP	
Accessible Entrance	YES		
Location from accessible parking	YES	walkway from parking or ramp from street	
Safety features i.e. warning for visually impaired	No		
Location from accessible path into water		zero entry	
Handrails	NA		
Shade provided (ST=Shade Trees, SS=Shade Shelter)	Yes	Trees	
Notes:			

Play Areas		YES	
Description			Comments
Facility Type (3-5 Yrs, 5-12 Yrs)	yes	no accessibility	
Same experience provided to all	no		
Access Routes			
Located adjacent to accessible paths	no		
Enough space between equipment for wheelchair	no		
Notes:			

Game Areas		YES	
Description			Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Bocce)	Yes	1RF, 2BF, 4TN, 1 BK	
Access Routes			
Located adjacent to accessible paths	Yes	Basketball court	
Berm cuts onto courts	NA	Courts are open to path, no curb cut required	
Equipment			
Spectator Seating	No		
Notes:			

Boat Docks N/A

Fishing Facilities N/A

Community Gardens N/A

Parking YES

Total Spaces		Required Accessible Spaces
		6 1 Space
Description		Comments
Parking Amenities (L=lot, ST=street)	YES	L
Accessible space located closest to accessible entrance	Yes	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	YES	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	Yes	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	No	
Sign with international symbol of accessibility at each space	Yes	
Surface evenly paved or hard-packed (no cracks)	NO	concrete broken in multiple spots
Surface slope less than 1:20, 5%	Yes	
Notes:		

Ramps		YES	
Description			Comments
Slope Maximum 1:12	No	Ramp to Building not to code	
Minimum width 4 ft between handrails	YES		
Handrails on both sides if ramp is longer than 6 ft	YES		
Handrails at 34" and 19" from ramp surface	YES		

Handrails extend 12" beyond top and bottom	Yes	
Handgrip oval or round	Round	
Handgrip smooth surface	Yes	
Handgrip diameter between 1 1/4" and 2"	Yes	
Clearance of 1 1/2" between wall and wall rail	NA	
Non-slip surface	Yes	
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction	NA	

Notes:

Site Access, Path of Travel, Entrances **YES**

<u>Site Access</u>		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	Yes	
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Disembarking area at accessible entrance	Yes	

<u>Path of Travel</u>		
Description		Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than 1/8 inch	No	

<u>Entrances</u>		
Description		Comments
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	Yes	No signage
Level space extending 5 ft. from the door, interior and exterior of entrance doors	Yes	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)	Yes	
At least 18" clear floor area on latch, pull side of door	Yes	
Door handle no higher than 48" and operable with a closed fist	No	
Vestibule is 4 ft plus the width of the door swinging into the space	No	
Entrance(s) on a level that makes elevators accessible		N/A
Door mats less than 1/2" thick are securely fastened	Yes	
Door mats more than 1/2" thick are recessed	Yes	
Grates in path of travel have openings of 1/2" maximum		N/A
Signs at non-accessible entrance(s) indicate direction to accessible entrance	No	
Emergency egress – alarms with flashing lights and audible signals, sufficiently lighted	Yes	

Notes:

Stairs and Doors **YES**

<u>Stairs</u>		
Description		Comments
Minimum 32" clear opening	Yes	
At least 18" clear floor space on pull side of door	Yes	
Threshold maximum 1/2" high, beveled on both sides	No	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)	No	
Hardware minimum 36", maximum 48" above the floor	Yes	
Clear, level floor space extends out 5 ft from both sides of the door	Yes	
Door adjacent to revolving door is accessible and unlocked		N/A
Doors opening into hazardous area have hardware that is knurled or roughened		N/A

Notes:

Restrooms **YES**

<u>Restrooms</u>		
Description		Comments
5 ft turning space measured 12" from the floor	Yes	

<u>At least one Sink</u>		
Description		Comments
Clear floor space of 30" by 48" to allow a forward approach	Yes	
Mounted without pedestal or legs, height 34" to top of rim	Yes	
Extends at least 22" from the wall	No	17.5in
Open knee space a minimum 19" deep, 30" width, and 27" high	Yes	
Cover exposed pipes with insulation	Yes	
Faucets operable with closed fist (lever or spring activated handle)	Yes	

<u>At least one Stall ---Single use restrooms</u>		
Description		Comments
Accessible to person using wheelchair at 60" wide by 72" deep	No	
Stall door is 36" wide	No	34.5in
Stall door swings out	Yes	
Stall door is self closing	Yes	
Stall door has a pull latch	No	
Lock on stall door is operable with a closed fist, and 32" above the floor	No	
Coat hook is 54" high	None	

<u>Toilet</u>		
Description		Comments
18" from center to nearest side wall	Yes	
42" minimum clear space from center to farthest wall or fixture	Yes	
Top of seat 17"-19" above the floor	Yes	

<u>Grab Bars</u>		
Description		Comments
On back and side wall closest to toilet	Yes	
1 1/4" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	No	
Acid-etched or roughened surface	No	
42" long	Yes	

<u>Fixtures</u>		
Description		Comments
1 1/4" diameter	No	
1 1/2" clearance to wall	No	
Located 30" above and parallel to the floor	No	

Notes:

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

YES

Switches, Controls and Signs

Description

Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach.

yes

Comments

Electrical outlets centered no lower than 18" above the floor

yes

Warning signals must be visual as well as audible

Yes

Notes:

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Cabot Park		
Size (Ac): 11.6 acres		
Address: 101 Eastside Parkway, Newtonville		
Ward: 2		
General Facility Notes: Sidewalk along Eastside Pkwy provides accessibility to tennis courts and off-leash dog area.; no accessible pathways in the park; no accessible route connecting amenities; 2019 school construction included accessible play structures, basketball court, and other schoolyard pavement games; accessible path connections to new sidewalk and curb cut ramps at Eastside Pkwy.		
Site Furnishings		YES
Description	Yes	Comments
Tables & Benches		
Number of Benches	YES	16 benches
Number of Tables	YES	2 Picnic tables
Located adjacent to accessible paths	No	There are no benches along an accessible path
Back and Arm Rests	Yes	12 out of 16 benches have backrests
Trash Cans		
Located adjacent to accessible paths	Yes	
Notes:		
Trails & Paths		YES
Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	YES	Asphalt
Dimensions (width)	YES	5-ft minimum
Rails	NO	
Signage for visually impaired	NO	
Notes:		
Play Areas		YES
Description	Yes	Comments
Facility Type (3-5 Yrs, 5-12 Yrs)	YES	3-5 yrs; 5-12 yrs
Same experience provided to all	YES	
Access Routes		
Located adjacent to accessible paths	No	
Enough space between equipment for wheelchair	Yes	
Notes:		
Game Areas		YES
Description	Yes	Comments
Facility Type (RF=Rectangular Fields, BF=Ballfields, BK=Basketball, TN=Tennis, BC= Bocce)	Yes	3 BF, 2 BK, 2 TN, 4 BC
Access Routes		
Located adjacent to accessible paths	Yes	Ballfields are adjacent to accessible route
Berm cuts onto courts	NA	
Equipment		
Spectator Seating	Yes	Not on accessible route
Notes:		
Boat Docks		N/A
Fishing Facilities		N/A
Community Gardens		N/A
Parking		N/A
Ramps		N/A
Site Access, Path of Travel, Entrances		YES
Path of Travel		
Description	Yes	Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than 1/4 inch	Yes	
Entrances		
Description	Yes	Comments
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	Yes	No signage
Level space extending 5 ft. from the door, interior and exterior of entrance doors	Yes	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)	Yes	
At least 18" clear floor area on latch, pull side of door	Yes	
Door handle no higher than 48" and operable with a closed fist	Yes	
Vestibule is 4 ft plus the width of the door swinging into the space	N/A	
Entrance(s) on a level that makes elevators accessible	N/A	
Door mats less than 1/2" thick are securely fastened	Yes	
Door mats more than 1/2" thick are recessed	Yes	
Grates in path of travel have openings of 1/2" maximum	N/A	
Signs at non-accessible entrance(s) indicate direction to accessible entrance	No	
Emergency egress – alarms with flashing lights and audible signals, sufficiently lighted	Yes	
Notes:		
Stairs and Doors		YES
Doors		
Description	Yes	Comments
Minimum 32" clear opening	Yes	
At least 18" clear floor space on pull side of door	Yes	
Threshold maximum 1/2" high, beveled on both sides	No	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)	Yes	
Hardware minimum 36", maximum 48" above the floor	Yes	
Clear, level floor space extends out 5 ft from both sides of the door	Yes	

Door adjacent to revolving door is accessible and unlocked	N/A	
Doors opening into hazardous area have hardware that is knurled or roughened	N/A	
Notes:		
Restrooms		
		YES
Description		Comments
5 ft turning space measured 12" from the floor	Yes	
At least one Sink		
Description		Comments
Clear floor space of 30" by 48" to allow a forward approach	Yes	
Mounted without pedestal or legs, height 34" to top of rim	Yes	
Extends at least 22" from the wall	yes	
Open knee space a minimum 19" deep, 30" width, and 27" high	Yes	
Cover exposed pipes with insulation	Yes	
Faucets operable with closed fist (lever or spring activated handle)	Yes	
At least one Stall		
Description		Comments
Accessible to person using wheelchair at 60" wide by 72" deep	No	Single use bathrooms
Stall door is 36" wide	Yes	
Stall door swings out	Yes	
Stall door is self closing	No	
Stall door has a pull latch	No	
Lock on stall door is operable with a closed fist, and 32" above the floor	Yes	
Coat hook is 54" high	No	62in
Toilet		
Description		Comments
18" from center to nearest side wall	No	
42" minimum clear space from center to farthest wall or fixture	Yes	
Top of seat 17"-19" above the floor	Yes	
Grab Bars		
Description		Comments
On back and side wall closest to toilet	No	
1 1/2" diameter	Yes	
1 1/2" clearance to wall	No	
Located 30" above and parallel to the floor	Yes	
Acid-etched or roughened surface	Yes	
42" long	No	30in
Fixtures		
Description		Comments
1 1/2" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	No	33.5in
Notes:		
Floors, Drinking Fountains, Telephones		
		YES
Floors		
Description		Comments
Non-slip surface	No	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored	N/A	
Corridor width minimum is 3 ft	Yes	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor	Yes	
Notes:		
Signs, Signals, and Switches		
		YES
Switches, Controls and Signs		
Description		Comments
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach	Yes	
Electrical outlets centered no lower than 18" above the floor	Yes	
Warning signals must be visual as well as audible	Yes	
Notes:		
Swimming Pool/ Lake beach		
		N/A
Shower Rooms		
		N/A
Picknicking		
		N/A
Off Leash Dog Areas (OLA)		
		YES
Description		Comments
Access Routes		
Located adjacent to accessible paths	yes	
Area accessible	no	
Notes:		

Facility Name: Captain Ryan Park 'Police Park'

Size (Ac): .4 acre

Address: Washington Street and Cherry Street, West Newton

Ward: 3

General Facility Notes: Small passive pocket park; accessible pathways with benches.

Site Furnishings

YES

Description	Yes	Comments
Tables & Benches		
Number of Benches		4
Number of Tables		0
Located adjacent to accessible paths	YES	
Back and Arm Rests	yes	
Grills		
Located adjacent to accessible paths	no	
Trash Cans		
Located adjacent to accessible paths	no	
Picnic Shelters		
Located adjacent to accessible paths	no	

Notes:

Trails & Paths

YES

Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	yes	Asphalt
Dimensions (width)	No	
Rails	No	
Signage for visually impaired	No	
Benches	yes	

Notes:

Play Areas

N/A

Game Areas

N/A

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Path of Travel		
Description	Yes	Comments
Path does not require the use of stairs	No	
Path does not require the use of wheelchair ramp	No	
Path is stable, firm and slip resistant	YES	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		unknown, pathways are generally gradually sloped.
Continuous common surface, no changes in level greater than 1/8 inch	YES	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	No	not applicable
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	No	not applicable
Curb on the pathway must have curb cuts at drives, parking and drop-offs	No	not applicable

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Carleton Park

Size (Ac): .1 acre

Address: Carleton Street, Newton Corner

Ward: 1

General Facility Notes: The city's smallest park; level lawn area; no on-street parking; accessible stone dust seating area with benches and picnic table; amenities are accessible from sidewalk.

Site Furnishings

YES

Description		Comments
Tables & Benches		
Number of Benches	Yes	2
Number of Tables	Yes	1
Located adjacent to accessible paths	Yes	one bench and one picknick table adjacent to stone dust area
Back and Arm Rests	Yes	both benches have backs but no arm rests
Grills		
Located adjacent to accessible paths	N/A	N/A
Trash Cans		
Located adjacent to accessible paths	no	
Picnic Shelters		
Located adjacent to accessible paths	no	

Notes:

Trails & Paths

N/A

Play Areas

N/A

Game Areas

N/A

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Site Access		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	No	No parking area
Surface evenly paved or hard-packed	yes	
Ponding of water?	no	
Path of Travel		
Description		Comments
Path does not require the use of stairs	yes	
Path does not require the use of wheelchair ramp	yes	
Path is stable, firm and slip resistant	yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	yes	
Continuous common surface, no changes in level greater than ¼ inch	yes	

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Chaffin Park

Size (Ac): 1.74 acre

Address: Corner of Vernon Street and Centre Street, Newton Corner

Ward: 1

General Facility Notes: Paved accessible asphalt path from Centre st. and Vernon st. corner; accessible parking space in adjacent pkg lot on Vernon St.; Contiguous to Farlow Park; 2-5 yr play structure.

Site Furnishings

YES

Description	Yes	Comments
Tables & Benches		
Number of Benches	Yes	7 (4 Double 3 Single)
Number of Tables	YES	1 Game Table
Located adjacent to accessible paths	YES	
Back and Arm Rests	YES	
Located adjacent to accessible paths	yes	
Trash Cans		
Located adjacent to accessible paths	yes	1 Big Belly
Picnic Shelters		
Located adjacent to accessible paths	NA	

Notes:

Trails & Paths

YES

Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	YES	A With granite curbing
Dimensions (width)	YES	6 ft
Rails		
Signage for visually impaired	No	
Benches		

Notes:

Play Areas

YES

Description	Yes	Comments
Facility Type (3-5 Yrs,5-12 Yrs)	Yes	2 5-yr
Same experience provided to all	no	
Access Routes		
Located adjacent to accessible paths	Yes	
Enough space between equipment for wheelchair	Yes	

Notes:Playground built in 2007

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Description	Yes	Comments
Parking Amenities (L=lot, ST=street)	Yes	
Accessible space located closest to accessible entrance	Yes	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	Yes	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	Yes	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	N/A	
Sign with international symbol of accessibility at each space	Yes	
Sign 5'-8" to top of sign	Yes	
Surface evenly paved or hard-packed (no cracks)	Yes	
Surface slope less than 1:20, 5%	Yes	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	Yes	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	Yes	

Notes:

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Site Access		
Description	Yes	Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	Yes	
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Path of Travel		
Description	Yes	Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	YES	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	YES	
Continuous common surface, no changes in level greater than 1/8 inch	YES	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	no	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	YES	
Curb on the pathway must have curb cuts at drives,parking and drop-offs	N/A	
Entrances		
Description	Yes	Comments
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	YES	
Level space extending 5 ft. from the door, interior and exterior of entrance doors	YES	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		30"
At least 18" clear floor area on latch, pull side of door	YES	
Door handle no higher than 48" and operable with a closed fist	YES	
Vestibule is 4 ft plus the width of the door swinging into the space	YES	
Entrance(s) on a level that makes elevators accessible	YES	
Door mats less than 1/2" thick are securely fastened	YES	

Door mats more than 1/2" thick are recessed	YES	
Grates in path of travel have openings of 1/2" maximum	No	
Signs at non-accessible entrance(s) indicate direction to accessible entrance	YES	
Emergency egress -- alarms with flashing lights and audible signals, sufficiently lighted	YES	

Notes:

Stairs and Doors **YES**

Stairs		
Description		Comments
Open risers	No	
Nosings not projecting	YES	
Treads no less than 11" wide	YES	
Handrails on both sides	No	
Handrails 34"-38" above tread	No	
Handrail extends a minimum of 1' beyond top and bottom riser (if no safety hazard and space permits)	No	
Handgrip oval or round	No	
Handgrip has a smooth surface	YES	
Handgrip diam. 1 1/4" - 1 1/2"	No	
1 1/2" clearance between wall and handrail	No	

Doors		
Description		Comments
Minimum 32" clear opening	YES	
Threshold maximum 1/2" high, beveled on both sides	YES	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)	YES	
Hardware minimum 36", maximum 48" above the floor	YES	
Clear, level floor space extends out 5 ft from both sides of the door	YES	
Door adjacent to revolving door is accessible and unlocked	N/A	
Doors opening into hazardous area have hardware that is knurled or roughened	N/A	

Notes:

Restrooms **YES**

Description		Comments
5 ft turning space measured 12" from the floor	YES	

At least one Sink

Description		Comments
Clear floor space of 30" by 48" to allow a forward approach	YES	
Mounted without pedestal or legs, height 34" to top of rim	YES	
Extends at least 22" from the wall	YES	
Open knee space a minimum 19" deep, 30" width, and 27" high	YES	
Cover exposed pipes with insulation	YES	
Faucets operable with closed fist (lever or spring activated handle)	YES	

At least one Stall

Description		Comments
Accessible to person using wheelchair at 60" wide by 72" deep	YES	
Stall door is 36" wide	YES	
Stall door swings out	YES	
Stall door is self closing	No	
Stall door has a pull latch	No	
Lock on stall door is operable with a closed fist, and 32" above the floor	No	
Coat hook is 54" high	No	

Toilet

Description		Comments
18" from center to nearest side wall	YES	
42" minimum clear space from center to farthest wall or fixture	YES	
Top of seat 17"-19" above the floor	YES	

Grab Bars

Description		Comments
On back and side wall closest to toilet	YES	
1 1/2" diameter	YES	
1 1/2" clearance to wall	YES	
Located 30" above and parallel to the floor	YES	
Acid-etched or roughened surface	YES	
42" long	YES	

Fixtures

Description		Comments
1 1/2" diameter	YES	
1 1/2" clearance to wall	YES	
Located 30" above and parallel to the floor	YES	

Notes:

Floors, Drinking Fountains, Telephones **YES**

Floors		
Description		Comments
Non-slip surface	YES	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored	N/A	
Corridor width minimum is 3 ft	YES	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor	YES	

Drinking Fountains		
Description		Comments
Spouts no higher than 36" from floor to outlet	N/A	
Hand operated push button or level controls	N/A	
Spouts located near front with stream of water as parallel to front as possible	N/A	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain	N/A	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach	N/A	

Telephones

Description		Comments
Highest operating part a maximum 54" above the floor	N/A	
Access within 12" of phone, 30" high by 30" wide	N/A	
Adjustable volume control on headset so identified	N/A	

Notes:

Signs, Signals, and Switches		YES
Switches, Controls and Signs		
<i>Description</i>		<i>Comments</i>
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach	No	
Electrical outlets centered no lower than 18" above the floor	YES	
Warning signals must be visual as well as audible	N/A	
Signs		
<i>Description</i>		<i>Comments</i>
Mounting height must be 60" to centerline of the sign	N/A	
Within 18" of door jamb or recessed	N/A	
Letters and numbers a t least 1/4" high	N/A	
Letters and numbers raised .03"	N/A	
Letters and numbers contrast with the background color	n/a	
Notes:		
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picknicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: Charlesbank Park 'Nonantum Place Playground'

Size (Ac): .5 acres

Address: Nonantum Place, Newton Corner

Ward: 1

General Facility Notes: Small pocket park; accessible route with ramp and hand rails to benches and picnic table; new accessible play equipment area.

Site Furnishings

YES

Description	Yes	Comments
Tables & Benches		
Number of Benches	Yes	4 - 3 accessible
Number of Tables	Yes	1
Located adjacent to accessible paths	Yes	
Back and Arm Rests	Yes	3 w/backs only
Grills		
Located adjacent to accessible paths	N/A	
Trash Cans		
Located adjacent to accessible paths	Yes	
Picnic Shelters		
Located adjacent to accessible paths	N/A	

Notes:

Trails & Paths

YES

Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	C
Dimensions (width)	Yes	5' minimum
Rails	Yes	
Signage for visually impaired	No	

Notes:

Play Areas

YES

Description	Yes	Comments
Facility Type (3-5 Yrs,5-12 Yrs)	Yes	3-5, 5-12
Same experience provided to all	Yes	
Access Routes		
Located adjacent to accessible paths	Yes	
Enough space between equipment for wheelchair	Yes	

Notes:

Game Areas

N/A

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

YES

Description	Yes	Comments
Slope Maximum 1:12	Yes	
Minimum width 4 ft between handrails	Yes	
Handrails on both sides if ramp is longer than 6 ft	Yes	
Handrails at 34" and 19" from ramp surface	Yes	
Handrails extend 12" beyond top and bottom	Yes	
Handgrip oval or round	Round	
Handgrip smooth surface	Yes	
Handgrip diameter between 1 1/4" and 2"	Yes	
Clearance of 1 1/2" between wall and wall rail	N/A	
Non-slip surface	Yes	
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction	Yes	

Notes:

Site Access, Path of Travel, Entrances

YES

Site Access		
Description	Yes	Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	N/A	no parking area and no street parking
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Disembarking area at accessible entrance	N/A	
Path of Travel		
Description	Yes	Comments
Path does not require the use of stairs	yes	
Path does not require the use of wheelchair ramp	no	
Path is stable, firm and slip resistant	yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	yes	
Continuous common surface, no changes in level greater than 1/8 inch	yes	

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Charles Brown and Oak Hill Middle Schools Playfields		
Size (Ac): 11.3 acres		
Address: Wheeler Road, Newton Centre		
Ward: 8		
General Facility Notes: Ballfields and soccer fields; no accessible pathways to or within field areas. The footprint for site specs includes the Oak Hill school and 2 parking lots.		
Site Furnishings YES		
Description		Comments
Number of benches	No	
Number of Tables	No	
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	yes	2 bigbelly trash compactors; 2 bigbelly recycling units
Picnic Shelters		
Located adjacent to accessible paths	NA	
Notes:		
Trails & Paths YES		
Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Noi	
Dimensions (width)	NA	
Rails	NA	
Signage for visually impaired	NA	
Notes:		
Play Areas N/A		
Game Areas YES		
Description		Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Boacce)	yes	3 RF, 2 BF
Access Routes		
Located adjacent to accessible paths	yes	
Berm cuts onto courts	No	
Equipment		
Height		
Dimensions		
Spectator Seating		
Notes: There is 1 climbing structure, 2 little leagues fields, 1 softball field, 1 baseball field, 4 soccer fields and 1 track/field area. All ballfields have a backstop, players benches and proective screens. The athletic field is irrigated with well water.		
Boat Docks N/A		
Fishing Facilities N/A		
Community Gardens N/A		
Parking YES		
Total Spaces	Accessible Spaces	
45 Spaces	3 Space	
Description		Comments
Parking Amenities (L=lot, ST=street)	Yes	3 L
Accessible space located closest to accessible entrance	Yes	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	na	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	no	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	Yes	2
Sign with international symbol of accessibility at each space	Yes	
Sign 5'-8" to top of sign	Yes	2
Surface evenly paved or hard-packed (no cracks)		
Surface slope less than 1:20, 5%	yes	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present.	yes	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	yes	
Notes:		
Ramps N/A		
Site Access, Path of Travel, Entrances YES		
Site Access		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	No	
Surface evenly paved or hard-packed	NA	
Ponding of water?	Yes	
Disembarking area at accessible entrance	No	
Path of Travel		
Description		Comments
Path does not require the use of stairs	yes	
Path does not require the use of wheelchair ramp	yes	
Path is stable, firm and slip resistant	yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than 1/8 inch	No	Path has cracks and some pot holes
Notes:		
Stairs and Doors N/A		
Restrooms N/A		
Floors, Drinking Fountains, Telephones N/A		
Signs, Signals, and Switches N/A		
Swimming Pool/ Lake beach N/A		
Shower Rooms N/A		

Picnicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: City Hall & War Memorial Grounds

Size (Ac): 10 acres

Address: 1000 Commonwealth Avenue, Newton Centre

Ward: 6

General Facility Notes: Stone dust pathways loop around the ponds and lead to parking; stone dust path and historic pond bridges in need of accessibility improvements including curb cuts; City Hall grounds include Millennium Park on Homer St. which is accessible and leads to the building's accessible entrance; accessible concrete sidewalk around the building and grounds.

Site Furnishings

YES

Table with 3 columns: Description, Yes, Comments. Sub-sections: Tables & Benches (Number of Benches: 9, Number of Tables: 3 Picnic, Located adjacent to accessible paths: 2, Back and Arm Rests: 9); Trash Cans (Located adjacent to accessible paths: 1); Picnic Shelters (Located adjacent to accessible paths: NA).

Notes:

Trails & Paths

YES

Table with 3 columns: Description, Yes, Comments. Description: Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge), Dimensions (width), Rails, Signage for visually impaired.

Notes:

Play Areas

N/A

Game Areas

N/A

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Site Access

Table with 3 columns: Description, Yes, Comments. Description: Accessible path of travel from passenger disembarking area and parking area to accessible entrance, Surface evenly paved or hard-packed, Ponding of water?, Disembarking area at accessible entrance.

Path of Travel

Table with 3 columns: Description, Yes, Comments. Description: Path does not require the use of stairs, Path does not require the use of wheelchair ramp, Path is stable, firm and slip resistant, Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50), Continuous common surface, no changes in level greater than 1/4 inch.

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Claflin Park		
Size (Ac): .75 acre		
Address: Lowell Street, Newton Centre		
Ward: 1		
General Facility Notes: Sloped Grassy area primarily used as dog park. Crumbling stairs and pathways do not meet MAAB or ADA requirements		
Site Furnishings		N/A
Trails & Paths		YES
<i>Description</i>		<i>Comments</i>
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	Asphalt
Dimensions (width)		4-ft min.
Rails	No	
Signage for visually impaired	No	
Notes:		
Play Areas		N/A
Game Areas		N/A
Boat Docks		N/A
Fishing Facilities		N/A
Community Gardens		N/A
Parking		N/A
Ramps		N/A
Site Access, Path of Travel, Entrances		YES
Site Access		
<i>Description</i>		<i>Comments</i>
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	NA	
Surface evenly paved or hard-packed	No	
Ponding of water?	No	
Disembarking area at accessible entrance	NA	
Path of Travel		
<i>Description</i>		<i>Comments</i>
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	No	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	No	
Continuous common surface, no changes in level greater than 1/8 inch	No	
Notes:		
Stairs and Doors		N/A
Restrooms		N/A
Floors, Drinking Fountains, Telephones		N/A
Signs, Signals, and Switches		N/A
Swimming Pool/ Lake beach		N/A
Shower Rooms		N/A
Picnicking		N/A
Off Leash Dog Areas (OLA)		N/A

Facility Name: Cold Spring Park 'New Cold Spring Park' + 'Old Cold Spring Park'		
Size (Ac): 65 acres		
Address: Beacon Street; Duncklee Street; Plymouth Road, Newton Highlands (main entrances)		
Ward: 6		
General Facility Notes: Accessible parking and path around tennis courts and to seasonal Farmers Market from Beacon St.; portions of the trail through the woods are accessible; outdoor exercise equipment is not accessible; steep paved maintenance road with pedestrian access into the park from Duncklee street not accessible; off-leash area and ballfield not accessible; Acreage includes Old Cold Spring Park and New Cold Spring Park; adjacent to Zervas Elementary School; contiguous to portions of the Cochituate aqueduct.		
Site Furnishings	YES	
<i>Description</i>	Yes	Comments
Tables & Benches		
Number of Benches	yes	14 benches total
Number of Tables	Yes	2
Located adjacent to accessible paths	No	4 Benches along accessible route
Back and Arm Rests	No	Only backrest, no armrest
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	Yes	
Picnic Shelters		
Located adjacent to accessible paths	NA	
Notes:		
Trails & Paths		
<i>Description</i>	YES	
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	A, SD
Dimensions (width)	Yes	6-ft min
Rails	No	
Signage for visually impaired	No	
Notes:		
Play Areas		
Game Areas		
<i>Description</i>	YES	
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC= Bocce)	Yes	1 RF, 2 BF, 4 TN, 2 BK
Access Routes		
Located adjacent to accessible paths	Yes	Only Tennis courts are adjacent to accessible route
Berm cuts onto courts	NA	
Equipment		
Spectator Seating	Yes	
Notes:		
Boat Docks		
Fishing Facilities		
Community Gardens		
Parking		
<i>Total Spaces</i>	Accessible Spaces	
	62	5 Space
<i>Description</i>	Yes	Comments
Parking Amenities (L=lot, ST=street)	Yes	Lot
Accessible space located closest to accessible entrance	Yes	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	NA	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	Yes	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	No	
Sign with international symbol of accessibility at each space	Yes	
Surface evenly paved or hard-packed (no cracks)	Yes	
Surface slope less than 1:20, 5%	Yes	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	NA	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	NA	
Notes: Parking lot requires restriping. Accessible aisle striping doesn't seem to meet MAAB requirements.		
Ramps		
Site Access, Path of Travel, Entrances		
<i>Site Access</i>	YES	
<i>Description</i>	Yes	Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	Yes	
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Disembarking area at accessible entrance	Yes	
Path of Travel		
<i>Description</i>	Yes	Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	No	Some portions of the trail do not meet ADA or MAAB slope requirements
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	No	
Continuous common surface, no changes in level greater than 1/8 inch	Yes	
Curb on the pathway must have curb cuts at drives, parking and drop-offs	NA	
Notes:		
Stairs and Doors		
Restrooms		
Floors, Drinking Fountains, Telephones		

Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picknicking	N/A	
Off Leash Dog Areas (OLA)	YES	
<i>Description</i>		<i>Comments</i>
Access Routes		
Located adjacent to accessible paths	No	
Area accessible	No	Lawn and dirt
Notes:		

Facility Name: Coletti-Magni Park

Size (Ac): .46 acres

Address: Corner of Watertown Street and Bridge Street., Nonantum

Ward: 1

General Facility Notes: Accessible pathways w/benches and bus stop; Watertown St. crosswalk with curb cut ramp at Bridge St. corner.

Site Furnishings

YES

Description		Comments
Tables & Benches		
Number of Benches	yes	8 DuMor gray slat benches with backs, no arm rests
Number of Tables	yes	1 Chess table with four concrete slab pedestal seats, no backs, no arm rests
Located adjacent to accessible paths	yes	
Back and Arm Rests	no	NO Arm rests, all benches are backed
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	yes	2 bigbelly trash compactors; 2 bigbelly recycling units
Picnic Shelters		
Located adjacent to accessible paths	NA	

Notes: Covered bust stop with bench, no back, no arm rest, WWII memorial with 2 flagpoles

Trails & Paths

YES

Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	yes	C
Dimensions (width)	yes	Five foot wide concrete paths
Rails	no	
Signage for visually impaired	no	
Benches	yes	8 DuMor gray slat benches with backs, no arm rests

Notes:

Play Areas

N/A

Game Areas

N/A

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Description		Comments
Parking Amenities (L=lot, ST=street)	No	5 Metered on street parking spaces, no accessible parking spaces
Accessible space located closest to accessible entrance	no	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	NA	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	No	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	no	
Sign with international symbol of accessibility at each space	NA	
Sign 5'-8' to top of sign	NA	
Surface evenly paved or hard-packed (no cracks)	NA	
Surface slope less than 1:20, 5%	NA	

Notes:

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Site Access		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	yes	
Surface evenly paved or hard-packed	yes	
Ponding of water?		
Disembarking area at accessible entrance		
Path of Travel		
Description		Comments
Path does not require the use of stairs	yes	
Path does not require the use of wheelchair ramp	yes	
Path is stable, firm and slip resistant	yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	yes	
Continuous common surface, no changes in level greater than 1/4 inch	yes	

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Cronin's Cove

Size (Ac): .5

Address: Lake Avenue, Newton Highlands

Ward: 6

General Facility Notes: Steps down from street to a sloped, inaccessible path w/benches; no accesible entrance; access to Crystal Lake shoreline and canoe launch.

Site Furnishings

YES

Description		Comments
Tables & Benches		
Number of Benches	YES	6 benches
Number of Tables	no	
Located adjacent to accessible paths	No	ramp leading to natural dirt path level
Back and Arm Rests	YES	
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	No	1
Picnic Shelters		
Located adjacent to accessible paths	NA	
Notes:		

Trails & Paths

YES

Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	YES	NS
Dimensions (width)		Varies
Rails	No	
Signage for visually impaired	No	
Notes:		

Play Areas

N/A

Game Areas

N/A

Boat Docks

Yes

Description		Comments
Facility Type (R=River, P= Pond)	Yes	Pond
Access Routes		
Located adjacent to accessible paths	No	
Handrails	No	
Notes:		

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	No	
Surface evenly paved or hard-packed	YES	
Ponding of water?	No	
Disembarking area at accessible entrance	No	
Path of Travel		
Description		Comments
Path does not require the use of stairs	YES	
Path does not require the use of wheelchair ramp	YES	
Path is stable, firm and slip resistant		
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		
Continuous common surface, no changes in level greater than 1/8 inch		
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	NO	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		
Curb on the pathway must have curb cuts at drives, parking and drop-offs	NO	
Notes:		

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Crystal Lake Park		
Size (Ac): 2.0 acres; Crystal Lake: 24 acres		
Address: 30 Rogers Street, Newton Highlands		
Ward: 6		
General Facility Notes: Parking lot currently not accessible; portions of the bathhouse are accessible; steep slope down to the lake beach area; a ramp from the bathhouse to beach area is not accessible; accessible dead-end stone dust pathway runs behind 230 Lake Ave. to Levingston Cove; asphalt sidewalk along Rogers St. constructed in 2016; acreage breakdown: bathhouse and parking lot: .7 acres; newly acquired 20 Rogers: 1.0 acre; portion of 230 Lake Avenue plus easement behind house: .2 acres.		
Site Furnishings		YES
Description	Yes	Comments
Tables & Benches		
Number of Benches	Yes	4 at shoreline
Number of Tables	Yes	10
Located adjacent to accessible paths	No	
Back and Arm Rests	Yes	Backed benches only, no armrests
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	NA	
Picnic Shelters		
Located adjacent to accessible paths	NA	
Notes:		
Trails & Paths		YES
Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	NS
Dimensions (width)		Varies; dirt path
Rails	No	
Signage for visually impaired	No	
Notes:		
Aquatics		YES
Description		Comments
Facility Type (P=Pool, L=Lake Beach, SP=Splash Pad)	Yes	L
Accessible Entrance	No	
Location from accessible parking	NA	No accessible path to the park's shoreline. Shoreline is elevated and retained by a wall, public beach has accessible beach wheelchair
Safety features i.e. warning for visually impaired	NA	
Location from accessible path into water	NA	
Handrails	NA	
Shade provided (ST=Shade Trees, SS=Shade Shelter)	Yes	Trees
Notes:		
Play Areas		N/A
Game Areas		N/A
Boat Docks		N/A
Fishing Facilities		N/A
Community Gardens		N/A
Parking		YES
<u>Total Spaces</u>	<u>Accessible Spaces</u>	
	25	2 Spaces
Description		Comments
Parking Amenities (L=lot, ST=street)	Yes	Lot
Accessible space located closest to accessible entrance	No	striped accessible parking spaces do not meet MAAB requirements
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	NA	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	Yes	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	Yes	
Sign with international symbol of accessibility at each space	Yes	
Surface evenly paved or hard-packed (no cracks)	Yes	
Surface slope less than 1:20, 5%	No	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	NA	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	NA	
Notes: Parking spaces on a slope exceeding MAAB requirements		
Ramps		YES
Description		Comments
Slope Maximum 1:12	Yes	
Minimum width 4 ft between handrails	Yes	
Handrails on both sides if ramp is longer than 6 ft	Yes	
Handrails at 34" and 19" from ramp surface	Yes	
Handrails extend 12" beyond top and bottom	No	
Handgrip oval or round	Round	
Handgrip smooth surface	Yes	

Handgrip diameter between 1½" and 2"	Yes	
Clearance of 1½" between wall and wall rail	NA	
Non-slip surface	Yes	
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction	Yes	

Notes:

Site Access, Path of Travel, Entrances	YES
---	------------

Site Access		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance		
Surface evenly paved or hard-packed		
Ponding of water?		
Disembarking area at accessible entrance		
Path of Travel		
Description		Comments
Path does not require the use of stairs	No	All paths are primarily exceeding max slopes
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	Beach is sand, but paths leading to sand area is slip resistant
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	Only at ramp and a few other sections. Generally paths are not accessible
Continuous common surface, no changes in level greater than ½ inch	NO	

Entrances		
Description		Comments
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance		
Level space extending 5 ft. from the door, interior and exterior of entrance doors		
Minimum 32" clear width opening (i.e. 36" door with standard hinge)		
At least 18" clear floor area on latch, pull side of door		
Door handle no higher than 48" and operable with a closed fist		
Vestibule is 4 ft plus the width of the door swinging into the space		
Entrance(s) on a level that makes elevators accessible		
Door mats less than ½" thick are securely fastened		
Door mats more than ½" thick are recessed		
Grates in path of travel have openings of ½" maximum		
Signs at non-accessible entrance(s) indicate direction to accessible entrance		
Emergency egress – alarms with flashing lights and audible signals, sufficiently lighted		

Notes: Bathroom in moldy due to COVID 19 Closure - Inspection not possible

Stairs and Doors	YES
-------------------------	------------

Notes: Bathroom in moldy due to COVID 19 Closure - Inspection not possible

Restrooms	YES
------------------	------------

Notes: Bathroom in moldy due to COVID 19 Closure - Inspection not possible

Floors, Drinking Fountains, Telephones	YES
---	------------

Notes: Bathroom in moldy due to COVID 19 Closure - Inspection not possible

Signs, Signals, and Switches	YES
-------------------------------------	------------

Notes: Bathroom in moldy due to COVID 19 Closure - Inspection not possible

Lake beach	YES
-------------------	------------

Description		Comments
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides	Yes	
Lifting device	No	
Transfer area 18" above the path of travel and a minimum of 18" wide	NA	
Unobstructed path of travel not less than 48" wide around pool	NA	
Non-slip surface	No	

Notes:

Shower Rooms	YES
---------------------	------------

Notes: Bathroom in moldy due to COVID 19 Closure - Inspection not possible

Picnicking	N/A
-------------------	------------

Off Leash Dog Areas (OLA)	N/A
----------------------------------	------------

Facility Name: Davis 'Tom Torchia' Playground

Size (Ac): 2.0 acres

Address: Eden Street, West Newton

Ward: 3

General Facility Notes: Softball field with no accessible route, basketball court and playground with accessible route from the 'Family access parking lot; accessible pathway from Eden Ave. sidewalk; no curb ramp at entrance; accessible playground area with splash pad; formerly the Davis School.

Site Furnishings

Description	YES	
	Yes	Comments
Tables & Benches		
Number of Benches	Yes	3 - 1 accessible
Number of Tables	N/A	
Located adjacent to accessible paths	Yes	
Back and Arm Rests	Yes	
Grills		
Located adjacent to accessible paths	N/A	
Trash Cans		
Located adjacent to accessible paths	Yes	
Picnic Shelters		
Located adjacent to accessible paths	N/A	
Notes:		

Trails & Paths

Description	YES	
	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	A
Dimensions (width)	Yes	5'
Rails	N/A	
Signage for visually impaired	No	
Benches		see above
Notes:		

Aquatics

Description	YES	
	Yes	Comments
Facility Type (P=Pool, L=Lake Beach, SP= Splash Pad)	Yes	
Accessible Entrance	Yes	
Location from accessible parking	No	
Safety features i.e. warning for visually impaired		
Location from accessible path into water	Yes	
Handrails	N/A	
Shade provided (ST=Shade Trees, SS=Shade Shelter)	Yes	ST
Notes:		

Play Areas

Description	YES	
	Yes	Comments
Facility Type (3-5 Yrs, 5-12 Yrs)	Yes	18 m - 5yrs and 5 - 12 yrs
Same experience provided to all	no	Yes in 18m - 5 yrs No in 5 - 12 yrs.
Access Routes		
Located adjacent to accessible paths	Yes	
Enough space between equipment for wheelchair	Yes	
Play Areas built in 2017		

Game Areas

Description	YES	
	Yes	Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC= Bocce)	Yes	BF and BK
Access Routes		
Located adjacent to accessible paths	Yes	
Berm cuts onto courts	No	
Equipment		
Spectator Seating		
Notes:		

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Site Access		
Description	Yes	Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	N/A	no designated parking space
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Disembarking area at accessible entrance	No	
Path of Travel		
Description	Yes	Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than 1/8 inch	Yes	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	Yes	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	N/A	
Curb on the pathway must have curb cuts at drives, parking and drop-offs	N/A	

Entrances		
<i>Description</i>		<i>Comments</i>
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	N/A	no public building
Level space extending 5 ft. from the door, interior and exterior of entrance doors	N/A	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)	N/A	
At least 18" clear floor area on latch, pull side of door	N/A	
Door handle no higher than 48" and operable with a closed fist	N/A	
Vestibule is 4 ft plus the width of the door swinging into the space	N/A	
Entrance(s) on a level that makes elevators accessible	N/A	
Door mats less than 1/2" thick are securely fastened	N/A	
Door mats more than 1/2" thick are recessed	N/A	
Grates in path of travel have openings of 1/2" maximum	N/A	
Signs at non-accessible entrance(s) indicate direction to accessible entrance	N/A	
Emergency egress – alarms with flashing lights and audible signals, sufficiently lighted	N/A	
Notes:		
Stairs and Doors	N/A	
Restrooms	N/A	
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picknicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: Edmands Park 'Cabot Woods'

Size (Ac): 32.6 acres

Address: Blake Street, Newtonville

Ward: 2

General Facility Notes: large, natural, wooded area with meadow and uneven dirt trail throughout; unofficial off-leash dog area; park is inaccessible.

Site Furnishings

YES

Description		Comments
Tables & Benches		
Number of Benches	yes	2 Benches both with backs, one with arm rests
Number of Tables	no	
Located adjacent to accessible paths	no	
Back and Arm Rests	yes	
Grills		
Located adjacent to accessible paths		
Trash Cans		
Located adjacent to accessible paths	yes	Two trash bins located at parking areas; 2 pet waste stations
Picnic Shelters		
Located adjacent to accessible paths	NA	

Notes: There is an informational kiosk on site.

Trails & Paths

YES

Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	yes	NS
Dimensions (width)		varies
Rails	No	
Signage for visually impaired	No	
Benches	yes	2 Benches both with backs, one with arm rests

Notes:

Play Areas

N/A

Game Areas

N/A

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Site Access		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	no	
Surface evenly paved or hard-packed	no	
Ponding of water?	Yes	
Disembarking area at accessible entrance	no	
Path of Travel		
Description		Comments
Path does not require the use of stairs	no	
Path does not require the use of wheelchair ramp	no	
Path is stable, firm and slip resistant	no	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	no	
Continuous common surface, no changes in level greater than 1/4 inch	no	

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Eliot Memorial Park

Size (Ac): .2 acres

Address: Eliot Memorial Road, Newton Centre

Ward: 7

General Facility Notes: historic memorial overlook area; not accessible; no paths; no site furnishings and amenities

Site Furnishings	N/A
Trails & Paths	N/A
Play Areas	N/A
Game Areas	N/A
Boat Docks	N/A
Fishing Facilities	N/A
Community Gardens	N/A
Parking	N/A
Ramps	N/A
Site Access, Path of Travel, Entrances	N/A
Stairs and Doors	N/A
Restrooms	N/A
Floors, Drinking Fountains, Telephones	N/A
Signs, Signals, and Switches	N/A
Swimming Pool/ Lake beach	N/A
Shower Rooms	N/A
Picnicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Elmwood Park

Size (Ac): 1.5 acres

Address: Lowell Avenue and Elmwood Avenue, Newtonville

Ward: 2

General Facility Notes: large, rectangular-shaped traffic island; trees, shrubs and lawn only; no pathways; two new benches in lawn area; not accessible.

Site Furnishings		YES
Description	Yes	Comments
Tables & Benches		
Number of Benches	Yes	2
Number of Tables	No	
Located adjacent to accessible paths	No	
Back and Arm Rests	Yes	benches have backs but no arm rests
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	NA	
Picnic Shelters		
Located adjacent to accessible paths	NA	
Notes:		
Trails & Paths		
		N/A
Play Areas		N/A
Game Areas		N/A
Boat Docks		N/A
Fishing Facilities		N/A
Community Gardens		N/A
Parking		N/A
Ramps		N/A
Site Access, Path of Travel, Entrances		N/A
Stairs and Doors		N/A
Restrooms		N/A
Floors, Drinking Fountains, Telephones		N/A
Signs, Signals, and Switches		N/A
Swimming Pool/ Lake beach		N/A
Shower Rooms		N/A
Picnicking		N/A
Off Leash Dog Areas (OLA)		N/A

Facility Name: Emerson Playground		
Size (Ac): 1.0 acres		
Address: Pettee Street, Newton Upper Falls (adjacent to Emerson Community Center)		
Ward: 5		
General Facility Notes: no internal pathways on the playfield; accessible playground area with poured in place safety surfacing; accessible pathways and benches; accessible picnic table; accessible basketball court; accessible parking in adjacent building lot; adjacent to Emerson Community Center.		
Site Furnishings		YES
Description	Yes	Comments
Tables & Benches		
Number of Benches	Yes	7 benches
Number of Tables	Yes	2 picnic tables
Located adjacent to accessible paths	Yes	
Back and Arm Rests	Yes	3 out of 7 benches are backed, no arm rests
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	Yes	
Picnic Shelters		
Located adjacent to accessible paths	Yes	
Notes:		
Trails & Paths		YES
Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	Asphalt
Dimensions (width)	Yes	4-ft min
Rails	NO	
Signage for visually impaired	NO	
Notes:		
Play Areas		YES
Description	Yes	Comments
Facility Type (3-5 Yrs,5-12 Yrs)	Yes	3-5, 5-12
Same experience provided to all	Yes	
Access Routes		
Located adjacent to accessible paths	Yes	
Enough space between equipment for wheelchair	Yes	
Notes:		
Game Areas		YES
Description	Yes	Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC= Bocce)	Yes	RF, BK, BF
Access Routes		
Located adjacent to accessible paths	Yes	Only basket ball court is along accessible route
Berm cuts onto courts	NA	
Equipment		
Spectator Seating	Yes	
Notes:		
Boat Docks		N/A
Fishing Facilities		N/A
Community Gardens		N/A
Parking		N/A
Ramps		N/A
Site Access, Path of Travel, Entrances		YES
Site Access		
Description	NA	Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	NA	
Surface evenly paved or hard-packed	NA	
Ponding of water?	NA	
Disembarking area at accessible entrance	NA	
Path of Travel		
Description	Yes	Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than ¼ inch	Yes	
Stairs and Doors		N/A
Restrooms		N/A
Floors, Drinking Fountains, Telephones		N/A
Signs, Signals, and Switches		N/A
Swimming Pool/ Lake beach		N/A
Shower Rooms		N/A
Picnicking		N/A
Off Leash Dog Areas (OLA)		N/A

Facility Name: Hamilton Playground 'Lower Falls'

Size (Ac): 4.3 acres

Address: 545 Grove St., Lower Falls

Ward: 4

General Facility Notes: Accessible play apparatus area constructed in 2013; level sidewalk circumvents playfield; no internal pathways; Lower Falls Community Center building accessible with lift and accessible parking; formerly Hamilton School.

Site Furnishings

Description	YES	Comments
Tables & Benches		
Number of Benches	yes	15 benches - 5 dumbor gray slat benches with backs no arm rests, 2 backless benches, 8 benches with backs and arm rests
Number of Tables	yes	1 picnic table
Located adjacent to accessible paths	no	
Back and Arm Rests	yes	15 benches - 5 dumbor gray slat benches with backs no arm rests, 2 backless benches, 8 benches with backs and arm rests
Grills		
Located adjacent to accessible paths	no	
Trash Cans		
Located adjacent to accessible paths	yes	2 big belly trash bin and 2 big belly recycling unit, located in parking lot
Picnic Shelters		
Located adjacent to accessible paths	no	1 picnic table
Notes: Two bike racks, one pest waste station, one backless players bench.		

Trails & Paths

Description	YES	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	no	
Dimensions (width)		
Rails		
Signage for visually impaired		
Benches	yes	15 benches - 5 dumbor gray slat benches with backs no arm rests, 2 backless benches, 8 benches with backs and arm rests
Notes:		

Play Areas

Description	YES	Comments
Facility Type (3-5 Yrs,5-12 Yrs)	yes	Fibar safety surfacing.
Same experience provided to all	yes	
Access Routes		
Located adjacent to accessible paths	no	
Enough space between equipment for wheelchair	no	
Notes:		

Game Areas

Description	YES	Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC= Bocce)	yes	2 TN, 2 BF, 3 RF
Access Routes		
Located adjacent to accessible paths	no	
Berm cuts onto courts	no	
Equipment		
Spectator Seating		
There are 16 parking spaces (15 + 1 handicap parking space). Athletic field is irrigated with well water.		

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

YES

Description	YES	Comments
Access Routes		
Located adjacent to accessible paths	yes	
Notes:		

Parking

YES

Total Spaces	Accessible Spaces	
16	1 Space	
Description		
Parking Amenities (L=lot, ST=street)	yes	L
Accessible space located closest to accessible entrance	yes	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	na	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	yes	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	yes	
Sign with international symbol of accessibility at each space	yes	
Sign 5'-8' to top of sign	yes	
Surface evenly paved or hard-packed (no cracks)	no	
Surface slope less than 1:20, 5%	yes	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	NA	accessible parking space abuts the building.
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	no	
Notes:		

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Site Access	Comments
Description	

Accessible path of travel from passenger disembarking area and parking area to accessible entrance	yes	
Surface evenly paved or hard-packed	yes	
Ponding of water?		
Disembarking area at accessible entrance	yes	
Path of Travel		
Description		Comments
Path does not require the use of stairs	yes	
Path does not require the use of wheelchair ramp	yes	
Path is stable, firm and slip resistant	yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	yes	
Continuous common surface, no changes in level greater than 1/8 inch		
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane		
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"		
Curb on the pathway must have curb cuts at drives, parking and drop-offs		
Entrances		
Description		Comments
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	yes	
Level space extending 5 ft. from the door, interior and exterior of entrance doors	yes	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)	yes	
At least 18" clear floor area on latch, pull side of door	Yes	
Door handle no higher than 48" and operable with a closed fist	Yes	
Vestibule is 4 ft plus the width of the door swinging into the space		N/A
Entrance(s) on a level that makes elevators accessible	Yes	
Door mats less than 1/2" thick are securely fastened	No	
Door mats more than 1/2" thick are recessed	No	
Grates in path of travel have openings of 1/4" maximum		N/A
Signs at non-accessible entrance(s) indicate direction to accessible entrance	Yes	
Emergency egress -- alarms with flashing lights and audible signals, sufficiently lighted	Yes	
Notes:		
Stairs and Doors YES		
Stairs		
Description		Comments
Open risers	No	
Nosings not projecting	No	
Treads no less than 11" wide	Yes	
Handrails on both sides	Yes	
Handrails 34" - 38" above tread	Yes	
Handrail extends a minimum of 1' beyond top and bottom riser (if no safety hazard and space permits)	Yes	
Handgrip oval or round	Yes	
Handgrip has a smooth surface	Yes	
Handgrip diam. 1 1/2" - 1 3/4"	Yes	
1 1/2" clearance between wall and handrail	Yes	
Doors		
Description		Comments
Minimum 32" clear opening	yes	
At least 18" clear floor space on pull side of door	yes	
Threshold maximum 1/2" high, beveled on both sides	Yes	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)	Yes	
Hardware minimum 36", maximum 48" above the floor	Yes	
Clear, level floor space extends out 5 ft from both sides of the door	Yes	
Door adjacent to revolving door is accessible and unlocked		N/A
Doors opening into hazardous area have hardware that is knurled or roughened		N/A
Notes:		
Restrooms YES		
Description		Comments
5 ft turning space measured 12" from the floor	Yes	
At least one Sink		
Description		Comments
Clear floor space of 30" by 48" to allow a forward approach	Yes	
Mounted without pedestal or legs, height 34" to top of rim	Yes	
Extends at least 22" from the wall	Yes	
Open knee space a minimum 19" deep, 30" width, and 27" high	Yes	
Cover exposed pipes with insulation	Yes	
Faucets operable with closed fist (lever or spring activated handle)	Yes	
At least one Stall		
Description		Comments
Accessible to person using wheelchair at 60" wide by 72" deep	Yes	
Stall door is 36" wide	Yes	
Stall door swings out	Yes	
Stall door is self closing	No	
Stall door has a pull latch	No	
Lock on stall door is operable with a closed fist, and 32" above the floor	No	42in
Coat hook is 54" high		
Toilet		
Description		Comments
18" from center to nearest side wall	Yes	
42" minimum clear space from center to farthest wall or fixture	Yes	
Top of seat 17"-19" above the floor	Yes	
Grab Bars		
Description		Comments
On back and side wall closest to toilet	Yes	
1 1/2" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor		36in
Acid-etched or roughened surface	Yes	
42" long	Yes	
Fixtures		
Description		Comments
1 1/2" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	Yes	

Notes:

Floors, Drinking Fountains, Telephones

YES

Floors

Description

		<i>Comments</i>
Non-slip surface	No	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored	Yes	
Corridor width minimum is 3 ft	Yes	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor	Yes	

Drinking Fountains

Description

		<i>Comments</i>
Spouts no higher than 36" from floor to outlet	Yes	
Hand operated push button or level controls	Yes	
Spouts located near front with stream of water as parallel to front as possible	Yes	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain	Yes	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach	Yes	

Notes:

Signs, Signals, and Switches

YES

Switches, Controls and Signs

Description

		<i>Comments</i>
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach	Yes	
Electrical outlets centered no lower than 18" above the floor	Yes	
Warning signals must be visual as well as audible	Yes	

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Harry Gath Memorial Pool and Bathhouse

Size (Ac): .6 Acres inclusive of the Bathhouse building

Address: 250 Albemarle Road, Newtonville

Ward: 2

General Facility Notes: Interior renovation in 2013 included: updated accessible bathrooms, accessible pool deck, and pool accessible with lift access; accessible bubbler; kiddie pool not accessible; adjacent fieldhouse is accessible; on-street parking on Albemarle Rd.

Site Furnishings

N/A

Trails & Paths

N/A

Aquatics

YES

Description		Comments
Facility Type (P=Pool, L=Lake Beach, SP=Splash Pad)	Pool	
Accessible Entrance	Yes	
Location from accessible parking	Yes	
Safety features i.e. warning for visually impaired	No	
Location from accessible path into water	Yes	
Handrails	Yes	
Shade provided (ST=Shade Trees, SS=Shade Shelter)	SS	

Notes:

Play Areas

N/A

Game Areas

N/A

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

YES

Notes: See Albemarle Park Parking Count

Ramps

YES

Description		Comments
Slope Maximum 1:12	Yes	
Minimum width 4 ft between handrails	Yes	
Handrails on both sides if ramp is longer than 6 ft	Yes	
Handrails at 34" and 19" from ramp surface	Yes	
Handrails extend 12" beyond top and bottom	Yes	
Handgrip oval or round	Round	
Handgrip smooth surface	Yes	
Handgrip diameter between 1 1/4" and 2"	Yes	
Clearance of 1 1/2" between wall and wall rail	Yes	
Non-slip surface	Yes	
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction	Yes	

Notes:

Site Access, Path of Travel, Entrances

YES

Path of Travel

Description		Comments
Path does not require the use of stairs	no	
Path does not require the use of wheelchair ramp	no	
Path is stable, firm and slip resistant	yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	no	
Continuous common surface, no changes in level greater than 1/4 inch	yes	

Entrances

Description		Comments
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	No	

Notes:

Stairs and Doors

YES

Stairs

Description		Comments
Open risers	No	
Nosings not projecting	Yes	
Treads no less than 11" wide	Yes	
Handrails on both sides	Yes	
Handrails 34"-38" above tread	Yes	
Handrail extends a minimum of 1' beyond top and bottom riser (if no safety hazard and space permits)	Yes	
Handgrip oval or round	No	
Handgrip has a smooth surface	Yes	
Handgrip diam. 1 1/4" - 1 1/2"	No	
1 1/2" clearance between wall and handrail	Yes	

Doors

Description		Comments
Minimum 32" clear opening	Yes	
At least 18" clear floor space on pull side of door		N/A
Closing speed minimum 3 seconds to within 3" of the latch		N/A
Maximum pressure 5 pounds interior doors		N/A
Threshold maximum 1/2" high, beveled on both sides	Yes	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)	Yes	
Hardware minimum 36", maximum 48" above the floor	Yes	
Clear, level floor space extends out 5 ft from both sides of the door	Yes	
Door adjacent to revolving door is accessible and unlocked		N/A
Doors opening into hazardous area have hardware that is knurled or roughened		N/A

Notes:

Restrooms		YES	
Description			Comments
5 ft turning space measured 12" from the floor		Yes	
At least one Sink			
Description			Comments
Clear floor space of 30" by 48" to allow a forward approach		Yes	
Mounted without pedestal or legs, height 34" to top of rim		Yes	
Extends at least 22" from the wall		Yes	
Open knee space a minimum 19" deep, 30" width, and 27" high		Yes	
Cover exposed pipes with insulation		No	
Faucets operable with closed fist (lever or spring activated handle)		Yes	
At least one Stall			
Description			Comments
Accessible to person using wheelchair at 60" wide by 72" deep		Yes	
Stall door is 36" wide		Yes	
Stall door swings out		Yes	
Stall door is self closing		No	
Stall door has a pull latch		Yes	
Lock on stall door is operable with a closed fist, and 32" above the floor		Yes	
Coat hook is 54" high		No	
Toilet			
Description			Comments
18" from center to nearest side wall		Yes	
42" minimum clear space from center to farthest wall or fixture		No	40in
Top of seat 17"-19" above the floor		Yes	
Grab Bars			
Description			Comments
On back and side wall closest to toilet		Yes	
1 1/2" diameter		Yes	
1 1/2" clearance to wall		Yes	
Located 30" above and parallel to the floor		Yes	
Acid-etched or roughened surface		Yes	
42" long		Yes	
Fixtures			
Description			Comments
1 1/2" diameter		Yes	
1 1/2" clearance to wall		Yes	
Located 30" above and parallel to the floor		Yes	
Notes:			
Floors, Drinking Fountains, Telephones		YES	
Floors			
Description			Comments
Non-slip surface		Yes	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored			N/A
Corridor width minimum is 3 ft		Yes	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor		Yes	
Drinking Fountains			
Description			Comments
Spouts no higher than 36" from floor to outlet		NA	Drinking fountains inoperable due to lead
Hand operated push button or level controls		NA	Drinking fountains inoperable due to lead
Spouts located near front with stream of water as parallel to front as possible		NA	Drinking fountains inoperable due to lead
If recessed, recess a minimum 30" width, and no deeper than depth of fountain		NA	Drinking fountains inoperable due to lead
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach		NA	Drinking fountains inoperable due to lead
Notes:			
Signs, Signals, and Switches		YES	
Switches, Controls and Signs			
Description			Comments
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach		Yes	
Electrical outlets centered no lower than 18" above the floor		Yes	
Warning signals must be visual as well as audible		No	
Notes:			
Swimming Pool/ Lake beach		YES	
Description			Comments
Ramp at least 34" wide with a non-slip surface extending into the shallow end, slope not exceeding 1:6 with handrails on both sides		No	
Lifting device		Yes	
Transfer area 18" above the path of travel and a minimum of 18" wide		No	
Unobstructed path of travel not less than 48" wide around pool		Yes	
Non-slip surface		Yes	
Notes:			
Shower Rooms		YES	
Description			Comments
Stalls 36" by 60" minimum, with a 36" door opening		Yes	One private stall
Floors are pitched to drain the stall at the corner farthest from entrance		Yes	
Floors are non-slip surface		Yes	
Controls operate by a single lever with a pressure balance mixing valve		Yes	
Controls are located on the center wall adjacent to the hinged seat		Yes	
Shower heads attached to a flexible metal hose		Yes	
Shower heads attached to wall mounting adjustable from 42" to 72" above the floor		Yes	
Seat is hinged and padded and at least 16" deep, folds upward, securely attached to side wall, height is 18" to the top of the seat, and at least 24" long		No	
Soap trays without handhold features unless they can support 250 pounds		Yes	
2 grab bars are provided, one 30" and one 48" long, or one continuous L shaped bar		Yes	
Grab bars are placed horizontally at 36" above the floor line		Yes	
Notes:			
Picknicking		N/A	
Off Leash Dog Areas (OLA)		N/A	

Facility Name: Heartbreak Hill Park @ Waban Hill Reservoir

Size (Ac): 5.1 acres

Address: Manet Road, Chestnut Hill

Ward: 7

General Facility Notes: Full renovation of the park constructed in 2019 to 2020; 1/4 mile perimeter stabilized stone dust path is accessible; new stair and handrail meet MAAB requirements; accessible parking space at one of the two park entrances; two benches with accessible companion pad; timber curbing along the outside perimeter of path installed as guide to the visually impaired; new plaza surface is accessible; path to plaza and stairs require a curb cut from Ward street; existing gate house building not open to the public and is not accessible.

Site Furnishings

YES

Table with 3 columns: Description, Yes, Comments. Includes sections for Tables & Benches and Trash Cans.

Notes:

Trails & Paths

YES

Table with 3 columns: Description, Yes, Comments. Includes rows for Surface, Dimensions, Rails, and Signage.

Notes:

Play Areas

N/A

Game Areas

N/A

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

YES

Table with 3 columns: Description, Yes, Comments. Includes sections for Total Spaces, Up to 25, and Description of parking amenities.

Notes:

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Table with 3 columns: Description, Yes, Comments. Includes sections for Site Access and Path of Travel.

Notes:

Stairs and Doors

YES

Table with 3 columns: Description, Yes, Comments. Includes rows for Open risers, Nosings, Treads, Handrails, and Handgrip.

Notes:

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms	N/A
Picnicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Horace Mann School Playground (formerly Carr School Playground)		
Size (Ac): 7.8 acres		
Address: Nevada Street, Newtonville		
Ward: 1		
General Facility Notes: building made fully accessible in 2012; there are no internal pathways to ball fields; play area accessible through parking lot; play area not accessible.		
Site Furnishings		YES
Description		Comments
Tables & Benches		
Number of Benches	No	7
Number of Tables	No	
Located adjacent to accessible paths	No	
Back and Arm Rests	Yes	Backs only
Grills		
Located adjacent to accessible paths	N/A	
Trash Cans		
Located adjacent to accessible paths	Yes	
Picnic Shelters		
Located adjacent to accessible paths	N/A	
Notes:		
Trails & Paths		YES
Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	A
Dimensions (width)	Yes	minimum 6'
Rails	N/A	
Signage for visually impaired	No	
Benches		See above
Notes:		
Play Areas		YES
Description		Comments
Facility Type (3-5 Yrs,5-12 Yrs)	Yes	5 - 12 yrs
Same experience provided to all	No	
Access Routes		
Located adjacent to accessible paths	Yes	
Enough space between equipment for wheelchair	Yes	
Playground relocated in 2013		
Game Areas		YES
Description		Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Boerce)	Yes	RF,BF
Access Routes		
Located adjacent to accessible paths	No	
Berm cuts onto courts	NA	
Equipment		
Spectator Seating	Yes	NO along accessible route
Notes:		
Boat Docks		N/A
Fishing Facilities		N/A
Community Gardens		N/A
Parking		YES
Total Spaces	Accessible Spaces	
30	2	
Description		Comments
Parking Amenities (L=lot, ST=street)	Yes	L
Accessible space located closest to accessible entrance	No	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	No	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	Yes	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	N/A	
Sign with international symbol of accessibility at each space	Yes	
Sign 5'-8' to top of sign	Yes	
Surface evenly paved or hard-packed (no cracks)	Yes	
Surface slope less than 1:20, 5%	Yes	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	Yes	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	Yes	
Parking is designed for school purposes. Use of parking lot for public nights and weekends.		
Ramps		N/A
Site Access, Path of Travel, Entrances		YES
Site Access		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	N/A	Building is not for public use.
Surface evenly paved or hard-packed	N/A	
Ponding of water?	N/A	
Disembarking area at accessible entrance	N/A	
Path of Travel		
Description		Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	

Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than 1/8 inch	Yes	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	N/A	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	N/A	
Curb on the pathway must have curb cuts at drives, parking and drop-offs	N/A	
Entrances		
<i>Description</i>		<i>Comments</i>
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	N/A	
Level space extending 5 ft. from the door, interior and exterior of entrance doors	N/A	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)	N/A	
At least 18" clear floor area on latch, pull side of door	N/A	
Door handle no higher than 48" and operable with a closed fist	N/A	
Vestibule is 4 ft plus the width of the door swinging into the space	N/A	
Entrance(s) on a level that makes elevators accessible	N/A	
Door mats less than 1/2" thick are securely fastened	N/A	
Door mats more than 1/2" thick are recessed	N/A	
Grates in path of travel have openings of 1/2" maximum	N/A	
Signs at non-accessible entrance(s) indicate direction to accessible entrance	N/A	
Emergency egress -- alarms with flashing lights and audible signals, sufficiently lighted	N/A	
Notes:		
Stairs and Doors	N/A	
Restrooms	N/A	
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picnicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: Hunnewell Playground

Size (Ac): 4.6 acres

Address: Grasmere Street, off Hunnewell Avenue, Newton Corner

Ward: 1

General Facility Notes: Park is inaccessible; no accessible route to tot lot; no accessible route to ballfield or fenced off-leash area; no accessible parking; steep stairs at the Grasmere Street entrance.

Site Furnishings

YES

Table with columns: Description, Yes, Comments. Includes sections for Tables & Benches, Grills, and Trash Cans.

Notes: Three pest waste stations. Enclosed off leash dog park.

Trails & Paths

N/A

Play Areas

YES

Table with columns: Description, Yes, Comments. Includes sections for Facility Type and Access Routes.

Notes:

Game Areas

YES

Table with columns: Description, Yes, Comments. Includes sections for Facility Type and Access Routes.

Notes:

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

N/A

Stairs and Doors

YES

Table with columns: Description, Yes, Comments. Lists various accessibility criteria for stairs.

Notes:

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

YES

Table with columns: Description, Yes, Comments. Includes section for Access Routes.

Notes:

Facility Name: Hyde Playground		
Size (Ac): 1.0 acres		
Address: Lincoln Street, Newton Highlands (adjacent to Hyde Community Center)		
Ward: 6		
General Facility Notes: Accessible garden area w/benches on Lincoln St.; accessible pathway from Lincoln to Erie; accessible concrete walkway to playstructure and accessible playground area constructed in 2019.		
Site Furnishings		YES
Description		Comments
Tables & Benches		
Number of Benches	Yes	17 total 8 are accessible
Number of Tables	Yes	both accessible
Located adjacent to accessible paths	Yes	
Back and Arm Rests	Yes	3 of the 8 are backless the rest back only
Grills		
Located adjacent to accessible paths	N/A	
Trash Cans		
Located adjacent to accessible paths	Yes	
Picnic Shelters		
Located adjacent to accessible paths	N/A	
Notes:		
Trails & Paths		YES
Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	C
Dimensions (width)	Yes	minimum 5'
Rails		
Signage for visually impaired	No	
Benches		see above
Notes:		
Play Areas		YES
Description		Comments
Facility Type (3-5 Yrs,5-12 Yrs)	Yes	2 - 5 yrs and 5 - 12 yrs
Same experience provided to all	Yes	
Access Routes		
Located adjacent to accessible paths	Yes	
Enough space between equipment for wheelchair	Yes	
Play Areas: Playground built in 2019		
Game Areas		YES
Description		Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Boce)	Yes	RF
Access Routes		
Located adjacent to accessible paths	Yes	
Berm cuts onto courts	N/A	
Equipment		
Height	N/A	
Dimensions	N/A	
Spectator Seating	N/A	
Notes:		
Boat Docks	N/A	
Fishing Facilities	N/A	
Community Gardens	N/A	
Parking	N/A	
Ramps	N/A	
Site Access, Path of Travel, Entrances		YES
Site Access		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	Yes	
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Disembarking area at accessible entrance	Yes	
Path of Travel		
Description		Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than 1/8 inch	Yes	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	Yes	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	Yes	
Curb on the pathway must have curb cuts at drives,parking and drop-offs	Yes	
Notes: The building adjacent to the playground is a private community Center		
Stairs and Doors	N/A	
Restrooms	N/A	
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picnicking	N/A	

Off Leash Dog Areas (OLA)

N/A

Facility Name: Islington Oval

Size (Ac): 1.5 acres

Address: Islington Road, Auburndale

Ward: 4

General Facility Notes: Inaccessible oval island; no pathways; site furniture not accessible.

Site Furnishings

YES

Description Yes Comments

Tables & Benches

Number of Benches	Yes	Three DuMor gray slat benches with backs.
Number of Tables	No	
Located adjacent to accessible paths	No	
Back and Arm Rests		Backs, no arm rests

Grills

Located adjacent to accessible paths	No	
--------------------------------------	----	--

Trash Cans

Located adjacent to accessible paths	No	
--------------------------------------	----	--

Picnic Shelters

Located adjacent to accessible paths	No	
--------------------------------------	----	--

Notes:

Trails & Paths	N/A
Play Areas	N/A
Game Areas	N/A
Boat Docks	N/A
Fishing Facilities	N/A
Community Gardens	N/A
Parking	N/A
Ramps	N/A
Site Access, Path of Travel, Entrances	N/A
Stairs and Doors	N/A
Restrooms	N/A
Floors, Drinking Fountains, Telephones	N/A
Signs, Signals, and Switches	N/A
Swimming Pool/ Lake beach	N/A
Shower Rooms	N/A
Picnicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Joanne C. Pellegrini Memorial Playground 'Hawthorn'

Size (Ac): 4.2 acres

Address: Hawthorn Street, Nonantum

Ward: 1

General Facility Notes: Community center with accessible parking lot; park entry from Hawthorn Street and ramp to building entrance; accessible playground and basketball half-court , shade structure with picnic tables constructed in 2013.

Site Furnishings

Description	YES	
	Yes	Comments
Tables & Benches		
Number of Benches	yes	11
Number of Tables	yes	2
Located adjacent to accessible paths	Yes	
Back and Arm Rests	Yes	Mixed
Grills		
Located adjacent to accessible paths	N/A	
Trash Cans		
Located adjacent to accessible paths	Yes	
Picnic Shelters		
Located adjacent to accessible paths	Yes	

Notes:

Trails & Paths

Description	YES	
	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	Asphalt
Dimensions (width)		Minimum 6'
Rails	No	
Signage for visually impaired	No	

Notes:

Play Areas

Description	YES	
	Yes	Comments
Facility Type (3-5 Yrs,5-12 Yrs)	Yes	Playground & Tot Lot
Same experience provided to all	Yes	yes in the 5 - 12yrs - No in tot lot
Access Routes		
Located adjacent to accessible paths	Yes	
Enough space between equipment for wheelchair	Yes	

Notes:

Game Areas

Description	YES	
	Yes	Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC= Bocce)	RF, BK, TN	lighted multipurpose field
Access Routes		
Located adjacent to accessible paths	Yes	
Berm cuts onto courts	N/A	

Notes:

Parking

Total Spaces	YES	
19	Accessible Spaces	
19	1 Space	
Description	Yes	Comments
Parking Amenities (L=lot, ST=street)	Lot	
Accessible space located closest to accessible entrance	Yes	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	N/A	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	Yes	
Minimum of 1 van space for every accessible space, 8' wide x 8' aisle.	N/A	
Sign with international symbol of accessibility at each space	Yes	
Sign 5'-8" to top of sign	Yes	
Surface evenly paved or hard-packed (no cracks)	Yes	
Surface slope less than 1:20, 5%	Yes	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	Yes	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow		

Notes:

Ramps

Description	YES	
	Yes	Comments
Slope Maximum 1:12		
Minimum width 4 ft between handrails	Yes	
Handrails on both sides if ramp is longer than 6 ft	Yes	
Handrails at 34" and 19" from ramp surface	Yes	
Handrails extend 12" beyond top and bottom		
Handgrip oval or round	Yes	
Handgrip smooth surface	Yes	
Handgrip diameter between 1 1/4" and 2"	Yes	
Clearance of 1 1/2" between wall and wall rail	Yes	
Non-slip surface	Yes	
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction	No	

Notes:

Site Access, Path of Travel, Entrances

YES	
Site Access	Comments
Description	

Accessible path of travel from passenger disembarking area and parking area to accessible entrance	Yes	
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Disembarking area at accessible entrance	Yes	
Path of Travel		
Description		Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		
Continuous common surface, no changes in level greater than 1/8 inch		
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	Yes	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	Yes	
Curb on the pathway must have curb cuts at drives, parking and drop-offs	Yes	
Entrances		
Description		Comments
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	Yes	Needs signage
Level space extending 5 ft. from the door, interior and exterior of entrance doors	Yes	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)	Yes	
At least 18" clear floor area on latch, pull side of door	Yes	
Door handle no higher than 48" and operable with a closed fist	Yes	
Vestibule is 4 ft plus the width of the door swinging into the space	Yes	
Entrance(s) on a level that makes elevators accessible	N/A	
Door mats less than 1/2" thick are securely fastened	No	
Door mats more than 1/2" thick are recessed	No	
Grates in path of travel have openings of 1/2" maximum	N/A	
Signs at non-accessible entrance(s) indicate direction to accessible entrance	No	
Emergency egress -- alarms with flashing lights and audible signals, sufficiently lighted	Yes	
Notes:		
Stairs and Doors YES		
Doors		
Description		Comments
Minimum 32" clear opening	Yes	
At least 18" clear floor space on pull side of door	Yes	
Threshold maximum 1/2" high, beveled on both sides	Yes	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)	Yes	
Hardware minimum 36", maximum 48" above the floor	Yes	
Clear, level floor space extends out 5 ft from both sides of the door	Yes	
Door adjacent to revolving door is accessible and unlocked	N/A	
Doors opening into hazardous area have hardware that is knurled or roughened	N/A	
Notes:		
Restrooms YES		
Description		Comments
5 ft turning space measured 12" from the floor	Yes	
At least one Sink		
Description		Comments
Clear floor space of 30" by 48" to allow a forward approach	Yes	
Mounted without pedestal or legs, height 34" to top of rim	No	
Extends at least 22" from the wall	Yes	
Open knee space a minimum 19" deep, 30" width, and 27" high	Yes	
Cover exposed pipes with insulation	No	
Faucets operable with closed fist (lever or spring activated handle)	Yes	
At least one Stall		
Description		Comments
Accessible to person using wheelchair at 60" wide by 72" deep	Yes	
Stall door is 36" wide	Yes	
Stall door swings out	Yes	
Stall door is self closing	No	
Stall door has a pull latch	No	
Lock on stall door is operable with a closed fist, and 32" above the floor	Yes	But at 41 inches high
Coat hook is 54" high	Yes	
Toilet		
Description		Comments
18" from center to nearest side wall	Yes	
42" minimum clear space from center to farthest wall or fixture	Yes	
Top of seat 17"-19" above the floor	Yes	
Grab Bars		
Description		Comments
On back and side wall closest to toilet	Yes	
1 1/2" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	No	33inches
Acid-etched or roughened surface	No	
42" long	Yes	
Fixtures		
Description		Comments
1 1/2" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	Yes	
Notes:		
Floors, Drinking Fountains, Telephones YES		
Floors		
Description		Comments
Non-slip surface	No	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored	N/A	
Corridor width minimum is 3 ft	Yes	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor	Yes	
Drinking Fountains		
Description		Comments

Spouts no higher than 36" from floor to outlet	Yes	
Hand operated push button or level controls	Yes	
Spouts located near front with stream of water as parallel to front as possible	Yes	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain	Yes	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach	Yes	

Signs, Signals, and Switches	YES	
-------------------------------------	------------	--

Switches, Controls and Signs		
-------------------------------------	--	--

Description		Comments
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach	Yes	
Electrical outlets centered no lower than 18" above the floor	Yes	
Warning signals must be visual as well as audible	Yes	

Signs		
--------------	--	--

Description		Comments
Mounting height must be 60" to centerline of the sign		
Within 18" of door jamb or recessed		
Letters and numbers a t least 1/4" high		
Letters and numbers raised .03"		
Letters and numbers contrast with the background color	Yes	

Notes:

Swimming Pool/ Lake beach	N/A
Shower Rooms	N/A
Picnicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Kennard Park		
Size (Ac): 14.0 acres		
Address: Dudley Road, Newton Centre		
Ward: 8		
General Facility Notes: Lawn and natural wooded area; inaccessible dirt footpaths throughout the wooded areas; accessible parking; building is Parks, Recreation & Culture HQ and has accessible ramped entrance; contiguous to Kennard Conservation Area and the Town of Brookline.		
Site Furnishings		YES
Description	Yes	Comments
Tables & Benches		
Number of Benches	1	
Number of Tables	No	
Located adjacent to accessible paths	No	
Back and Arm Rests	No	
Grills		
Located adjacent to accessible paths	No	
Trash Cans		
Located adjacent to accessible paths	No	
Picnic Shelters		
Located adjacent to accessible paths	No	
Notes:		
Trails & Paths		YES
Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	NS	
Dimensions (width)		variable with 3' to 5'
Rails	no	
Signage for visually impaired	no	
Benches	No	
Notes:		
Play Areas		N/A
Game Areas		N/A
Boat Docks		N/A
Fishing Facilities		N/A
Community Gardens		N/A
Parking		YES
Total Spaces	Accessible Spaces	
8	0	
Description		Comments
Parking Amenities (L=lot, ST=street)	L	
Accessible space located closest to accessible entrance	No	No accessible spots
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	No	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	No	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	No	
Sign with international symbol of accessibility at each space	No	
Sign 5'-8" to top of sign	No	
Surface evenly paved or hard-packed (no cracks)	No	
Surface slope less than 1:20, 5%	No	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	No	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	No	
Notes:		
Ramps		YES
Description	Yes	Comments
Slope Maximum 1:12	YES	to building
Minimum width 4 ft between handrails	YES	
Handrails on both sides if ramp is longer than 6 ft	YES	
Handrails at 34" and 19" from ramp surface	YES	
Handrails extend 12" beyond top and bottom	YES	
Handgrip oval or round	round	
Handgrip smooth surface	YES	
Handgrip diameter between 1 1/4" and 2"	YES	
Clearance of 1 1/2" between wall and wall rail	YES	
Non-slip surface	YES	
Level platforms (4ft x 4 ft) at every 30 ft, at top, at bottom, at change of direction	YES	
Notes: This is ramp into building. Front door is not accessible once you reach top of ramp.		
Site Access, Path of Travel, Entrances		YES
Site Access		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	No	
Surface evenly paved or hard-packed	No	
Ponding of water?	No	
Disembarking area at accessible entrance	No	
Path of Travel		
Description		Comments
Path does not require the use of stairs	YES	
Path does not require the use of wheelchair ramp	YES	
Path is stable, firm and slip resistant	No	non accessible naturalized paths
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	No	
Continuous common surface, no changes in level greater than 1/8 inch	No	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	No	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	No	

Curb on the pathway must have curb cuts at drives, parking and drop-offs	No	
Entrances		
<i>Description</i>		<i>Comments</i>
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	No	
Level space extending 5 ft. from the door, interior and exterior of entrance doors	No	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)	No	
At least 18" clear floor area on latch, pull side of door	No	
Door handle no higher than 48" and operable with a closed fist	No	
Vestibule is 4 ft plus the width of the door swinging into the space	No	
Entrance(s) on a level that makes elevators accessible	No	
Door mats less than 1/2" thick are securely fastened	No	
Door mats more than 1/2" thick are recessed	No	
Grates in path of travel have openings of 1/2" maximum	No	
Signs at non-accessible entrance(s) indicate direction to accessible entrance	No	
Emergency egress – alarms with flashing lights and audible signals, sufficiently lighted	No	
Notes:		
Stairs and Doors		
	YES	
Stairs		
<i>Description</i>		<i>Comments</i>
Open risers	No	
Nosings not projecting	No	
Treads no less than 11" wide	No	
Handrails on both sides	No	
Handrails 34"-38" above tread	No	
Handrail extends a minimum of 1' beyond top and bottom riser (if no safety hazard and space permits)	No	
Handgrip oval or round	No	
Handgrip has a smooth surface	No	
Handgrip diam. 1 1/4" - 1 1/2"	No	
1 1/2" clearance between wall and handrail	No	
Doors		
<i>Description</i>		<i>Comments</i>
Minimum 32" clear opening	No	
At least 18" clear floor space on pull side of door	No	
Closing speed minimum 3 seconds to within 3" of the latch	No	
Maximum pressure 5 pounds interior doors	No	
Threshold maximum 1/2" high, beveled on both sides	No	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)	No	
Hardware minimum 36", maximum 48" above the floor	No	
Clear, level floor space extends out 5 ft from both sides of the door	No	
Door adjacent to revolving door is accessible and unlocked	No	
Doors opening into hazardous area have hardware that is knurled or roughened	No	
Notes: Building and entrance are not accessible.		
Restrooms	N/A	
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picknicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: Louise Levingston Cove

Size (Ac): .5 acres

Address: Lake Avenue, Newton Highlands

Ward: 6

General Facility Notes: Accessible stone dust portion of pathway eroded and inaccessible; wheelchair ramp with discontinuous handrail at the Berwick Rd. and Lakewood Rd. entrances; renovation of the park set to begin in FY 22; Park Renovation will provide accessibility throughout the entire parcel.

Site Furnishings

YES

Table with 3 columns: Description, YES, Comments. Rows include Tables & Benches (Number of Benches: 7, Number of Tables: No, Located adjacent to accessible paths: 3, Back and Arm Rests: 6) and Grills (Located adjacent to accessible paths: No).

Table with 3 columns: Description, YES, Comments. Row includes Trash Cans (Located adjacent to accessible paths: YES).

Table with 3 columns: Description, YES, Comments. Row includes Picnic Shelters (Located adjacent to accessible paths: No).

Notes:

Trails & Paths

YES

Table with 3 columns: Description, YES, Comments. Rows include Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge), Dimensions (width): 4', Rails: YES, Signage for visually impaired: No, Benches: 7.

Notes:

Play Areas N/A

Game Areas N/A

Boat Docks N/A

Fishing Facilities N/A

Community Gardens N/A

Parking N/A

Ramps YES

Table with 3 columns: Description, YES, Comments. Rows include Slope Maximum 1:12, Minimum width 4 ft between handrails, Handrails on both sides if ramp is longer than 6 ft, Handrails at 34" and 19" from ramp surface, Handrails extend 12" beyond top and bottom, Handgrip oval or round, Handgrip smooth surface, Handgrip diameter between 1 1/2" and 2", Clearance of 1 1/2" between wall and wall rail, Non-slip surface, Level platforms (4R x 4 ft) at every 30 ft, at top, at bottom, at change of direction.

Notes: Ramp handrails are not continuous

Site Access, Path of Travel, Entrances

YES

Table with 3 columns: Description, YES, Comments. Rows include Site Access (Accessible path of travel from passenger disembarking area and parking area to accessible entrance: No, Surface evenly paved or hard-packed: No, Ponding of water?: YES, Disembarking area at accessible entrance: No).

Table with 3 columns: Description, YES, Comments. Rows include Path of Travel (Path does not require the use of stairs: YES, Path does not require the use of wheelchair ramp: no, Path is stable, firm and slip resistant: no, Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50): no, Continuous common surface, no changes in level greater than 1/8 inch: no, Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane: no, Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80": no, Curb on the pathway must have curb cuts at drives, parking and drop-offs: no).

Notes:

Stairs and Doors N/A

Restrooms N/A

Floors, Drinking Fountains, Telephones N/A

Signs, Signals, and Switches N/A

Swimming Pool/ Lake beach N/A

Shower Rooms N/A

Picnicking N/A

Off Leash Dog Areas (OLA) N/A

Facility Name: Lowell Park		
Size (Ac): .6 acres		
Address: Watertown Street and Walnut Street and Lowell Avenue, Newtonville		
Ward: 2		
<u>General Facility Notes:</u> Large, triangular traffic island; accessible pathways with benches from sidewalk constructed in 2012.		
Site Furnishings YES		
Description	Yes	Comments
Tables & Benches		
Number of Benches	3	
Number of Tables	No	
Located adjacent to accessible paths	3	
Back and Arm Rests	3	
Grills		
Located adjacent to accessible paths	No	
Trash Cans		
Located adjacent to accessible paths	1	
Picnic Shelters		
Located adjacent to accessible paths	No	
Notes:		
Trails & Paths YES		
Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	A	
Dimensions (width)	5'	
Rails	No	
Signage for visually impaired	No	
Benches	2	
Notes:		
Play Areas N/A		
Game Areas N/A		
Boat Docks N/A		
Fishing Facilities N/A		
Community Gardens N/A		
Parking N/A		
Ramps N/A		
Site Access, Path of Travel, Entrances YES		
Site Access		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	No	
Surface evenly paved or hard-packed	YES	
Ponding of water?	No	
Disembarking area at accessible entrance	No	
Path of Travel		
Description		Comments
Path does not require the use of stairs	YES	
Path does not require the use of wheelchair ramp	YES	
Path is stable, firm and slip resistant	YES	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	YES	
Continuous common surface, no changes in level greater than 1/8 inch	YES	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	No	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	No	
Curb on the pathway must have curb cuts at drives, parking and drop-offs	No	
Stairs and Doors N/A		
Restrooms N/A		
Floors, Drinking Fountains, Telephones N/A		
Signs, Signals, and Switches N/A		
Swimming Pool/ Lake beach N/A		
Shower Rooms N/A		
Picnicking N/A		
Off Leash Dog Areas (OLA) N/A		

Facility Name: Lyons Park		
Size (Ac): 5.3 acres		
Address: Commonwealth Ave., at Islington Road, Auburndale		
Ward: 4		
General Facility Notes: Little League field/bleachers not accessible; Marty Sender Pathway (DCR) leads to park down from Islington Rd.; conditions of the trail render it inaccessible; Bathrooms/concession are accessible but no accessible path to the building. Accessible path to concession stand from Commonwealth Ave. planned for 2020-2021 construction; contiguous to Auburndale Park; accessible stone dust trail from Lyons to Auburndale Park to be constructed in 2020-2021.		
Site Furnishings		YES
Description		Comments
Tables & Benches		
Number of Benches	YES	7
Number of Tables	No	
Located adjacent to accessible paths	No	
Back and Arm Rests	Yes	3 out of 7 benches have backrests
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	No	
Picnic Shelters		
Located adjacent to accessible paths	NA	
Notes:		
Trails & Paths		YES
Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	NS, sD
Dimensions (width)		4 ft min.
Rails	no	
Signage for visually impaired	no	
Notes:		
Play Areas		N/A
Game Areas		YES
Description		Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Bocce)	Yes	BF
Access Routes		
Located adjacent to accessible paths	No	
Berm cuts onto courts	NA	
Equipment		
Spectator Seating	Yes	
Notes:		
Boat Docks	N/A	
Fishing Facilities	N/A	
Community Gardens	N/A	
Parking	N/A	
Ramps	N/A	
Site Access, Path of Travel, Entrances	N/A	
Stairs and Doors	N/A	
Restrooms	N/A	
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picnicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: Linwood Park

Size (Ac): 1.25 acres

Address: Linwood Ave. and Walnut St., Newtonville

Ward: 2

General Facility Notes: Large traffic island with perimeter sidewalks; accessible route through the park; site furniture accessible.

Site Furnishings

YES

Description	Yes	Comments
Tables & Benches		
Number of Benches	yes	1
Number of Tables	No	
Located adjacent to accessible paths	No	Bench is not along a path
Back and Arm Rests	yes	Bench with back only, no armrest
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	NA	
Picnic Shelters		
Located adjacent to accessible paths	NA	

Notes:

Trails & Paths

YES

Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	Concrete
Dimensions (width)	Yes	6-ft min
Rails	No	
Signage for visually impaired	No	

Notes:

Play Areas

N/A

Game Areas

N/A

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Site Access		
Description	Yes	Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	NA	no parking
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Disembarking area at accessible entrance	NA	
Path of Travel		
Description	Yes	Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than 1/8 inch	No	

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Warren E. Lincoln Playground

Size (Ac): 5.42 acres

Address: Montclair Rd, Waban

Ward: 5

General Facility Notes: multi-use playing Fields 3-5 yr Play structure; 5-12 yr play structure; no paths to amenities.

Site Furnishings

Description	YES	
	Yes	Comments
Tables & Benches		
Number of Benches	yes	3 benches
Number of Tables	NA	
Located adjacent to accessible paths	No	
Back and Arm Rests	No	
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	No	
Picnic Shelters		
Located adjacent to accessible paths	NA	
Notes:		

Trails & Paths

Description	YES	
	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	No	No pathways within this park
Dimensions (width)	NA	
Rails	No	
Signage for visually impaired	No	
Notes:		

Play Areas

Description	YES	
	Yes	Comments
Facility Type (3-5 Yrs,5-12 Yrs)	Yes	3-5 yrs, 5-12 yrs
Same experience provided to all	No	
Access Routes		
Located adjacent to accessible paths	No	
Enough space between equipment for wheelchair	Yes	
Notes:		

Game Areas

Description	YES	
	Yes	Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC= Bocce)	Yes	1 BF, 1 RF
Access Routes		
Located adjacent to accessible paths	No	
Berm cuts onto courts	NA	
Equipment		
Spectator Seating	Yes	
Notes:		

Boat Docks	N/A
Fishing Facilities	N/A
Community Gardens	N/A
Parking	N/A
Ramps	N/A
Site Access, Path of Travel, Entrances	N/A
Stairs and Doors	N/A
Restrooms	N/A
Floors, Drinking Fountains, Telephones	N/A
Signs, Signals, and Switches	N/A
Swimming Pool/ Lake beach	N/A
Shower Rooms	N/A
Picnicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Nahanton Park

Size (Ac): 57.0 acres

Address: Nahanton Street and Winchester Street entrances, Newton Highlands

Ward: 8

General Facility Notes: Accessible parking in lot; no accessible route to Nature Center building; accessible stonedust riverpath (Florries Path); bridge at Florries path not accessible; accessible stone dust path from lower Winchester St. parking lot to Nahanton St. side; community gardens not accessible; formerly Infirmary Land/Alms House Park.

Site Furnishings		YES
Description	Yes	Comments
Tables & Benches		
Number of Benches	No	
Number of Tables	6	
Located adjacent to accessible paths	Yes	
Back and Arm Rests	Yes	Mixed
Grills		
Located adjacent to accessible paths	No	
Trash Cans		
Located adjacent to accessible paths	Yes	
Picnic Shelters		
Located adjacent to accessible paths	No	
Notes:		

Trails & Paths		YES
Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	SD & NS	
Dimensions (width)	Approx 6ft	
Rails	No	
Signage for visually impaired	No	
Benches	No	
Notes:		

Boat Docks		YES
Description	Yes	Comments
Facility Type (R=River, P= Pond)	River	Boat dock is semi accessible
Access Routes		
Located adjacent to accessible paths	Yes	
Handrails	No	
Notes:		

Fishing Facilities		N/A
Community Gardens		YES
Description	Yes	Comments
Access Routes		
Located adjacent to accessible paths	Yes	Portions are along stone dust trail. Other gradens are not along accessible routes
Notes:		

Parking		YES
Total Spaces	Accessible Spaces	
	25	1 Space
Description		
Parking Amenities (L=lot, ST=street)	Lot	
Accessible space located closest to accessible entrance	Yes	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	N/A	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	Yes	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	N/A	
Sign with international symbol of accessibility at each space	Yes	
Sign 5'-8" to top of sign	Yes	
Surface evenly paved or hard-packed (no cracks)	No	
Surface slope less than 1:20, 5%	Yes	
Curbs to pathway from parking lot at each space if sidewalk (curb) is present.	N/A	
Curbs are a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	N/A	
Notes:		

Ramps		N/A
Site Access, Path of Travel, Entrances		YES
Site Access		
Description	Yes	Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	Yes	
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Disembarking area at accessible entrance	Yes	
Path of Travel		
Description		
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	No	
Path is stable, firm and slip resistant	No	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).		
Continuous common surface, no changes in level greater than 1/4 inch	No	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	No	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	No	
Curbs on the pathway must have curb cuts at drives, parking and drop-offs	N/A	
Entrances		
Description		
		Comments

Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	No	
Level space extending 5 ft. from the door, interior and exterior of entrance doors	No	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)	Yes	
At least 18" clear floor area on latch, pull side of door	Yes	
Door handle no higher than 48" and operable with a closed fist	Yes	Height is acceptable but cannot be operated with close fist
Vestibule is 4 ft plus the width of the door swinging into the space	Yes	
Entrance(s) on a level that makes elevators accessible	N/A	
Door mats less than 1/2" thick are securely fastened	No	
Door mats more than 1/2" thick are recessed	No	
Grates in path of travel have openings of 1/4" maximum	N/A	
Signs at non-accessible entrance(s) indicate direction to accessible entrance	No	
Emergency egress – alarms with flashing lights and audible signals, sufficiently lighted	Yes	

Notes:

Stairs and Doors

YES

Doors

Description		Comments
Minimum 32" clear opening	Yes	
At least 18" clear floor space on pull side of door	Yes	
Threshold maximum 1/2" high, beveled on both sides	Yes	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)	No	
Hardware minimum 36", maximum 48" above the floor	Yes	
Clear, level floor space extends out 5 ft from both sides of the door	No	
Door adjacent to revolving door is accessible and unlocked	N/A	
Doors opening into hazardous area have hardware that is knurled or roughened	N/A	

Notes:

Restrooms

YES

Description		Comments
5 ft turning space measured 12" from the floor	Yes	

At least one Sink

Description		Comments
Clear floor space of 30" by 48" to allow a forward approach	Yes	
Mounted without pedestal or legs, height 34" to top of rim	No	33inches
Extends at least 22" from the wall	Yes	
Open knee space a minimum 19" deep, 30" width, and 27" high	Yes	
Cover exposed pipes with insulation	Yes	
Faucets operable with closed fist (lever or spring activated handle)	Yes	

At least one Stall

Description		Comments
Accessible to person using wheelchair at 60" wide by 72" deep	Yes	
Stall door is 36" wide	No	35in wide
Stall door swings out	Yes	
Stall door is self closing	No	
Stall door has a pull latch	No	
Lock on stall door is operable with a closed fist, and 32" above the floor	No	
Coat hook is 54" high	N/A	

Toilet

Description		Comments
18" from center to nearest side wall	Yes	
42" minimum clear space from center to farthest wall or fixture	Yes	
Top of seat 17"-19" above the floor	No	33 in high

Grab Bars

Description		Comments
On back and side wall closest to toilet	Yes	
1 1/2" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	Yes	
Acid-etched or roughened surface	Yes	
42" long	Yes	

Fixtures

Description		Comments
1 1/2" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	Yes	

Notes:

Floors, Drinking Fountains, Telephones

YES

Floors

Description		Comments
Non-slip surface	No	
Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored	N/A	
Corridor width minimum is 3 ft	Yes	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor	N/A	

Drinking Fountains

Description		Comments
Spouts no higher than 36" from floor to outlet	Yes	
Hand operated push button or level controls	Yes	
Spouts located near front with stream of water as parallel to front as possible	Yes	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain	Yes	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach	Yes	

Telephones

Description		Comments
Highest operating part a maximum 54" above the floor	No	
Access within 12" of phone, 30" high by 30" wide	No	
Adjustable volume control on headset so identified	No	

Notes:

Signs, Signals, and Switches

YES

Switches, Controls and Signs

Description		Comments
-------------	--	----------

Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach	No	50 inches high
Electrical outlets centered no lower than 18" above the floor	N/A	
Warning signals must be visual as well as audible	Yes	
Signs		
<i>Description</i>		<i>Comments</i>
Mounting height must be 60" to centerline of the sign	Yes	
Within 18" of door jamb or recessed	Yes	
Letters and numbers a t least 1/4" high	Yes	
Letters and numbers raised .03"	Yes	
Letters and numbers contrast with the background color	Yes	
Notes:		
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picknicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: Newton Centre Common/Green

Size (Ac): 2.0 acres

Address: Centre Street, Newton Centre, (divided by Langley Road)

Ward: 6

General Facility Notes: Accessible pathways and sidewalk; new benches (Total of 7) with companion pads (Total of 3) added along pathways in 2019.

Site Furnishings

		YES	
Description	Yes	Comments	
Tables & Benches			
Number of Benches	yes	13 total - 12 benches with backs and arm rests, 1 dumbor bench w/ gray slats and back, no arm rest	
Number of Tables	yes	2 picnic tables	
Located adjacent to accessible paths	yes		
Back and Arm Rests	yes	all have backs and arm rests	
Grills			
Located adjacent to accessible paths	no		
Trash Cans			
Located adjacent to accessible paths	yes	2 big belly trash bins and 2 big belly recycling units	
Picnic Shelters			
Located adjacent to accessible paths	yes	2 picnic tables	
Notes: There is a ww1, wwII and korean war monumnet w/ flagpole and kiosk. There is an irrigated (city water) award winning flower garden and an ornate flower pot (formerly this was a horse watering trough). There are 3 bike racks along with park lighting. There are 21 metered parking spaces abutting this location. There are no handicap accessible parking spaces.			

Trails & Paths

		YES	
Description	Yes	Comments	
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	yes	A, C	
Dimensions (width)	yes	varies - minimum is 7 feet	
Rails	No		
Signage for visually impaired	No		
Benches	yes	12 benches with backs and arm rests	
Notes:			

Play Areas

N/A

Game Areas

N/A

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Site Access			
Description	Yes	Comments	
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	yes	multiple access points	
Surface evenly paved or hard-packed	yes		
Ponding of water?	no		
Disembarking area at accessible entrance	yes		
Path of Travel			
Description	Yes	Comments	
Path does not require the use of stairs	yes		
Path does not require the use of wheelchair ramp	yes		
Path is stable, firm and slip resistant	yes		
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	yes		
Continuous common surface, no changes in level greater than 1/8 inch	yes		
Notes:			

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Newton Centre Playground

Size (Ac): 17.9 acres

Address: 81 Tyler Terrace, Newton Centre (contiguous to Mason Rice School)

Ward: 6

General Facility Notes: Master plan for accessibility in 2006; Olmsted-designed historic park; steeply sloped bowl shaped park; accessible pathway network; large, universal play equipment area in center of park with accessible route; accessible parking on Bowen St. and in Mason-Rice parking lot; formerly Brewer Playground.

Site Furnishings

		YES	
Description	Yes	Comments	
Tables & Benches			
Number of Benches	Yes	17	
Number of Tables	Yes	2	
Located adjacent to accessible paths	Yes	9 benches and both tables	
Back and Arm Rests	Yes	5 w/ back and arm and all others back only	
Grills			
Located adjacent to accessible paths	N/A		
Trash Cans			
Located adjacent to accessible paths	Yes		
Picnic Shelters			
Located adjacent to accessible paths	N/A		
Notes:			

Trails & Paths

		YES	
Description	Yes	Comments	
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	A	
Dimensions (width)	Yes	minimum 5'	
Rails	N/A		
Signage for visually impaired	No		
Benches	Yes	9 are accessible	
Notes:			

Play Areas

		YES	
Description	Yes	Comments	
Facility Type (3-5 Yrs,5-12 Yrs)	Yes	2 - 5 yrs and 5 - 12 yrs	
Same experience provided to all	Yes		
Access Routes			
Located adjacent to accessible paths	Yes		
Enough space between equipment for wheelchair	Yes		
Notes: Playground built in 2008			

Game Areas

		YES	
Description	Yes	Comments	
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Boce)	Yes	BF, BK and TN	
Access Routes			
Located adjacent to accessible paths	Yes		
Berm cuts onto courts	Yes		
Equipment			
Height			
Dimensions			
Spectator Seating			
Notes:			

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

		YES	
Description	Yes	Comments	
Parking Amenities (L=lot, ST=street)	Yes	ST no designated parking spot	
Accessible space located closest to accessible entrance	No		
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	No		
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	No		
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	No		
Sign with international symbol of accessibility at each space	No		
Sign 5'-8' to top of sign	No		
Surface evenly paved or hard-packed (no cracks)	No		
Surface slope less than 1:20, 5%	No		
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	No		
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	No		
Notes:			

Ramps

N/A

Site Access, Path of Travel, Entrances

		YES	
Site Access			
Description	Yes	Comments	
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	Yes		
Surface evenly paved or hard-packed	Yes		
Ponding of water?	No		
Disembarking area at accessible entrance	Yes		
Path of Travel			
Description	Yes	Comments	
Path does not require the use of stairs	Yes		
Path does not require the use of wheelchair ramp	Yes		
Path is stable, firm and slip resistant	Yes		

Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than 1/8 inch	Yes	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	Yes	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	Yes	
Curbs on the pathway must have curb cuts at drives, parking and drop-offs	N/A	

Entrances		
Description		Comments
Primary public entrances accessible to person using wheelchair, must be signed, gotten to independently, and not be the service entrance	No	
Level space extending 5 ft. from the door, interior and exterior of entrance doors	No	
Minimum 32" clear width opening (i.e. 36" door with standard hinge)	No	
At least 18" clear floor area on latch, pull side of door	No	
Door handle no higher than 48" and operable with a closed fist	No	
Vestibule is 4 ft plus the width of the door swinging into the space	No	
Entrance(s) on a level that makes elevators accessible	No	
Door mats less than 1/2" thick are securely fastened	No	
Door mats more than 1/2" thick are recessed	No	
Grates in path of travel have openings of 1/4" maximum	No	
Signs at non-accessible entrance(s) indicate direction to accessible entrance	No	
Emergency egress -- alarms with flashing lights and audible signals, sufficiently lighted	No	

Notes: building is not accessible at all

Stairs and Doors YES

Stairs		
Description		Comments
Open risers	No	
Nosings not projecting	Yes	
Treads no less than 11" wide	Yes	
Handrails on both sides	Yes	
Handrails 34" - 38" above tread	Yes	
Handrail extends a minimum of 1' beyond top and bottom riser (if no safety hazard and space permits)	No	
Handgrip oval or round	Yes	
Handgrip has a smooth surface	Yes	
Handgrip diam. 1 1/2" - 1 3/4"	Yes	
1 1/2" clearance between wall and handrail	Yes	

Doors		
Description		Comments
Minimum 32" clear opening	Yes	
At least 18" clear floor space on pull side of door	No	
Closing speed minimum 3 seconds to within 3" of the latch	No	
Maximum pressure 5 pounds interior doors	No	
Threshold maximum 1/2" high, beveled on both sides	Yes	
Hardware operable with a closed fist (no conventional door knobs or thumb latch devices)	No	
Hardware minimum 36", maximum 48" above the floor	Yes	
Clear, level floor space extends out 5 ft from both sides of the door	No	
Door adjacent to revolving door is accessible and unlocked	N/A	
Doors opening into hazardous area have hardware that is knurled or roughened	N/A	

Notes:

Restrooms YES

Restrooms		
Description		Comments
5 ft turning space measured 12" from the floor	No	
At least one Sink		
Description		Comments
Clear floor space of 30" by 48" to allow a forward approach	No	
Mounted without pedestal or legs, height 34" to top of rim	No	
Extends at least 22" from the wall	No	
Open knee space a minimum 19" deep, 30" width, and 27" high	No	
Cover exposed pipes with insulation	Yes	
Faucets operable with closed fist (lever or spring activated handle)	No	

At least one Stall		
Description		Comments
Accessible to person using wheelchair at 60" wide by 72" deep	No	
Stall door is 36" wide	No	
Stall door swings out	Yes	
Stall door is self closing	No	
Stall door has a pull latch	No	
Lock on stall door is operable with a closed fist, and 32" above the floor	No	
Coat hook is 54" high	N/A	

Toilet		
Description		Comments
18" from center to nearest side wall	No	
42" minimum clear space from center to farthest wall or fixture	No	
Top of seat 17" - 19" above the floor	Yes	

Grab Bars		
Description		Comments
On back and side wall closest to toilet	No	
1 1/2" diameter	No	
1 1/2" clearance to wall	No	
Located 30" above and parallel to the floor	No	
Acid-etched or roughened surface	No	
42" long	No	

Fixtures		
Description		Comments
1 1/2" diameter	Yes	
1 1/2" clearance to wall	No	
Located 30" above and parallel to the floor	Yes	

Notes:

Floors, Drinking Fountains, Telephones YES

Floors		
Description		Comments
Non-slip surface	Yes	

Carpeting is high-density, low pile, non-absorbent, stretched taut, securely anchored	Yes	
Corridor width minimum is 3 ft	Yes	
Objects (signs, ceiling lights, fixtures) can only protrude 4" into the path of travel from a height of 27" to 80" above the floor	No	
Drinking Fountains		
<i>Description</i>		<i>Comments</i>
Spouts no higher than 36" from floor to outlet	N/A	
Hand operated push button or level controls	N/A	
Spouts located near front with stream of water as parallel to front as possible	N/A	
If recessed, recess a minimum 30" width, and no deeper than depth of fountain	N/A	
If no clear knee space underneath, clear floor space 30" x 48" to allow parallel approach	N/A	
Telephones		
<i>Description</i>		<i>Comments</i>
Highest operating part a maximum 54" above the floor	N/A	
Access within 12" of phone, 30" high by 30" wide	N/A	
Adjustable volume control on headset so identified	N/A	
Notes:		
Signs, Signals, and Switches		
		YES
Switches, Controls and Signs		
<i>Description</i>		<i>Comments</i>
Switches and controls for light, heat, ventilation, windows, fire alarms, thermostats, etc, must be a minimum of 36" and a maximum of 48" above the floor for a forward reach, a maximum of 54" for a side reach	No	
Electrical outlets centered no lower than 18" above the floor	Yes	
Warning signals must be visual as well as audible	No	
Signs		
<i>Description</i>		<i>Comments</i>
Mounting height must be 60" to centerline of the sign	Yes	
Within 18" of door jamb or recessed	Yes	
Letters and numbers a t least 1/16" high	Yes	
Letters and numbers raised .03"	Yes	
Letters and numbers contrast with the background color	Yes	
Notes:		
Swimming Pool/ Lake beach		
		N/A
Shower Rooms		
		N/A
Picnicking		
		N/A
Off Leash Dog Areas (OLA)		
		YES
<i>Description</i>		<i>Comments</i>
Access Routes		
Located adjacent to accessible paths	Yes	
Area accessible	No	
Notes:		

Facility Name: Newton Highlands Playground

Size (Ac): 12.6 acres

Address: Winchester St., Newton Highlands

Ward: 5

General Facility Notes: Large park renovated in 2018/2019; fully accessible; includes accessible trail and path network throughout and into the wooded section of the park; accessible parking lot.

Site Furnishings

YES

Description	Yes	Comments
Tables & Benches		
Number of Benches	YES	19 Benches
Number of Tables	YES	3 Tables; one is ADA compliant
Located adjacent to accessible paths	YES	All benches and tables are along an accessible path
Back and Arm Rests		All benches have back and arm rests
Trash Cans		
Located adjacent to accessible paths	YES	

Notes:

Trails & Paths

YES

Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	YES	A; SD
Dimensions (width)		6 feet minimum
Rails	NO	
Signage for visually impaired	NO	

Notes:

Play Areas

YES

Description	Yes	Comments
Facility Type (3-5 Yrs, 5-12 Yrs)	YES	3-5 Yrs; 5-12 Yrs
Same experience provided to all	YES	
Access Routes		
Located adjacent to accessible paths	YES	
Enough space between equipment for wheelchair	YES	

Notes:

Game Areas

YES

Description	Yes	Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC= Bocce)	YES	1 RF; 1 BF; 1 BK; 2 TN
Access Routes		
Located adjacent to accessible paths	YES	
Berm cuts onto courts	YES	

Notes:

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

YES

Total Spaces	Required Accessible Spaces
27	2 Space
Description	
Parking Amenities (L=lot, ST=street)	YES L
Accessible space located closest to accessible entrance	YES
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	YES
Minimum of 1 van space for every accessible space, 8' wide x 8' aisle.	YES
Sign with international symbol of accessibility at each space	YES
Surface evenly paved or hard-packed (no cracks)	YES
Surface slope less than 1:20, 5%	YES
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present.	YES
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	YES

Notes:

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Site Access		
Description	Yes	Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	YES	
Surface evenly paved or hard-packed	YES	
Ponding of water?	NO	
Disembarking area at accessible entrance	YES	

Path of Travel

Description	Yes	Comments
Path does not require the use of stairs	NO	Winchester street entrance can be accessed by stairs or sloped path
Path does not require the use of wheelchair ramp	YES	
Path is stable, firm and slip resistant	YES	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	YES	
Continuous common surface, no changes in level greater than 1/4 inch	YES	
Any objects protruding onto the pathway that may not be detected by a person with a visual disability using a cane	NO	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	NO	

Notes:

Stairs and Doors		YES
Stairs		
<i>Description</i>		<i>Comments</i>
Open risers	NO	Concrete stairs
Nosings not projecting	YES	
Treads no less than 11" wide	YES	
Handrails on both sides	YES	
Handrails 34"-38" above tread	YES	
Handrail extends a minimum of 1' beyond top and bottom riser (if no safety hazard and space permits)	YES	
Handgrip oval or round	YES	Round stainless steel tube
Handgrip has a smooth surface	YES	
Notes:		
Restrooms	N/A	
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picknicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: Newton South High School Winkler Stadium

Size (Ac): 7.0 acres

Address: 140 Brandeis Road, Newton Centre (contiguous to Oak Hill Middle School playfields)

Ward: 8

General Facility Notes: Accessible pathways to ballfields, football field, fieldhouse and track; Lift to bleachers; facility opened fall 2009.

Site Furnishings

YES

Description	Yes	Comments
Tables & Benches		
Number of Benches	YES	Spectator Stands
Number of Tables	No	
Located adjacent to accessible paths	YES	
Back and Arm Rests	No	
Grills		
Located adjacent to accessible paths	No	
Trash Cans		
Located adjacent to accessible paths	YES	
Picnic Shelters		
Located adjacent to accessible paths	No	

Notes:

Trails & Paths

YES

Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	YES	A
Dimensions (width)		8 FT
Rails	No	
Signage for visually impaired	No	

Notes:

Play Areas

N/A

Game Areas

YES

Description	Yes	Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Bocece)		BF RF ,Shot Put ,Track
Access Routes		
Located adjacent to accessible paths	No	
Berm cuts onto courts	NA	
Equipment		
Spectator Seating	Yes	Stadium grand stand is accessible

Notes:

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

YES

Total Spaces	Accessible Spaces	
151-200	6 Space	
Description		
Parking Amenities (L=lot, ST=street)	YES	L
Accessible space located closest to accessible entrance	YES	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	YES	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	YES	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	YES	
Sign with international symbol of accessibility at each space	YES	
Sign 5'-8" to top of sign	YES	
Surface evenly paved or hard-packed (no cracks)	YES	
Surface slope less than 1:20, 5%	YES	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	YES	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	YES	

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Description	Yes	Comments
Site Access		
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	YES	
Surface evenly paved or hard-packed	YES	
Ponding of water?	No	
Disembarking area at accessible entrance	YES	
Path of Travel		
Description		
Path does not require the use of stairs	YES	
Path does not require the use of wheelchair ramp	YES	
Path is stable, firm and slip resistant	YES	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	YES	
Continuous common surface, no changes in level greater than 1/8 inch	YES	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	No	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	No	
Curb on the pathway must have curb cuts at drives,parking and drop-offs	YES	

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones	N/A
Signs, Signals, and Switches	N/A
Swimming Pool/ Lake beach	N/A
Shower Rooms	N/A
Picnicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Newton Veterans Memorial Park

Size (Ac): 0.1 acres

Address: Washington Street, opposite Newton History Museum, Newton Corner

Ward: 1

General Facility Notes: Small memorial park area alongside Washington St.; sidewalk; benches and one short pathway to memorial markers.

Site Furnishings

YES

Description	Yes	Comments
Tables & Benches		
Number of Benches	6	
Number of Tables	No	
Located adjacent to accessible paths	No	
Back and Arm Rests	2	
Grills		
Located adjacent to accessible paths	No	
Trash Cans		
Located adjacent to accessible paths	No	
Picnic Shelters		
Located adjacent to accessible paths	No	

Notes:

Trails & Paths

YES

Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	A & C	
Dimensions (width)	4'	
Rails	No	
Signage for visually impaired	No	
Benches	No	

Notes:

Play Areas

N/A

Game Areas

N/A

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Site Access		
Description	Yes	Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	No	
Surface evenly paved or hard-packed	YES	
Ponding of water?	No	
Disembarking area at accessible entrance	No	
Path of Travel		
Description	Yes	Comments
Path does not require the use of stairs	YES	
Path does not require the use of wheelchair ramp	YES	
Path is stable, firm and slip resistant	YES	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	YES	
Continuous common surface, no changes in level greater than 1/8 inch	YES	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	No	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	No	
Curb on the pathway must have curb cuts at drives, parking and drop-offs	YES	

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Richard J. Forte Memorial Park 'Allison Park'

Size (Ac): 6.0 acres

Address: 235 rear California Street

Ward: 1

General Facility Notes: Accessible route connecting exercise equipment stations, bocce courts, bb court & tot lot; accessible parking; accessible route abuts but does not connect to adjacent DCR Charles River Reservation multiuse path.

Site Furnishings

YES

Description		Comments
Tables & Benches		
Number of Benches	Yes	8
Number of Tables	No	
Located adjacent to accessible paths	Yes	
Back and Arm Rests	Yes	
Grills		
Located adjacent to accessible paths	No	
Trash Cans		
Located adjacent to accessible paths	Yes	
Picnic Shelters		
Located adjacent to accessible paths	NA	

Notes:

Trails & Paths

YES

Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	A, C, SD
Dimensions (width)		
Rails	No	
Signage for visually impaired	No	
Benches	No	

Notes:

Play Areas

YES

Description		Comments
Facility Type (3-5 Yrs, 5-12 Yrs)	Yes	3-5 Yrs
Same experience provided to all	Yes	
Access Routes		
Located adjacent to accessible paths	Yes	
Enough space between equipment for wheelchair	Yes	

Notes:

Game Areas

YES

Description		Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Bocce)	Yes	RF, BF, BK, BC
Access Routes		
Located adjacent to accessible paths	Yes	
Berm cuts onto courts	NA	
Equipment		
Spectator Seating	Yes	

Notes:

Parking

YES

Total Spaces	Accessible Spaces	
42	2 Space	
Description		
Parking Amenities (L=lot, ST=street)	Yes	Lot
Accessible space located closest to accessible entrance	Yes	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	NA	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	Yes	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	No	
Sign with international symbol of accessibility at each space	Yes	
Surface evenly paved or hard-packed (no cracks)	Yes	
Surface slope less than 1:20, 5%	Yes	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	Yes	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	Yes	

Notes:

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Description		Comments
Site Access		
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	Yes	
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Disembarking area at accessible entrance	Yes	
Path of Travel		
Description		
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than ¼ inch	Yes	

Notes:

Stairs and Doors	N/A	
Restrooms	YES	
<i>Description</i>		<i>Comments</i>
5 ft turning space measured 12" from the floor	Yes	
At least one Sink		
<i>Description</i>		<i>Comments</i>
Clear floor space of 30" by 48" to allow a forward approach	Yes	
Mounted without pedestal or legs, height 34" to top of rim	Yes	
Extends at least 22" from the wall	Yes	
Open knee space a minimum 19" deep, 30" width, and 27" high	Yes	
Cover exposed pipes with insulation	No	
Faucets operable with closed fist (lever or spring activated handle)	Yes	
At least one Stall		
<i>Description</i>		<i>Comments</i>
Accessible to person using wheelchair at 60" wideby 72" deep	Yes	
Stall door is 36" wide	Yes	
Stall door swings out	Yes	
Stall door is self closing	No	
Stall door has a pull latch	Yes	
Lock on stall door is operable with a closed fist, and 32" above the floor	Yes	34in
Coat hook is 54" high	No	
Toilet		
<i>Description</i>		<i>Comments</i>
18" from center to nearest side wall	Yes	
42" minimum clear space from center to farthest wall or fixture	Yes	
Top of seat 17"-19" above the floor	Yes	
Grab Bars		
<i>Description</i>		<i>Comments</i>
On back and side wall closest to toilet	Yes	
1 1/2" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	Yes	
Acid-etched or roughened surface	Yes	
42" long	Yes	
Fixtures		
<i>Description</i>		<i>Comments</i>
1 1/2" diameter	Yes	
1 1/2" clearance to wall	Yes	
Located 30" above and parallel to the floor	No	33in
Notes:		
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picnicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: Richard J. McGrath Park

Size (Ac): 10.1 acres

Address: 1600 Washington Street, West Newton (behind Warren Apartments)

Ward: 3

General Facility Notes: No accessible route from parking lot to soccer fields, ballfields and one set of tennis courts (east side); tennis court and off-leash dog area (west side of the park) renovation completed in 2018 with accessible route from Washington St. and the parking lot; formerly Warren Jr. High Playground.

Site Furnishings		YES
Description		Comments
Tables & Benches		
Number of Benches	YES	3 wpa benches
Number of Tables	YES	1 picnic
Located adjacent to accessible paths	No	
Back and Arm Rests	YES	
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	No	
Picnic Shelters		
Located adjacent to accessible paths	No	
Notes:		

Trails & Paths		YES
Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	yes	A Leading to tennis courts on the west end of the park
Dimensions (width)	YES	5 ft
Rails	No	
Signage for visually impaired	No	
Benches	No	
Notes:		

Play Areas		N/A
Game Areas		YES
Description		Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Bocce)	Yes	RF, 2 BF, 7 TN
Access Routes		
Located adjacent to accessible paths	NO	One of the two tennis court banks are along accessible path
Berm cuts onto courts	Yes	
Equipment		
Spectator Seating	Yes	
Notes:		

Boat Docks		N/A
Fishing Facilities		N/A
Community Gardens		N/A
Parking		YES
Total Spaces	Required Accessible Spaces	
59	3 Space	
Description		Comments
Parking Amenities (L=lot, ST=street)	YES	L
Accessible space located closest to accessible entrance	YES	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	NA	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	Yes	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	NO	
Sign with international symbol of accessibility at each space	Yes	
Surface evenly paved or hard-packed (no cracks)	Yes	
Surface slope less than 1:20, 5%	Yes	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	NA	
Notes:		

Ramps		N/A
Site Access, Path of Travel, Entrances		YES
Site Access		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	Yes	
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Disembarking area at accessible entrance	Yes	
Path of Travel		
Description		Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than 1/8 inch	Yes	
Notes:		

Stairs and Doors	N/A
Restrooms	N/A
Floors, Drinking Fountains, Telephones	N/A
Signs, Signals, and Switches	N/A
Swimming Pool/ Lake beach	N/A
Shower Rooms	N/A

Picknicking	N/A	
Off Leash Dog Areas (OLA)	YES	
<i>Description</i>	Yes	<i>Comments</i>
Access Routes		
Located adjacent to accessible paths	YES	
Area accessible	YES	
Notes:		

Facility Name: Richardson Playground

Size (Ac): 5.4 acres

Address: Allen Avenue, Waban

Ward: 5

General Facility Notes: Inaccessible little league field; no accessible paths; inaccessible tot lot near Beethoven.

Site Furnishings

YES

Description		Comments
Tables & Benches		
Number of Benches	yes	6 dumbor benches
Number of Tables	yes	1 picnic table
Located adjacent to accessible paths	no	
Back and Arm Rests	yes	3 benches with backs and no arm rests, 3 benches with no backs and no arm rests
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	no	1 big belly trash bin and 1 big belly recycling unit
Picnic Shelters		
Located adjacent to accessible paths	NA	

Notes: There is one bike rack, one spectator bleacher stand.

Trails & Paths

YES

Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	yes	A
Dimensions (width)	yes	Four foot wide non-continuous path.
Rails	No	
Signage for visually impaired	No	
Benches	yes	There are 3 dumbor gray slat benches with backs, There are 3 dumbor gray slat benches with NO backs

Notes:

Play Areas

YES

Description		Comments
Facility Type (3-5 Yrs,5-12 Yrs)	yes	Fibar safety surfacing.
Same experience provided to all	yes	
Access Routes		
Located adjacent to accessible paths	No	
Enough space between equipment for wheelchair	yes	

Notes: Athletic areas are irrigated with city water.

Game Areas

YES

Description		Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC= Bocce)	yes	1 BF (irrigated enclosed little league field w/ scoreboard, practice area, backstop, benches, protective screens, and shed), 1 RF - irrigated
Access Routes		
Located adjacent to accessible paths	no	
Berm cuts onto courts	no	
Equipment		
Spectator Seating	yes	

Notes:

Boat Docks	N/A
Fishing Facilities	N/A
Community Gardens	N/A
Parking	N/A
Ramps	N/A
Site Access, Path of Travel, Entrances	N/A
Stairs and Doors	N/A
Restrooms	N/A
Floors, Drinking Fountains, Telephones	N/A
Signs, Signals, and Switches	N/A
Swimming Pool/ Lake beach	N/A
Shower Rooms	N/A
Picknicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: River Street Playground

Size (Ac): .5 acres

Address: River St., West Newton

Ward: 3

General Facility Notes: Inaccessible play equipment area with sand safety surface; accessible pathway with bench and companion pad from entrance.

Site Furnishings

YES

Description	Yes	Comments
Tables & Benches		
Number of Benches	Yes	3
Number of Tables	No	
Located adjacent to accessible paths	Yes	1 bench
Back and Arm Rests	Yes	back rest only

Grills

Located adjacent to accessible paths	N/A	
--------------------------------------	-----	--

Trash Cans

Located adjacent to accessible paths	Yes	
--------------------------------------	-----	--

Picnic Shelters

Located adjacent to accessible paths	N/A	
--------------------------------------	-----	--

Notes:

Trails & Paths

YES

Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	A
Dimensions (width)	Yes	Minimum 5'
Rails	N/A	
Signage for visually impaired	No	

Notes:

Play Areas

YES

Description	Yes	Comments
Facility Type (3-5 Yrs,5-12 Yrs)	Yes	5 - 12 yrs
Same experience provided to all	No	

Access Routes

Located adjacent to accessible paths	Yes	
Enough space between equipment for wheelchair	Yes	

Notes: Playground built in 1990

Game Areas

N/A

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Site Access

Description	Yes	Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	Yes	
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Disembarking area at accessible entrance	Yes	

Path of Travel

Description	Yes	Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than 1/8 inch	Yes	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	Yes	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	N/A	
Curb on the pathway must have curb cuts at drives, parking and drop-offs	N/A	

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picknicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: Solomon Schecter 'Memorial' Playground		
Size (Ac): 3.9 acres		
Address: Stein Circle, Oak Hill		
Ward: 8		
General Facility Notes: No pathways to play equipment; formerly Memorial/Solomon Schecter School		
Site Furnishings		
Description		YES
		Yes
		Comments
Tables & Benches		
Number of Benches		YES
Number of Tables		yes
Located adjacent to accessible paths		YES
Back and Arm Rests		
		7 Benches
		2 Tables
		path from neighborhoods to benches
Grills		
Located adjacent to accessible paths		No
Trash Cans		
Located adjacent to accessible paths		No
Picnic Shelters		
Located adjacent to accessible paths		No
Notes:		
Trails & Paths		
Description		YES
		Yes
		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)		C
Dimensions (width)		5"
Rails		No
Signage for visually impaired		No
Benches		No
Notes:		
Play Areas		
Description		YES
		Yes
		Comments
Facility Type (3-5 Yrs,5-12 Yrs)		
Same experience provided to all		YES
Access Routes		
Located adjacent to accessible paths		No
Enough space between equipment for wheelchair		No
Notes:		
Game Areas		
Description		YES
		Yes
		Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Boce)		RF, BF, TN
Access Routes		
Located adjacent to accessible paths		No
Berm cuts onto courts		No
Equipment		
Spectator Seating		No
Notes:		
Boat Docks		
N/A		
Fishing Facilities		
N/A		
Community Gardens		
N/A		
Parking		
N/A		
Ramps		
N/A		
Site Access, Path of Travel, Entrances		
N/A		
Notes:		
Stairs and Doors		
N/A		
Restrooms		
N/A		
Floors, Drinking Fountains, Telephones		
N/A		
Signs, Signals, and Switches		
N/A		
Swimming Pool/ Lake beach		
N/A		
Shower Rooms		
N/A		
Picnicking		
N/A		
Off Leash Dog Areas (OLA)		
N/A		

Facility Name: Spears Park	
Size (Ac): .25 acres	
Address: Corner of Washington Street and Walnut Park, Nonantum	
Ward: 1	
<u>General Facility Notes:</u> Open lawn on corner lot with no pathways; no amenities. Potential location for pocket park or community garden. Level lawn with very little topographical change.	
Site Furnishings	N/A
Trails & Paths	N/A
Play Areas	N/A
Game Areas	N/A
Boat Docks	N/A
Fishing Facilities	N/A
Community Gardens	N/A
Parking	N/A
Ramps	N/A
Site Access, Path of Travel, Entrances	N/A
Stairs and Doors	N/A
Restrooms	N/A
Floors, Drinking Fountains, Telephones	N/A
Signs, Signals, and Switches	N/A
Swimming Pool/ Lake beach	N/A
Shower Rooms	N/A
Picnicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Stearns Park		
Size (Ac): 3.4 acres		
Address: Jassett Street, Nonantum		
Ward: 1		
General Facility Notes: 2006 master plan; phase 1: accessible tennis courts with ramp to adjacent housing project; accessible playground and half-court area on Jasset St constructed in 2011; accessible route from the street to play structure and courts; park is sloped and not all pathways are accessible.		
Site Furnishings		
Description		YES
		<i>Comments</i>
Tables & Benches		
Number of Benches	Yes	15
Number of Tables	Yes	4
Located adjacent to accessible paths	Yes	8 benches and 2 tables
Back and Arm Rests	Yes	
Grills		
Located adjacent to accessible paths	N/A	
Trash Cans		
Located adjacent to accessible paths	Yes	
Picnic Shelters		
Located adjacent to accessible paths	N/A	
Notes:		
Trails & Paths		
Description		YES
		<i>Comments</i>
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	Yes	A
Dimensions (width)	Yes	5'
Rails	No	
Signage for visually impaired	No	
Benches	Yes	see above
Notes:		
Play Areas		
Description		YES
		<i>Comments</i>
Facility Type (3-5 Yrs,5-12 Yrs)	Yes	2-5 yrs and 5 - 12 yrs
Same experience provided to all	Yes	
Access Routes		
Located adjacent to accessible paths	Yes	
Enough space between equipment for wheelchair	Yes	
Notes: Playground built in 2011		
Game Areas		
Description		YES
		<i>Comments</i>
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Boerce)	Yes	BF, BK and TN
Access Routes		
Located adjacent to accessible paths	Yes	
Berm cuts onto courts	Yes	
Equipment		
Spectator Seating	No	
Notes:		
Boat Docks		
N/A		
Fishing Facilities		
N/A		
Community Gardens		
N/A		
Parking		
Description		YES
		<i>Comments</i>
Parking Amenities (L=lot, ST=street)	Yes	ST
Accessible space located closest to accessible entrance	N/A	No designated accessible space
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	N/A	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	N/A	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	N/A	
Sign with international symbol of accessibility at each space	N/A	
Sign 5'-8' to top of sign	N/A	
Surface evenly paved or hard-packed (no cracks)	Yes	
Surface slope less than 1:20, 5%	Yes	
Curbscut to pathway from parking lot at each space if sidewalk (curb) is present.	N/A	
Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	N/A	
Notes:		
Ramps		
N/A		
Site Access, Path of Travel, Entrances		
YES		
Site Access		
Description		<i>Comments</i>
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	Yes	
Surface evenly paved or hard-packed	Yes	
Ponding of water?	No	
Disembarking area at accessible entrance	No	
Path of Travel		
Description		<i>Comments</i>
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	No	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	In most areas
Continuous common surface, no changes in level greater than 1/8 inch	Yes	

Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	Yes	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	N/A	
Curb on the pathway must have curb cuts at drives, parking and drop-offs	N/A	
Notes:		
Stairs and Doors	N/A	
Restrooms	N/A	
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picnicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: The Reverend Louis E. Ford Playground 'Curve Street Playground'		
Size (Ac): 2.0 acres		
Address: Behind Baptist Church on Curve Street, West Newton		
Ward: 4		
General Facility Notes: inaccessible playground area; park expansion and renovation with all accessible amenities planned.		
Site Furnishings		
Description		YES
		Yes Comments
Tables & Benches		
Number of Benches	yes	2 benches with backs and no arm rests
Number of Tables	yes	1 picnic table
Located adjacent to accessible paths	no	
Back and Arm Rests	yes	2 benches with backs and no arm rests
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	yes	
Picnic Shelters		
Located adjacent to accessible paths	NA	
Notes:		
Trails & Paths		
		N/A
Play Areas		
Description		YES
		Yes Comments
Facility Type (3-5 Yrs,5-12 Yrs)	yes	Fibar safety surfacing.
Same experience provided to all	yes	
Access Routes		
Located adjacent to accessible paths	no	There are no paths at this location.
Enough space between equipment for wheelchair	yes	
Notes:		
Game Areas		
		N/A
Boat Docks		
		N/A
Fishing Facilities		
		N/A
Community Gardens		
		N/A
Parking		
		N/A
Ramps		
		N/A
Site Access, Path of Travel, Entrances		
		N/A
Stairs and Doors		
		N/A
Restrooms		
		N/A
Floors, Drinking Fountains, Telephones		
		N/A
Signs, Signals, and Switches		
		N/A
Swimming Pool/ Lake beach		
		N/A
Shower Rooms		
		N/A
Picnicking		
		N/A
Off Leash Dog Areas (OLA)		
		N/A

Facility Name: Thompsonville-Bowen Playground - DOES NOT INCLUDE SCHOOL

Size (Ac): 8.8 acres

Address: Langley Path and Cypress Street, Thompsonville (adjacent to Bowen School)

Ward: 6

General Facility Notes: No accessible route to ballfields; steep pathway from Langley Path down to adjoining Bowen School; no designated accessible parking on Langley Path; new accessible playground in Bowen schoolyard.

Site Furnishings		YES
Description	Yes	Comments
Tables & Benches		
Number of Benches	Yes	2
Number of Tables	no	
Located adjacent to accessible paths	no	
Back and Arm Rests	no	
Grills		
Located adjacent to accessible paths	NA	
Trash Cans		
Located adjacent to accessible paths	yes	1 big belly trash bin and 1 big belly recycling unit, located off asphalt drive
Picnic Shelters		
Located adjacent to accessible paths	no	
Notes:		
Trails & Paths		
Description	YES	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	yes	A, non-accessible pathway from cul de sac to school
Dimensions (width)	yes	Ten feet wide
Rails	No	
Signage for visually impaired	No	
Notes:		
Play Areas		
Description	YES	Comments
Facility Type (3-5 Yrs,5-12 Yrs)	no	
Same experience provided to all	No	
Access Routes		
Located adjacent to accessible paths	no	
Enough space between equipment for wheelchair	no	
Notes:		
Game Areas		
Description	YES	Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Bocce)	yes	1 RF, 2 BF with backstops, players benches, protective screens and one shed, 1 Basketball Standard
Access Routes		
Located adjacent to accessible paths	no	
Berm cuts onto courts	no	
Equipment		
Spectator Seating	No	
Notes: Athletic field is irrigated with well water.		
Boat Docks	N/A	
Fishing Facilities	N/A	
Community Gardens	N/A	
Parking	N/A	
Ramps	N/A	
Site Access, Path of Travel, Entrances	N/A	
Stairs and Doors	N/A	
Restrooms	N/A	
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picnicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: Upper Falls Greenway

Size (Mi): 1.0 mile

Address: Easy St. to Oak St., Upper Falls

Ward: 5

General Facility Notes: 1 Miles accessible stone dust rail trail with accessible parkingon-street on Oak Street; accessible entrance from Oak Street.

Site Furnishings

YES

Table with columns: Description, YES, Comments. Rows include Tables & Benches (Number of Benches: Yes, 2; Number of Tables: NO; Located adjacent to accessible paths: Yes; Back and Arm Rests: Yes, Back rests only), Grills (Located adjacent to accessible paths: NA), Trash Cans (Located adjacent to accessible paths: Yes), Picnic Shelters (Located adjacent to accessible paths: NA).

Notes:

Trails & Paths

YES

Table with columns: Description, YES, Comments. Rows include Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge): Yes, C, SD; Dimensions (width): 6 ft min.; Rails: No; Signage for visually impaired: No.

Notes:

Play Areas

N/A

Game Areas

YES

Table with columns: Description, YES, Comments. Rows include Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Bocce): Yes, BC; Access Routes (Located adjacent to accessible paths: Yes; Berm cuts onto courts: No); Equipment (Spectator Seating: No).

Notes:

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

YES

Table with columns: Description, Accessible Spaces, Comments. Rows include Total Spaces: 27; Accessible Spaces: 2 Spaces; Description (Parking Amenities (L=lot, ST=street): Yes, ST; Accessible space located closest to accessible entrance: Yes; Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft: NA; Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle: Yes; Minimum of 1 van space for every accessible space, 8' wide + 8' aisle: No; Sign with international symbol of accessibility at each space: Yes; Surface evenly paved or hard-packed (no cracks): Yes; Surface slope less than 1:20, 5%: Yes; Curbscut to pathway from parking lot at each space if sidewalk (curb) is present.: No, Shared curb cut; Curbscut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow: Yes).

Notes:

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Table with columns: Description, YES, Comments. Rows include Site Access (Accessible path of travel from passenger disembarking area and parking area to accessible entrance: Yes; Surface evenly paved or hard-packed: Yes; Ponding of water?: No; Disembarking area at accessible entrance: Yes); Path of Travel (Path does not require the use of stairs: Yes; Path does not require the use of wheelchair ramp: Yes; Path is stable, firm and slip resistant: Yes; Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50): Yes; Continuous common surface, no changes in level greater than 1/8 inch: Yes).

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picknicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Ward Park		
Size (Ac): 3.5 acres		
Address: Montrose Street, Newton Centre		
Ward: 7		
General Facility Notes: ballfield and soccer field not accessible; contiguous to Ward School Playground.		
Site Furnishings YES		
Description		Comments
Tables & Benches		
Number of Benches	No	
Number of Tables	No	
Located adjacent to accessible paths	No	
Back and Arm Rests	No	
B		
Located adjacent to accessible paths	No	
Trash Cans		
Located adjacent to accessible paths	YES	
Picnic Shelters		
Located adjacent to accessible paths	No	
Notes:		
Trails & Paths YES		
Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	YES	A- From Lorna RD To School
Dimensions (width)	Yes	8ft
Rails	No	
Signage for visually impaired	No	
Notes:		
Play Areas N/A		
Game Areas YES		
Description		Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Boce)	Yes	BF BK RF, TN
Access Routes		
Located adjacent to accessible paths	YES	Access to RF
Berm cuts onto courts	No	Courts are not accessible
Equipment		
Spectator Seating	Yes	
Notes:		
Boat Docks N/A		
Fishing Facilities N/A		
Community Gardens N/A		
Parking YES		
Total Spaces	55	Accessible Spaces
		0
Description		Comments
Parking Amenities (L=lot, ST=street)	YES	ST, L School lot
Accessible space located closest to accessible entrance	NA	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	NA	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	NA	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	NA	
Sign with international symbol of accessibility at each space	NA	
Surface evenly paved or hard-packed (no cracks)	Yes	
Surface slope less than 1:20, 5%	Yes	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present.	NA	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	NA	
Notes:		
Ramps N/A		
Site Access, Path of Travel, Entrances YES		
Site Access		
Description		Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	Yes	
Surface evenly paved or hard-packed	Yes	
Ponding of water?	Yes	
Disembarking area at accessible entrance	Yes	
Path of Travel		
Description		Comments
Path does not require the use of stairs	Yes	
Path does not require the use of wheelchair ramp	Yes	
Path is stable, firm and slip resistant	Yes	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	Yes	
Continuous common surface, no changes in level greater than 1/8 inch	Yes	
Notes:		
Stairs and Doors N/A		
Restrooms N/A		
Floors, Drinking Fountains, Telephones N/A		
Signs, Signals, and Switches N/A		
Swimming Pool/ Lake beach N/A		
Shower Rooms N/A		

Picknicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Washington Park

Size (Ac): 1.0 acres

Address: Washington Park, Newtonville

Ward: 2

General Facility Notes: Historic park; large, rectangular traffic island; trees and lawn only; no pathways; benches are not accessible.

Site Furnishings	N/A
Trails & Paths	N/A
Play Areas	N/A
Game Areas	N/A
Boat Docks	N/A
Fishing Facilities	N/A
Community Gardens	N/A
Parking	N/A
Ramps	N/A
Site Access, Path of Travel, Entrances	N/A
Stairs and Doors	N/A
Restrooms	N/A
Floors, Drinking Fountains, Telephones	N/A
Signs, Signals, and Switches	N/A
Swimming Pool/ Lake beach	N/A
Shower Rooms	N/A
Picnicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Webster Park	
Size (Ac): 1.0 acres	
Address: End of Warren Street, Newton Centre (adjoins Webster Conservation Area)	
Ward: 7	
<u>General Facility Notes:</u> Oval level lawn area surrounded by woods; no pathways; little parking with no accessible parking space; adjoins Webster Conservation Area.	
Site Furnishings	N/A
Trails & Paths	N/A
Play Areas	N/A
Game Areas	N/A
Boat Docks	N/A
Fishing Facilities	N/A
Community Gardens	N/A
Parking	N/A
Ramps	N/A
Site Access, Path of Travel, Entrances	N/A
Stairs and Doors	N/A
Restrooms	N/A
Floors, Drinking Fountains, Telephones	N/A
Signs, Signals, and Switches	N/A
Swimming Pool/ Lake beach	N/A
Shower Rooms	N/A
Picnicking	N/A
Off Leash Dog Areas (OLA)	N/A

Facility Name: Weeks Park		
Size (Ac): 11.1 acres		
Address: Hereward Rd. or Paul St. or Cedric St., Newton Centre (adjacent to Weeks Housing),		
Ward: 6		
<u>General Facility Notes:</u> Soccer fields, ballfields, and bermed passive area in the middle not accessible; accessible route from parking lot to tot lot constructed in 2020.		
Site Furnishings YES		
Description	Yes	Comments
Tables & Benches		
Number of Benches	YES	9
Number of Tables	YES	1 in middle area seats 4
Located adjacent to accessible paths	No	
Back and Arm Rests	YES	
Grills		
Located adjacent to accessible paths	No	
Trash Cans		
Located adjacent to accessible paths	YES	
Picnic Shelters		
Located adjacent to accessible paths	No	
Notes:		
Trails & Paths YES		
Description	Yes	Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)		A to playground area
Dimensions (width)		4 ft min
Rails	No	
Signage for visually impaired	No	
Benches	No	
Notes:		
Play Areas YES		
Description	Yes	Comments
Facility Type (3-5 Yrs,5-12 Yrs)	YES	3-5 yrs
Same experience provided to all	YES	
Access Routes		
Located adjacent to accessible paths	YES	
Enough space between equipment for wheelchair	YES	
Notes:		
Game Areas YES		
Description	Yes	Comments
Facility Type (RF=Rectangular Fields, BF= Ballfields, BK=Basketball, TN=Tennis, BC=Boce)	YES	RF, TN
Access Routes		
Located adjacent to accessible paths	no	Path leads to playground only
Berm cuts onto courts	No	
Equipment		
Spectator Seating	No	
Notes:		
Boat Docks N/A		
Fishing Facilities N/A		
Community Gardens N/A		
Parking YES		
Total Spaces	Required Accessible Spaces	
	10	1 Space
Description	Yes	Comments
Parking Amenities (L=lot, ST=street)	YES	Lot
Accessible space located closest to accessible entrance	NO	
Where spaces cannot be located within 200 ft of accessible entrance, drop-off area is provided within 100 ft	NA	
Minimum width of 13 ft includes 8 ft space plus 5 ft access aisle	Yes	
Minimum of 1 van space for every accessible space, 8' wide + 8' aisle.	No	
Sign with international symbol of accessibility at each space	No	
Surface evenly paved or hard-packed (no cracks)	Yes	
Surface slope less than 1:20, 5%	Yes	
Curbcut to pathway from parking lot at each space if sidewalk (curb) is present .	Yes	
Curbcut is a minimum width of 3 ft, excluding sloped sides, has sloped sides, all slopes not to exceed 1:12, and textured or painted yellow	Yes	
Notes: Parking spaces need restriping		
Ramps N/A		
Site Access, Path of Travel, Entrances YES		
Site Access		
Description	Yes	Comments
Accessible path of travel from passenger disembarking area and parking area to accessible entrance	YES	
Surface evenly paved or hard-packed	YES	
Ponding of water?	No	
Disembarking area at accessible entrance	YES	
Path of Travel		
Description	Yes	Comments
Path does not require the use of stairs	YES	
Path does not require the use of wheelchair ramp	YES	
Path is stable, firm and slip resistant	YES	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	YES	

Continuous common surface, no changes in level greater than 1/8 inch	YES	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane	No	
Objects protruding more than 4" from the wall must be within 27" of the ground, or higher than 80"	No	
Curb on the pathway must have curb cuts at drives, parking and drop-offs	YES	
Notes:		
Stairs and Doors	N/A	
Restrooms	N/A	
Floors, Drinking Fountains, Telephones	N/A	
Signs, Signals, and Switches	N/A	
Swimming Pool/ Lake beach	N/A	
Shower Rooms	N/A	
Picnicking	N/A	
Off Leash Dog Areas (OLA)	N/A	

Facility Name: Wellington Playground

Size (Ac): 1.9 acres

Address: Kilburn Road, West Newton

Ward: 3

General Facility Notes: Accessible pathways connecting two of the three entrances to the tot lot; one entrance on Kilburn St. not accessible; play equipment area accessible.

Site Furnishings

YES

Table with 3 columns: Description, YES/NO, Comments. Sub-sections: Tables & Benches, Grills, Trash Cans, Picnic Shelters.

Notes:

Trails & Paths

YES

Table with 3 columns: Description, YES/NO, Comments. Sub-section: Description.

Notes:

Play Areas

YES

Table with 3 columns: Description, YES/NO, Comments. Sub-sections: Description, Access Routes.

Notes:

Game Areas

YES

Table with 3 columns: Description, YES/NO, Comments. Sub-sections: Description, Access Routes, Equipment.

Notes:

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Table with 3 columns: Description, YES/NO, Comments. Sub-sections: Site Access, Path of Travel.

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A

Facility Name: West Newton Commons Playground

Size (Ac): 3.7 acres

Address: Elm Road and Webster Street, West Newton

Ward: 3

General Facility Notes: Circumvented by sidewalks on 3 sides; no internal pathways; On-street parking; accessible route from sidewalk to tot lot constructed in 2020.

Site Furnishings

YES

Description		Comments
Tables & Benches		
Number of Benches	YES	7 benches
Number of Tables	NO	
Located adjacent to accessible paths	NO	
Back and Arm Rests	YES	all benches have back rests; no arm rests

Trash Cans

Located adjacent to accessible paths		
--------------------------------------	--	--

Notes:

Trails & Paths

YES

Description		Comments
Surface (A=Asphalt, C=Concrete, SD= stone dust, NS= naturally surfaced, B=Boardwalk, BR=Bridge)	YES	A
Dimensions (width)	YES	5 feet wide
Rails	NO	
Signage for visually impaired	NO	

Notes: accessible route from Webster street entrance to the play area.

Play Areas

YES

Description		Comments
Facility Type (3-5 Yrs, 5-12 Yrs)	YES	3-5 Yrs, renovated in 1995
Same experience provided to all	NO	

Access Routes

Located adjacent to accessible paths	YES	
Enough space between equipment for wheelchair	YES	

Notes:

Game Areas

YES

Description		Comments
Facility Type (RF=Rectangular Fields, BF=Ballfields, BK=Basketball, TN=Tennis, BC= Bocce)	YES	1 RF, 1 BF

Access Routes

Located adjacent to accessible paths	NO	
--------------------------------------	----	--

Equipment

Spectator Seating	YES	
-------------------	-----	--

Notes:

Boat Docks

N/A

Fishing Facilities

N/A

Community Gardens

N/A

Parking

N/A

Ramps

N/A

Site Access, Path of Travel, Entrances

YES

Description		Comments
Path does not require the use of stairs	YES	
Path does not require the use of wheelchair ramp	YES	
Path is stable, firm and slip resistant	YES	
Slope maximum 1:20 (5%) and maximum cross pitch is 2% (1:50).	YES	
Continuous common surface, no changes in level greater than 1/8 inch	YES	
Any objects protruding onto the pathway must be detected by a person with a visual disability using a cane.	NO	

Notes:

Stairs and Doors

N/A

Restrooms

N/A

Floors, Drinking Fountains, Telephones

N/A

Signs, Signals, and Switches

N/A

Swimming Pool/ Lake beach

N/A

Shower Rooms

N/A

Picnicking

N/A

Off Leash Dog Areas (OLA)

N/A